

LEBA, Poland

WMO: 121200

Lat: 54.7536N

Lon: 17.5347E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-8.8	-14.6	1.1	-10.4	-12.0	1.3	-8.0	18.1	5.9	16.1	5.4	2.4	180	0.650

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	26.8	19.4	24.5	18.7	22.7	18.1	20.7	24.7	19.7	22.9	18.8	21.7	4.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.2	22.6	18.5	13.4	21.5	17.6	12.6	20.5	60.0	24.8	56.3	22.9	53.4	21.8	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.0	10.4	DB	-14.6	30.8	4.2	1.8	-17.7	32.0	-20.1	33.1	-22.5	34.1	-25.6	35.4	(4)
(5)			WB	-15.0	22.9	4.1	1.6	-18.0	24.0	-20.4	25.0	-22.7	25.8	-25.7	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-0.2	0.3	2.6	6.8	10.9	14.6	17.1	17.3	13.9	9.4	4.9	1.5
	DBStd	7.12	4.31	4.04	3.42	3.90	3.80	2.95	2.68	2.51	2.69	3.18	3.26	4.07
	HDD10.0	1434	316	271	229	114	32	1	0	0	3	51	153	264
	HDD18.3	3708	574	504	487	347	232	119	56	51	134	278	402	522
	CDD10.0	818	0	0	1	17	61	139	222	226	120	31	1	0
	CDD18.3	49	0	0	0	1	3	7	19	18	2	0	0	0
	CDH23.3	324	0	0	0	7	32	63	116	95	11	0	0	0
	CDH26.7	69	0	0	0	1	4	17	27	19	1	0	0	0
Wind	WSAvg	4.7	5.3	5.3	5.0	4.5	4.4	4.7	4.3	4.1	4.2	4.6	4.7	5.3
Precipitation	PrecAvg	677	42	33	37	30	48	56	78	80	78	73	60	59
	PrecMax	909	131	60	101	72	123	118	225	195	198	203	145	106
	PrecMin	421	3	6	13	5	8	13	3	3	13	17	7	19
	PrecStd	128	25	13	20	16	33	30	50	42	44	44	34	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	10.2	14.3	24.0	27.1	29.3	29.9	29.3	24.9	19.5	13.1	10.2
		MCWB	7.4	7.6	8.7	14.3	17.7	20.5	21.3	21.8	17.9	14.7	11.3	8.6
	2%	DB	7.1	7.8	10.8	19.0	22.9	24.8	26.4	25.9	22.0	16.7	11.4	8.5
		MCWB	6.0	6.0	7.6	11.9	16.4	18.3	20.1	19.3	16.8	14.1	9.9	7.4
	5%	DB	6.0	6.4	8.7	15.7	19.8	21.7	23.9	23.6	20.0	15.1	10.2	7.4
		MCWB	5.0	5.1	6.5	10.5	14.8	17.0	19.2	18.8	16.3	13.1	9.0	6.4
	10%	DB	4.9	5.3	7.1	12.9	17.2	19.7	22.1	22.1	18.3	13.9	9.2	6.5
		MCWB	4.0	4.3	5.4	9.0	13.5	16.0	18.4	18.4	15.5	12.3	8.2	5.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.1	10.1	15.2	18.7	21.1	22.6	22.3	19.5	15.7	11.7	9.1
		MCDB	8.7	9.5	12.7	22.8	24.7	27.6	27.2	27.2	22.8	17.7	12.6	9.9
	2%	WB	6.2	6.3	8.1	12.6	17.0	19.0	21.0	20.6	17.7	14.3	10.2	7.7
		MCDB	6.9	7.4	9.9	17.9	22.1	23.4	25.0	23.9	20.4	16.1	11.1	8.3
	5%	WB	5.1	5.3	6.7	10.9	15.3	17.5	19.9	19.6	16.7	13.4	9.2	6.6
		MCDB	5.9	6.1	8.4	14.8	19.0	21.1	23.0	22.5	19.1	14.9	10.0	7.3
	10%	WB	4.1	4.3	5.6	9.5	13.7	16.4	18.9	18.8	15.8	12.5	8.3	5.6
		MCDB	4.8	5.2	6.9	12.4	16.7	19.2	21.5	21.5	18.0	13.8	9.1	6.4
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.5	5.6	7.5	7.9	7.4	7.1	7.8	7.0	5.9	4.2	3.7
		MCDBR	3.9	5.5	8.4	12.6	12.5	11.9	10.9	10.8	10.0	7.7	4.9	3.8
		MCWBR	3.6	4.2	5.7	7.0	6.8	6.7	6.0	6.1	5.9	5.2	3.9	3.5
	5% WB	MCDBR	3.8	5.0	7.4	11.0	11.1	10.6	9.2	9.3	8.3	7.0	4.6	3.8
		MCWBR	3.5	4.1	5.4	6.6	6.5	6.5	5.6	6.0	5.6	5.1	4.0	3.6
Clear-Sky Solar Irradiance	taub	0.315	0.341	0.365	0.406	0.400	0.395	0.422	0.417	0.379	0.362	0.345	0.312	
	taud	2.287	2.291	2.280	2.232	2.316	2.364	2.308	2.323	2.405	2.410	2.321	2.280	
	Ebn at Noon	615	730	800	815	845	853	819	797	783	704	570	530	
	Edh at Noon	58	81	102	122	119	115	119	111	90	72	57	48	
All-Sky Solar Radiation	RadAvg	0.45	1.10	2.39	4.23	5.56	5.93	5.34	4.41	3.12	1.55	0.60	0.32	
	RadStd	0.06	0.16	0.23	0.48	0.58	0.41	0.57	0.41	0.34	0.23	0.09	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	+0.40	N/A	N/A	N/A	N/A	N/A	-150	+61	N/A	(46)
(47)	Regional (29 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	-126	+59	N/A	(47)

Nomenclature: See separate page