

DARLOWO, Poland

WMO: 121240

Lat: 54.4054N

Lon: 16.3516E

Elev: 16

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	14.9	4.4	6.9	11.6	9.6	9.0	16.5	27.9	40.3	25.8	39.4	6.2	100	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	82.2	67.3	78.4	65.8	75.0	64.9	69.7	77.9	67.9	75.0	66.4	72.7	9.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.0	99.4	72.7	65.4	94.0	70.9	63.9	88.8	69.4	33.7	78.2	32.3	74.9	31.0	72.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.5	18.2	DB	1.8	89.1	9.1	3.2	-4.8	91.4	-10.1	93.2	-15.3	95.0	-21.9	97.3	(4)
(5)			WB	2.2	73.4	9.0	1.9	-4.3	74.8	-9.5	75.9	-14.6	77.0	-21.1	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	31.4	32.6	37.1	45.2	52.9	59.3	63.9	64.0	57.7	49.1	41.9	36.1	(6)	
	DBStd	13.08	8.73	7.41	6.67	6.57	6.98	5.55	4.75	4.59	4.74	5.71	5.35	7.59	(7)	
	HDD50	2450	577	487	400	175	43	1	0	0	3	88	244	432	(8)	
	HDD65	6439	1042	907	864	593	383	189	79	75	224	494	692	897	(9)	
	CDD50	1605	0	0	2	32	133	280	430	434	233	58	3	0	(10)	
	CDD65	118	0	0	0	0	8	18	44	44	4	0	0	0	(11)	
	CDH74	936	0	0	0	4	103	167	339	289	34	0	0	0	(12)	
	CDH80	208	0	0	0	0	20	36	86	63	3	0	0	0	(13)	
(14) Wind	WSAvg	8.9	10.4	9.6	9.0	8.6	7.7	8.0	7.9	7.6	8.5	9.2	9.9	10.9	(14)	
(15) Precipitation	PrecAvg	28.2	2.0	1.4	1.7	1.4	2.3	2.8	3.1	3.5	3.0	2.5	2.3	2.2	(15)	
	PrecMax	39.4	5.7	2.5	3.9	3.1	4.0	8.7	6.6	7.8	7.2	6.2	4.1	4.0	(16)	
	PrecMin	22.7	0.1	0.1	0.3	0.4	0.7	0.0	0.6	0.5	0.9	0.6	0.2	0.6	(17)	
	PrecStd	4.1	1.2	0.7	0.9	0.7	0.8	1.7	1.7	1.7	1.4	1.5	1.0	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	50.5	60.8	72.3	82.7	84.7	87.6	86.8	78.3	67.3	56.3	52.2	(19)	
		MCWB	47.3	44.3	48.3	56.9	65.3	67.1	70.5	69.4	64.3	58.6	51.9	49.0	(20)	
	2%	DB	46.6	45.8	54.1	66.3	76.6	78.8	82.2	80.6	73.4	62.9	53.0	49.3	(21)	
		MCWB	44.2	42.3	47.0	53.1	62.8	64.8	68.4	67.1	63.0	57.6	50.2	46.6	(22)	
	5%	DB	44.3	43.3	49.5	61.6	70.4	74.1	77.5	76.8	69.5	59.9	51.2	46.6	(23)	
		MCWB	42.7	40.6	45.1	51.3	59.7	63.3	66.6	66.4	61.5	55.8	49.0	44.3	(24)	
	10%	DB	41.9	41.1	45.7	57.0	65.4	69.1	73.9	73.1	65.9	57.5	49.5	44.7	(25)	
		MCWB	40.3	39.1	42.3	48.8	57.0	61.2	65.6	65.1	60.5	54.4	47.5	43.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	45.8	51.6	58.5	67.8	69.7	72.5	71.8	67.9	60.6	52.4	50.1	(27)	
		MCDB	50.9	48.7	55.2	68.4	80.3	80.2	82.4	81.1	75.5	64.3	54.6	51.4	(28)	
	2%	WB	44.6	43.0	47.8	54.6	63.7	66.6	70.1	69.2	64.6	58.2	50.7	47.0	(29)	
		MCDB	46.0	45.4	53.0	64.1	74.4	75.7	78.4	76.7	68.9	61.8	52.4	48.9	(30)	
	5%	WB	42.6	40.9	45.1	51.9	60.8	64.3	68.2	67.7	62.8	56.5	49.3	44.5	(31)	
		MCDB	44.0	42.8	49.3	59.9	68.1	72.0	75.0	74.0	67.4	59.5	51.0	45.8	(32)	
	10%	WB	40.4	39.3	42.6	49.4	57.8	62.2	66.5	66.2	61.1	54.6	47.7	43.1	(33)	
		MCDB	41.7	41.0	45.4	56.2	64.1	67.8	72.4	71.8	65.7	57.3	49.3	44.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	9.0	11.2	15.6	15.5	14.6	14.3	14.7	13.8	11.5	8.2	7.2	(35)	
		MCDBR	7.1	11.7	17.8	24.8	25.1	24.0	23.0	22.8	21.2	15.5	9.8	7.7	(36)	
	5% WB	MCWBR	6.6	9.0	11.8	14.3	13.5	12.8	11.9	12.0	12.3	10.9	7.9	6.7	(37)	
		MCWBR	6.8	9.8	16.5	22.3	22.8	20.0	19.3	18.3	16.9	14.0	8.9	7.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.316	0.341	0.367	0.405	0.402	0.396	0.421	0.419	0.380	0.363	0.343	0.312	(40)	
		taud	2.303	2.309	2.286	2.248	2.316	2.363	2.313	2.323	2.407	2.407	2.339	2.298	(41)	
	Ebn at Noon	Ebn at Noon	198	234	254	259	268	270	260	253	249	224	185	172	(42)	
		Edh at Noon	18	25	32	38	38	36	38	35	29	23	18	15	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	150	354	748	1315	1706	1808	1642	1365	980	497	195	107	(44)	
	RadStd	RadStd	20	50	76	153	189	133	186	127	105	73	28	10	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-234	+106	N/A

Nomenclature: See separate page