

CEWICE LEBUNIA, Poland

WMO: 121360

Lat: 54.417N

Lon: 17.767E

Elev: 495

StdP: 14.43

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.6	10.5	-0.4	5.5	6.4	5.3	7.3	11.6	27.8	39.6	24.5	39.7	3.5	110	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	83.9	66.2	80.4	65.2	77.0	63.6	69.1	78.9	67.2	76.3	65.4	73.6	8.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	97.6	73.2	64.1	91.4	70.7	62.4	85.7	69.2	33.5	78.8	32.0	76.0	30.5	73.3	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 21.6	18.6	16.3		-4.3	89.9	9.8	4.1	-11.4	92.9	-17.1	95.3	-22.6	97.6	-29.8	100.6	
(5)			DB	-4.1	72.7	9.7	1.9	-11.1	74.1	-16.7	75.3	-22.2	76.4	-29.2	77.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.1	28.4	30.1	35.8	44.8	52.7	58.9	63.4	63.0	55.5	46.6	39.4	33.1	(6)
	DBStd	14.03	9.22	8.33	7.77	7.21	7.48	6.04	5.66	5.32	5.62	6.34	5.84	8.14	(7)
	HDD50	2909	669	556	442	188	54	3	0	0	13	142	319	523	(8)
	HDD65	7028	1134	976	905	606	389	200	101	102	290	569	768	988	(9)
	CDD50	1479	0	0	2	32	138	271	416	404	177	38	1	0	(10)
	CDD65	122	0	0	0	0	7	19	51	41	4	0	0	0	(11)
	CDH74	1436	0	0	0	14	115	272	578	409	48	0	0	0	(12)
	CDH80	332	0	0	0	2	15	66	162	80	7	0	0	0	(13)
	WSAvg	7.4	8.2	8.0	8.0	7.5	7.1	7.1	6.8	6.4	6.6	7.3	7.7	8.4	(14)
	PrecAvg	28.7	2.1	1.6	1.9	1.4	2.5	2.9	3.5	3.0	2.8	2.4	2.4	2.4	(15)
(16) Precipitation	PrecMax	37.9	6.4	3.2	4.7	3.1	4.7	7.0	8.4	5.1	6.1	6.1	5.3	5.0	(16)
	PrecMin	21.3	0.2	0.3	0.5	0.1	0.6	0.2	0.6	1.2	1.0	0.7	0.4	0.7	(17)
	PrecStd	4.5	1.3	0.7	1.1	0.8	1.0	1.5	1.8	1.0	1.3	1.5	1.2	1.2	(18)
	PrecStd	4.5	1.3	0.7	1.1	0.8	1.0	1.5	1.8	1.0	1.3	1.5	1.2	1.2	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	48.6	60.8	75.4	81.8	87.5	89.7	86.2	80.1	67.6	54.8	50.4	(19)
		MCWB	46.6	44.7	49.0	56.9	63.1	69.3	68.4	69.0	64.3	57.9	49.7	48.3	(20)
	2%	DB	44.8	45.5	55.6	68.8	77.1	80.8	84.4	82.1	73.8	62.8	51.7	47.8	(21)
		MCWB	43.1	42.1	45.8	53.8	62.0	64.9	66.2	66.5	61.4	55.8	49.0	46.5	(22)
	5%	DB	42.5	42.6	51.1	64.3	73.1	76.6	80.3	78.8	70.0	59.3	49.8	45.0	(23)
		MCWB	41.0	40.1	44.4	50.9	59.4	62.3	65.7	65.1	59.7	54.2	47.7	43.4	(24)
	10%	DB	39.8	40.4	46.8	59.8	68.5	72.6	76.6	75.2	66.4	56.6	47.8	42.9	(25)
		MCWB	38.6	38.3	42.5	48.8	56.7	60.3	64.2	64.0	58.3	52.8	46.2	41.6	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	46.6	51.3	59.4	66.5	70.8	71.6	71.4	66.4	59.7	51.3	49.1	(27)
		MCDB	48.3	47.8	57.6	75.1	75.7	81.9	83.3	82.7	75.1	64.6	52.9	50.0	(28)
	2%	WB	43.3	42.3	47.6	54.8	63.5	66.9	69.2	68.6	63.4	57.2	49.3	46.2	(29)
		MCDB	44.3	44.2	52.2	65.7	75.1	76.9	79.2	77.5	70.7	61.5	50.8	47.3	(30)
	5%	WB	40.7	40.1	45.1	52.2	60.9	64.0	67.5	66.7	61.1	55.1	47.8	43.6	(31)
		MCDB	41.8	42.0	49.7	62.2	70.5	73.6	76.8	75.3	67.7	58.6	49.3	44.6	(32)
	10%	WB	38.6	38.2	42.7	49.7	58.2	61.7	65.6	64.9	59.3	53.1	46.0	41.5	(33)
		MCDB	39.8	40.0	46.2	57.7	66.8	69.9	73.3	72.5	65.2	56.2	47.4	42.6	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	8.8	11.0	15.3	22.0	21.9	20.9	19.5	19.9	18.0	13.9	8.7	7.8	(35)
		MCDBR	7.7	12.8	22.4	30.3	28.1	28.3	26.9	26.1	23.9	18.2	10.6	7.9	(36)
		MCWBR	7.2	10.1	14.4	16.7	14.7	14.2	12.0	12.9	13.0	12.2	8.6	7.5	(37)
	5% WB	MCDBR	7.3	11.2	19.2	26.8	25.0	24.6	22.2	22.8	20.5	15.8	10.2	7.7	(38)
		MCWBR	7.1	9.5	13.6	15.5	13.6	13.4	11.4	12.7	12.0	11.4	8.7	7.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.305	0.333	0.361	0.403	0.396	0.391	0.419	0.413	0.373	0.355	0.338	0.302	(40)
	taud		2.270	2.275	2.276	2.221	2.297	2.340	2.281	2.301	2.393	2.416	2.326	2.273	(41)
	Ebn at Noon		201	236	256	260	269	272	261	254	251	227	187	175	(42)
	Edh at Noon		19	26	32	39	38	37	39	36	29	23	18	15	(43)
(44) All-Sky Solar Radiation	RadAvg		150	357	749	1314	1704	1799	1628	1367	978	497	193	108	(44)
	RadStd		20	51	80	156	183	138	183	131	106	74	27	11	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (27 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-234	+121	N/A	

Nomenclature: See separate page