

GDANSK NOWY PORT, Poland

WMO: 121400

Lat: 54.3997N

Lon: 18.6978E

Elev: 10

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 01-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	13.8	3.3	6.5	8.6	8.2	8.4	14.2	38.4	34.6	31.5	37.0	9.2	200	0.621

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	78.8	67.1	75.5	65.4	72.9	65.1	69.5	74.6	68.1	72.5	66.7	71.3	11.7	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	101.7	72.3	66.2	96.7	71.1	64.7	91.5	70.2	33.6	74.8	32.4	72.6	31.3	71.5	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.0	23.8	20.5	3.6	86.6	8.0	3.5	-2.1	89.1	-6.8	91.1	-11.3	93.1	-17.1	95.6		
			2.8	71.9	7.4	1.5	-2.5	73.0	-6.8	73.8	-10.9	74.7	-16.3	75.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	31.3	31.7	38.0	45.2	54.0	60.4	65.8	65.6	59.3	49.3	41.6	34.0
	DBStd	13.86	9.57	8.32	6.67	5.43	5.75	4.76	4.45	3.95	4.27	5.82	5.22	7.88
	HDD50	2491	581	513	374	165	22	0	0	0	0	84	255	497
	HDD65	6318	1046	933	837	595	344	151	42	41	177	488	703	961
	CDD50	1798	0	0	1	20	147	313	491	483	280	61	2	0
	CDD65	151	0	0	0	0	4	14	68	59	6	0	0	0
	CDH74	454	0	0	0	0	31	48	213	127	35	0	0	0
	CDH80	74	0	0	0	0	1	6	45	18	4	0	0	0
Wind	WSAvg	10.2	11.2	11.3	10.9	10.3	9.2	9.7	9.0	9.4	9.6	10.0	10.5	10.8
Precipitation	PrecAvg	22.4	1.3	1.0	1.2	1.2	2.1	2.3	3.0	2.6	2.3	2.0	1.9	1.5
	PrecMax	28.6	3.0	1.9	2.1	3.0	3.6	5.4	6.7	5.3	4.9	4.6	4.1	2.7
	PrecMin	15.3	0.2	0.1	0.2	0.0	0.6	0.4	0.6	0.4	0.6	0.5	0.6	0.6
	PrecStd	3.1	0.6	0.4	0.5	0.7	0.9	1.3	1.4	1.3	1.2	1.1	0.8	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.6	51.3	59.0	68.8	79.0	79.7	85.5	82.1	78.6	67.0	54.4	52.2
		MCWB	47.4	47.5	49.4	54.0	64.7	66.0	68.2	66.7	63.6	59.0	50.4	48.8
	2%	DB	47.6	48.7	52.9	61.0	71.2	74.2	79.1	77.3	72.4	62.8	52.7	47.2
		MCWB	43.8	45.7	46.4	50.8	60.3	62.1	68.7	66.5	61.5	56.6	49.3	44.3
	5%	DB	45.2	45.0	49.9	56.1	66.5	70.4	75.5	74.2	69.3	60.0	50.8	45.2
		MCWB	42.1	41.9	44.7	49.1	59.3	61.9	66.8	65.8	60.7	55.3	47.7	42.8
	10%	DB	43.1	42.3	46.9	53.0	62.9	67.9	72.9	72.3	67.0	57.5	49.1	43.3
		MCWB	40.4	39.4	43.0	47.5	56.8	60.7	66.0	65.5	60.3	53.6	46.3	41.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.2	48.7	51.2	54.6	66.2	67.5	72.4	71.3	66.5	60.8	51.6	48.8
		MCDB	52.6	50.6	55.3	63.6	73.4	74.3	79.7	76.1	71.5	65.3	53.4	51.6
	2%	WB	44.5	45.8	47.5	51.9	63.0	65.1	70.2	69.2	64.3	57.4	49.7	44.8
		MCDB	47.1	48.9	52.1	59.0	70.5	71.2	76.3	73.5	69.7	61.2	52.2	46.5
	5%	WB	42.3	42.3	45.1	50.1	59.9	63.6	68.6	68.0	62.5	55.7	48.1	43.0
		MCDB	44.8	44.8	49.1	55.1	65.9	69.1	73.6	71.8	67.6	59.3	50.3	45.0
	10%	WB	40.2	39.5	43.0	48.3	57.0	61.9	67.2	66.7	60.7	54.1	46.6	41.2
		MCDB	42.9	41.8	46.5	52.5	62.1	66.7	71.8	71.0	66.0	57.2	48.6	43.2
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.5	8.9	9.8	10.8	10.1	9.8	10.3	11.4	9.6	6.9	6.7
		MCDBR	7.9	8.7	14.1	17.6	19.4	15.9	15.6	14.7	17.4	13.0	8.2	7.2
		MCWBR	6.9	7.3	9.1	10.3	10.4	8.5	7.8	7.5	9.1	8.1	6.4	6.3
	5% WB	MCDBR	7.7	8.9	13.0	14.2	17.2	13.7	11.8	10.6	13.8	11.9	7.8	7.2
		MCWBR	7.1	7.7	9.2	9.2	10.0	8.3	7.3	6.6	8.7	8.1	6.4	6.5
Clear-Sky Solar Irradiance	taub		0.311	0.340	0.367	0.411	0.401	0.398	0.430	0.421	0.380	0.362	0.346	0.310
	taud		2.283	2.290	2.285	2.215	2.311	2.353	2.282	2.310	2.402	2.430	2.331	2.290
	Ebn at Noon		199	234	254	257	268	270	258	252	249	225	184	173
	Edh at Noon		19	26	32	40	38	37	39	36	29	23	18	15
All-Sky Solar Radiation	RadAvg		152	365	758	1327	1717	1795	1615	1386	984	500	190	110
	RadStd		20	56	89	162	169	150	182	134	108	77	24	14

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-241	+121	N/A

Nomenclature: See separate page