

GDANSKI PRUSZCZ, Poland

WMO: 121460

Lat: 54.2438N

Lon: 18.6690E

Elev: 21

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.6	12.6	1.7	6.0	7.2	7.5	8.1	13.9	25.0	40.0	21.9	38.9	2.1	140	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.6	84.2	67.9	80.8	67.0	77.9	65.8	71.1	79.9	69.1	77.3	67.3	74.9	6.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.1	103.4	75.5	66.2	96.7	73.2	64.3	90.3	71.6	35.0	80.0	33.2	77.5	31.8	74.7	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	16.5	14.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.2	30.1	31.7	37.7	46.5	55.1	61.6	65.9	65.6	58.8	48.6	40.1	35.5
	DBStd	14.21	10.33	7.45	7.70	6.27	6.89	5.29	4.93	4.72	4.85	6.34	5.62	7.15
	HDD50	2531	617	512	385	142	25	0	0	0	1	102	298	449
	HDD65	6329	1082	932	847	556	319	130	50	49	196	507	747	914
	CDD50	1871	0	0	3	35	182	347	494	485	264	60	1	0
	CDD65	194	0	0	0	0	10	27	79	69	9	0	0	0
	CDH74	1702	0	0	0	7	135	294	603	568	95	0	0	0
	CDH80	378	0	0	0	0	20	72	139	125	22	0	0	0
(14) Wind	WSAvg	5.5	5.8	5.6	6.3	6.2	5.6	5.5	5.6	4.8	4.7	5.0	5.0	6.1
(15) Precipitation	PrecAvg	22.4	1.3	1.0	1.2	1.2	2.1	2.3	3.0	2.6	2.3	2.0	1.9	1.5
	PrecMax	28.6	3.0	1.9	2.1	3.0	3.6	5.4	6.7	5.3	4.9	4.6	4.1	2.7
	PrecMin	15.3	0.2	0.1	0.2	0.0	0.6	0.4	0.6	0.4	0.6	0.5	0.6	0.6
	PrecStd	3.1	0.6	0.4	0.5	0.7	0.9	1.3	1.4	1.3	1.2	1.1	0.8	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.7	51.2	62.2	74.1	82.5	87.5	88.5	89.0	83.7	70.5	54.5	51.2
		MCWB	47.4	46.2	50.8	58.4	65.7	71.0	69.9	69.0	67.1	59.2	50.8	48.2
	2%	DB	47.7	48.0	56.1	68.0	78.1	80.9	84.0	83.0	76.1	65.1	52.4	48.6
		MCWB	44.8	43.8	47.6	53.9	65.0	66.6	68.2	67.8	64.1	56.8	49.7	46.2
	5%	DB	45.0	44.3	52.2	62.9	72.8	76.8	80.2	79.8	72.2	61.6	50.4	46.6
		MCWB	42.3	40.5	45.9	52.2	61.2	64.7	67.8	66.5	62.3	55.8	48.2	44.1
	10%	DB	42.7	41.4	48.7	59.2	68.5	73.1	77.1	76.8	69.0	58.3	48.5	44.7
		MCWB	40.4	38.5	44.1	50.5	58.8	63.0	66.2	65.4	60.4	54.1	46.7	42.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	47.7	52.7	59.3	69.1	72.5	74.7	73.7	68.6	60.8	52.1	49.2
		MCDB	51.0	49.6	58.8	71.7	78.5	84.2	82.4	81.6	79.4	66.7	53.8	51.1
	2%	WB	45.3	43.6	49.0	56.0	65.7	68.3	71.6	70.5	65.9	58.2	50.1	46.7
		MCDB	47.5	47.5	54.2	65.8	76.0	77.2	79.6	78.9	73.6	63.1	51.7	48.6
	5%	WB	42.6	40.8	46.7	53.5	62.9	65.8	69.4	68.7	63.5	56.2	48.4	44.4
		MCDB	44.6	44.0	51.3	61.2	71.1	74.8	77.4	76.5	69.8	60.7	50.1	46.4
	10%	WB	40.3	38.6	44.2	50.6	59.7	63.8	67.4	66.9	61.6	54.5	46.8	42.6
		MCDB	42.5	41.3	48.2	57.4	66.8	71.6	74.3	74.0	67.4	58.1	48.4	44.5
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.3	14.4	19.5	19.8	19.4	17.6	19.2	18.0	14.0	9.1	8.0
		MCDBR	8.5	12.9	21.0	27.4	26.5	25.5	23.8	24.8	25.2	20.6	11.4	9.5
	5% WB	MCWBR	7.4	9.6	13.9	16.1	14.2	13.2	11.3	11.6	14.1	13.3	9.5	8.3
		MCWBR	8.4	12.6	18.5	24.5	23.8	23.5	20.9	20.8	22.1	18.2	11.2	9.5
(40) Clear-Sky Solar Irradiance	taub		0.309	0.339	0.368	0.413	0.403	0.399	0.432	0.422	0.380	0.362	0.345	0.309
		taud	2.273	2.281	2.276	2.202	2.295	2.336	2.264	2.294	2.390	2.425	2.332	2.287
	Ebn at Noon		200	234	254	257	267	270	257	252	249	226	185	174
		Edh at Noon	19	26	33	40	38	37	40	36	29	23	18	16
(44) All-Sky Solar Radiation	RadAvg		160	374	767	1326	1708	1786	1609	1387	987	507	193	115
	RadStd		23	56	93	164	169	152	182	134	111	78	25	15

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-252	+126	N/A

Nomenclature: See separate page