

GDANSKI PRUSZCZ, Poland

WMO: 121460

Lat: 54.2438N

Lon: 18.6690E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-10.8	-16.8	0.9	-13.8	-13.6	1.2	-10.0	11.2	4.4	9.8	3.8	0.9	140	0.526

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	29.0	20.0	27.1	19.4	25.5	18.8	21.7	26.6	20.6	25.2	19.6	23.8	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	14.8	24.1	19.0	13.8	22.9	17.9	12.9	22.0	63.4	26.6	59.4	25.3	56.1	23.7	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.4	6.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-1.1	-0.2	3.1	8.0	12.8	16.4	18.9	18.7	14.9	9.2	4.5	2.0
	DBStd	7.90	5.74	4.14	4.28	3.48	3.83	2.94	2.74	2.62	2.70	3.52	3.12	3.97
	HDD10.0	1406	343	284	214	79	14	0	0	0	1	57	166	249
	HDD18.3	3516	601	518	471	309	177	72	28	27	109	282	415	508
	CDD10.0	1039	0	0	2	19	101	193	274	269	147	33	1	0
	CDD18.3	108	0	0	0	0	6	15	44	38	5	0	0	0
	CDH23.3	946	0	0	0	4	75	163	335	316	53	0	0	0
	CDH26.7	210	0	0	0	0	11	40	77	69	12	0	0	0
(14) Wind	WSAvg	2.5	2.6	2.5	2.8	2.8	2.5	2.4	2.5	2.2	2.1	2.2	2.2	2.7
(15) Precipitation	PrecAvg	569	32	26	30	30	53	59	76	65	59	52	48	39
	PrecMax	726	76	47	53	76	91	137	169	134	124	118	104	68
	PrecMin	388	5	3	6	1	15	10	15	10	16	13	16	14
	PrecStd	80	16	10	13	18	23	32	35	33	31	29	21	15
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	10.7	16.8	23.4	28.1	30.9	31.4	31.7	28.7	21.4	12.5	10.7
		MCWB	8.5	7.9	10.4	14.7	18.7	21.7	21.1	20.5	19.5	15.1	10.5	9.0
	2%	DB	8.7	8.9	13.4	20.0	25.6	27.2	28.9	28.4	24.5	18.4	11.3	9.2
		MCWB	7.1	6.6	8.7	12.2	18.3	19.2	20.1	19.9	17.8	13.8	9.8	7.9
	5%	DB	7.2	6.8	11.2	17.2	22.7	24.9	26.8	26.5	22.3	16.4	10.2	8.1
		MCWB	5.7	4.7	7.7	11.2	16.2	18.2	19.9	19.1	16.8	13.2	9.0	6.7
	10%	DB	5.9	5.2	9.3	15.1	20.3	22.8	25.0	24.9	20.6	14.6	9.2	7.1
		MCWB	4.7	3.6	6.7	10.3	14.9	17.2	19.0	18.5	15.8	12.3	8.2	5.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	8.7	11.5	15.2	20.6	22.5	23.7	23.2	20.3	16.0	11.2	9.6
		MCDB	10.6	9.8	14.9	22.0	25.8	29.0	28.0	27.6	26.4	19.3	12.1	10.6
	2%	WB	7.4	6.4	9.5	13.3	18.7	20.2	22.0	21.4	18.8	14.6	10.0	8.1
		MCDB	8.6	8.6	12.3	18.8	24.5	25.1	26.5	26.0	23.1	17.3	11.0	9.2
	5%	WB	5.9	4.9	8.2	12.0	17.2	18.8	20.8	20.4	17.5	13.5	9.1	6.9
		MCDB	7.0	6.7	10.7	16.2	21.7	23.8	25.2	24.7	21.0	15.9	10.0	8.0
	10%	WB	4.6	3.7	6.8	10.4	15.4	17.7	19.7	19.4	16.4	12.5	8.2	5.9
		MCDB	5.9	5.2	9.0	14.1	19.3	22.0	23.5	23.3	19.6	14.5	9.1	7.0
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.7	8.0	10.8	11.0	10.8	9.8	10.7	10.0	7.8	5.0	4.4
		MCDBR	4.7	7.2	11.7	15.2	14.7	14.1	13.2	13.8	14.0	11.4	6.3	5.3
		MCWBR	4.1	5.4	7.7	9.0	7.9	7.3	6.3	6.4	7.8	7.4	5.3	4.6
	5% WB	MCDWR	4.7	7.0	10.3	13.6	13.2	13.0	11.6	11.6	12.3	10.1	6.2	5.3
		MCWBR	4.2	5.4	7.4	8.5	7.6	7.3	6.4	6.4	7.3	7.0	5.3	4.7
(40) Clear-Sky Solar Irradiance	taub		0.309	0.339	0.368	0.413	0.403	0.399	0.432	0.422	0.380	0.362	0.345	0.309
	taud		2.273	2.281	2.276	2.202	2.295	2.336	2.264	2.294	2.390	2.425	2.332	2.287
	Ebn at Noon		632	739	801	810	843	850	811	794	784	711	584	550
	Edh at Noon		59	82	103	126	121	118	125	114	92	72	57	49
(44) All-Sky Solar Radiation	RadAvg		0.50	1.18	2.42	4.18	5.38	5.63	5.07	4.37	3.11	1.60	0.61	0.36
	RadStd		0.07	0.18	0.29	0.52	0.53	0.48	0.57	0.42	0.35	0.25	0.08	0.05

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (27 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-140	+70	N/A	

Nomenclature: See separate page