

GDANSK LECHA WALESY, Poland

WMO: 121500

Lat: 54.3805N

Lon: 18.4719E

Elev: 138

StdP: 99.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.0	-11.9	-17.2	0.8	-14.3	-14.2	1.1	-11.1	14.3	4.6	12.5	4.2	2.2	120	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	27.2	19.1	25.8	18.4	24.0	17.7	20.6	25.4	19.5	23.9	18.5	22.7	4.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	14.0	22.8	17.9	13.1	21.7	16.9	12.3	20.7	59.9	25.3	56.4	23.6	53.3	22.2	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.9	9.3	8.1	-19.2	31.2	4.9	2.0	-22.7	32.7	-25.6	33.9	-28.3	35.0	-31.9	36.4		
(5)			-19.4	22.8	4.9	1.1	-22.9	23.5	-25.7	24.2	-28.5	24.8	-32.0	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-1.6	-0.9	2.1	7.1	11.6	15.1	17.5	17.4	13.3	8.5	3.7	0.1	(6)
(7)		DBStd	7.85	5.12	4.92	4.16	4.03	3.85	3.08	2.84	2.69	2.93	3.52	3.67	4.71	(7)
(8)		HDD10.0	1615	361	307	245	104	25	1	0	0	6	72	189	307	(8)
(9)		HDD18.3	3877	619	540	502	336	211	105	50	51	154	306	438	565	(9)
(10)		CDD10.0	839	0	0	1	18	75	154	234	229	103	24	1	0	(10)
(11)		CDD18.3	61	0	0	0	0	3	9	26	21	2	0	0	0	(11)
(12)		CDH23.3	505	0	0	0	5	34	89	206	153	18	0	0	0	(12)
(13)		CDH26.7	101	0	0	0	0	3	19	51	24	3	0	0	0	(13)
(14)	Wind	WSAvg	3.7	4.2	4.1	4.2	3.8	3.6	3.7	3.4	3.2	3.3	3.6	3.7	4.0	(14)
(15)	Precipitation	PrecAvg	551	30	24	23	30	44	58	70	71	47	51	61	38	(15)
(16)		PrecMax	771	71	54	38	76	97	119	204	154	93	166	109	78	(16)
(17)		PrecMin	328	6	1	4	5	16	5	14	16	12	10	25	3	(17)
(18)		PrecStd	115	18	13	10	20	25	30	42	42	24	35	24	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	9.9	15.1	23.8	26.9	29.3	31.0	29.2	25.9	19.9	12.9	10.1	(19)
(20)			MCWB	7.8	7.6	9.1	14.4	17.7	20.4	20.9	19.8	18.0	15.0	11.3	9.1	(20)
(21)		2%	DB	7.0	8.0	12.1	19.8	23.9	25.9	27.9	26.9	22.2	17.1	11.0	8.2	(21)
(22)			MCWB	6.1	6.2	7.3	12.6	16.6	18.3	19.7	18.9	16.5	13.6	9.3	7.4	(22)
(23)		5%	DB	5.8	6.2	9.9	16.8	21.2	23.2	25.5	25.0	20.1	15.1	9.8	7.1	(23)
(24)			MCWB	4.9	5.0	6.9	10.8	15.1	16.9	18.8	18.3	15.5	12.6	8.7	6.3	(24)
(25)		10%	DB	4.2	5.0	7.9	14.2	19.0	21.2	23.3	23.1	18.8	13.8	8.2	5.9	(25)
(26)			MCWB	3.5	3.8	5.8	9.3	13.4	15.7	17.8	17.4	14.7	11.8	7.5	5.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.9	10.4	15.5	18.7	21.2	22.3	21.7	19.3	15.8	11.5	9.4	(27)
(28)			MCDWB	9.0	9.1	13.1	22.2	24.1	26.7	28.0	26.5	24.0	18.3	12.6	9.7	(28)
(29)		2%	WB	6.0	6.2	8.5	13.0	17.2	19.4	20.8	20.2	17.4	14.2	9.7	7.6	(29)
(30)			MCDWB	6.6	7.2	11.0	17.7	22.8	24.5	25.7	24.6	20.9	16.3	10.5	8.1	(30)
(31)		5%	WB	4.6	5.0	6.9	11.3	15.7	17.7	19.6	19.3	16.2	13.0	8.6	6.2	(31)
(32)			MCDWB	5.2	6.0	8.6	15.7	20.0	22.1	24.0	23.4	19.1	15.1	9.4	6.7	(32)
(33)		10%	WB	3.4	3.7	5.7	10.0	14.2	16.5	18.6	18.3	15.2	11.8	7.5	4.9	(33)
(34)			MCDWB	4.1	4.7	7.3	13.1	18.4	20.5	22.7	22.1	18.0	13.7	8.2	5.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.5	5.3	6.7	9.5	10.0	9.5	9.0	9.4	8.1	6.6	4.4	4.0	(35)
(36)			MCDBR	4.3	5.9	10.1	14.0	13.4	13.1	13.0	12.3	11.3	9.0	5.2	4.2	(36)
(37)			MCWBR	4.0	4.6	6.5	7.7	7.2	6.8	6.2	6.1	6.4	6.0	4.4	4.1	(37)
(38)		5% WB	MCDWR	4.2	5.6	8.4	12.2	11.9	11.6	11.1	10.6	9.9	8.1	4.9	4.1	(38)
(39)			MCWBR	4.0	4.7	6.2	7.4	7.0	6.7	5.8	6.0	6.2	5.7	4.4	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.334	0.361	0.404	0.395	0.391	0.421	0.413	0.373	0.356	0.339	0.304	(40)	
(41)		taud	2.282	2.292	2.291	2.226	2.317	2.357	2.288	2.314	2.407	2.434	2.335	2.289	(41)	
(42)		Ebn at Noon	636	745	809	818	851	857	820	803	792	718	589	554	(42)	
(43)		Edh at Noon	58	81	101	123	119	115	122	112	90	71	57	48	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.48	1.15	2.39	4.18	5.41	5.66	5.09	4.37	3.10	1.58	0.60	0.35	(44)	
(45)		RadStd	0.06	0.17	0.28	0.51	0.54	0.47	0.57	0.42	0.34	0.24	0.08	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	N/A	N/A	N/A	-126	-151	+70	N/A
(47) Regional (26 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-134	+67	N/A

Nomenclature: See separate page