

GDANSK-SWIBNO, Poland

WMO: 121550

Lat: 54.3336N

Lon: 18.9344E

Elev: 30

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.7	10.8	-0.3	5.4	3.2	6.4	7.7	11.8	30.2	43.5	26.5	39.9	3.7	100	0.562

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.2	79.8	68.0	76.1	65.8	72.7	64.4	69.3	77.5	67.2	73.6	65.4	71.4	8.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.0	73.4	64.6	91.4	70.9	62.9	85.9	69.3	33.4	78.1	31.7	73.7	30.3	71.6	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	19.2	16.7	DB	4.7	87.2	11.7	3.5	-3.7	89.7	-10.6	91.7	-17.2	93.7	-25.7	96.2	(4)
(5)			WB	4.2	73.8	11.3	2.5	-4.0	75.6	-10.6	77.1	-16.9	78.6	-25.2	80.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.4	30.0	30.5	35.9	44.2	53.6	59.4	62.5	62.9	55.4	48.8	38.4	34.0	(6)
(7)		DBStd	13.67	10.88	9.10	7.51	6.65	6.62	5.73	4.45	5.04	4.90	6.16	5.87	5.99	(7)
(8)		HDD50	2785	621	546	438	198	36	1	0	0	8	95	347	495	(8)
(9)		HDD65	6882	1086	965	902	624	360	187	105	102	292	502	797	960	(9)
(10)		CDD50	1471	0	1	1	24	147	283	387	401	169	58	0	0	(10)
(11)		CDD65	93	0	0	0	0	5	20	27	38	3	0	0	0	(11)
(12)		CDH74	554	0	0	0	0	43	131	141	215	24	0	0	0	(12)
(13)		CDH80	104	0	0	0	0	4	25	26	45	4	0	0	0	(13)
(14)	Wind	WSAvg	7.4	9.6	8.7	8.3	7.5	6.5	5.6	5.5	5.3	6.4	7.5	8.8	9.5	(14)
(15)	Precipitation	PrecAvg	22.2	1.2	1.0	1.1	1.2	2.1	2.3	3.0	2.6	2.4	2.0	1.8	1.5	(15)
(16)		PrecMax	27.8	2.7	1.7	2.0	2.9	3.5	5.5	5.9	5.6	5.0	4.6	4.0	2.5	(16)
(17)		PrecMin	14.7	0.2	0.1	0.2	0.1	0.7	0.5	0.6	0.3	0.6	0.5	0.6	0.6	(17)
(18)		PrecStd	3.1	0.6	0.4	0.5	0.7	0.9	1.2	1.3	1.4	1.3	1.1	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	54.2	59.3	70.1	79.0	83.3	83.8	85.4	77.3	67.8	52.2	50.1	(19)
(20)			MCWB	47.4	48.7	50.6	58.1	65.6	70.7	71.3	69.1	64.8	60.3	49.3	47.9	(20)
(21)		2%	DB	46.1	48.6	52.2	63.9	72.8	77.8	77.6	79.8	69.6	62.6	50.0	47.0	(21)
(22)			MCWB	43.6	44.5	47.1	53.9	62.6	66.6	68.0	67.8	63.1	57.0	47.9	44.9	(22)
(23)		5%	DB	43.9	43.9	48.8	58.2	68.3	72.9	73.8	75.7	66.1	59.6	48.1	44.4	(23)
(24)			MCWB	41.7	41.1	44.7	50.6	59.8	64.0	65.6	65.7	60.4	55.3	46.2	42.5	(24)
(25)		10%	DB	41.9	40.9	46.0	54.4	64.2	68.9	70.9	72.0	63.2	57.1	46.4	42.3	(25)
(26)			MCWB	39.9	38.9	42.8	48.7	57.9	62.0	64.2	64.2	58.3	53.9	44.5	40.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	49.7	51.1	58.5	66.5	72.7	72.5	71.8	66.8	62.1	50.4	48.3	(27)
(28)			MCD B	48.9	53.1	57.9	68.8	76.6	82.2	81.0	80.5	74.2	66.4	51.3	49.4	(28)
(29)		2%	WB	44.1	44.8	47.9	55.1	63.5	67.6	69.2	69.1	63.7	58.0	48.2	45.2	(29)
(30)			MCD B	45.8	47.9	51.5	63.3	71.5	74.9	76.4	77.2	69.0	61.5	49.4	46.8	(30)
(31)		5%	WB	42.0	41.3	45.4	51.5	61.0	65.0	66.7	67.1	61.3	56.1	46.6	42.7	(31)
(32)			MCD B	43.6	43.5	48.6	56.8	67.0	71.4	72.1	73.4	65.3	58.8	48.0	44.1	(32)
(33)		10%	WB	40.0	38.8	42.8	49.1	58.7	62.9	65.0	65.1	59.1	54.2	44.7	40.7	(33)
(34)			MCD B	41.7	40.7	45.6	53.5	63.3	68.4	70.0	70.9	62.2	56.8	46.2	42.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	8.3	10.2	12.0	12.7	12.5	12.9	14.2	11.9	11.3	7.6	6.8	(35)
(36)			MCDBR	8.0	11.0	15.8	20.0	20.2	19.7	19.1	20.9	16.2	14.5	8.9	8.6	(36)
(37)			MCWBR	7.3	8.6	11.3	12.1	10.9	10.5	11.0	10.2	10.1	9.6	7.5	8.2	(37)
(38)		5% WB	MCD BR	7.9	10.4	15.4	18.0	17.5	17.9	17.3	17.4	14.7	13.3	8.6	8.4	(38)
(39)			MCWBR	7.5	8.6	11.5	11.5	10.4	10.6	10.9	9.8	10.3	9.2	7.6	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.339	0.366	0.411	0.401	0.398	0.430	0.420	0.379	0.361	0.345	0.309	(40)	
(41)		taud	2.285	2.295	2.289	2.215	2.312	2.353	2.280	2.311	2.404	2.435	2.333	2.293	(41)	
(42)		Ebn at Noon	200	235	255	258	268	270	258	252	249	226	185	174	(42)	
(43)		Edh at Noon	19	26	32	40	38	37	39	36	29	23	18	15	(43)	
(44)	All-Sky Solar Radiation	RadAvg	155	369	762	1326	1713	1791	1612	1386	985	503	191	112	(44)	
(45)		RadStd	21	56	90	163	169	151	182	134	109	77	24	15	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (24 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-241	+124	N/A	

Nomenclature: See separate page