

RESKO-SMOLSKO, Poland

WMO: 122100

Lat: 53.7636N

Lon: 15.3933E

Elev: 53

StdP: 100.69

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.5	-9.4	-15.6	1.0	-10.9	-12.7	1.3	-8.0	9.6	5.3	8.6	5.1	1.4	70	0.515

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	29.2	19.5	27.3	18.8	25.6	18.1	20.8	26.8	19.9	25.4	19.0	23.7	3.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.6	22.9	18.0	13.0	22.0	17.2	12.3	21.2	60.3	27.0	57.2	25.3	54.2	23.5	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.5	5.7	-16.2	32.9	5.0	2.1	-19.9	34.5	-22.8	35.7	-25.6	36.9	-29.3	38.5		
(5)			-16.4	22.7	4.8	1.3	-19.9	23.7	-22.7	24.4	-25.4	25.2	-28.9	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.0	-0.6	0.5	3.5	8.6	12.7	15.9	18.1	13.9	9.4	5.2	1.8	(6)	
(7)		DBStd	7.54	4.92	4.35	4.31	3.89	3.89	3.29	2.97	2.92	3.00	3.52	3.27	4.36	(7)
(8)		HDD10.0	1342	328	266	203	71	16	1	0	3	54	147	253	(8)	
(9)		HDD18.3	3511	587	499	460	291	182	88	42	41	137	277	395	512	(9)
(10)		CDD10.0	967	0	0	2	30	98	178	251	250	120	36	2	0	(10)
(11)		CDD18.3	93	0	0	0	0	6	16	34	33	4	0	0	0	(11)
(12)		CDH23.3	951	0	0	0	6	71	187	363	287	37	0	0	0	(12)
(13)		CDH26.7	234	0	0	0	1	11	49	96	73	4	0	0	0	(13)
(14)	Wind	WSAvg	2.6	2.9	2.9	2.9	2.6	2.4	2.3	2.3	2.3	2.5	2.7	3.1	(14)	
(15)	Precipitation	PrecAvg	702	54	44	51	36	54	71	78	82	64	52	56	61	(15)
(16)		PrecMax	938	126	85	97	103	89	177	170	171	147	124	122	109	(16)
(17)		PrecMin	578	1	8	11	11	10	28	2	18	17	22	3	14	(17)
(18)		PrecStd	96	31	20	24	20	21	29	43	36	29	27	25	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	11.5	17.3	23.7	28.2	31.1	31.9	31.7	27.4	20.8	14.1	11.8	(19)
(20)			MCWB	8.7	8.6	10.5	14.5	18.3	20.5	20.8	20.7	18.8	15.3	12.4	10.3	(20)
(21)		2%	DB	8.4	9.4	14.0	20.6	25.4	27.8	29.2	28.5	24.1	18.4	12.1	9.9	(21)
(22)			MCWB	7.0	7.2	8.7	12.6	16.7	18.9	19.7	19.3	16.7	14.4	10.3	8.7	(22)
(23)		5%	DB	7.1	7.8	11.6	18.4	22.8	25.3	27.2	26.4	21.9	16.5	10.9	8.6	(23)
(24)			MCWB	6.0	6.0	8.2	11.4	15.3	18.2	19.0	18.4	15.9	13.5	9.4	7.4	(24)
(25)		10%	DB	5.7	6.3	9.7	16.2	20.6	23.1	25.2	24.4	19.7	14.8	9.8	7.2	(25)
(26)			MCWB	4.7	4.7	7.0	10.4	14.3	17.1	18.3	17.9	15.0	12.5	8.6	6.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.4	11.4	15.7	19.6	22.3	21.9	19.8	16.3	13.0	10.6	(27)	
(28)			MCDWB	10.6	10.8	15.1	22.4	25.8	28.8	28.8	28.7	25.0	19.4	14.0	11.5	(28)
(29)		2%	WB	7.2	7.6	9.8	13.3	17.7	20.0	20.8	20.6	17.6	14.9	10.7	8.9	(29)
(30)			MCDWB	8.2	9.0	12.7	19.2	23.2	26.4	27.1	26.2	22.2	17.5	11.7	9.8	(30)
(31)		5%	WB	6.0	6.1	8.3	12.0	16.4	18.9	19.9	19.6	16.5	13.8	9.6	7.5	(31)
(32)			MCDWB	6.9	7.5	11.0	17.2	21.4	24.0	25.6	24.3	20.3	16.0	10.6	8.5	(32)
(33)		10%	WB	4.8	4.7	7.2	10.8	14.9	17.6	19.0	18.7	15.5	12.7	8.7	6.2	(33)
(34)			MCDWB	5.8	6.2	9.5	15.4	19.3	22.0	23.7	22.6	19.1	14.6	9.7	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	5.3	7.5	10.1	10.9	10.6	10.2	10.2	9.1	7.1	4.5	3.9	(35)
(36)			MCDBR	4.2	6.5	10.8	14.1	14.3	14.4	14.4	14.0	12.8	9.7	5.5	4.7	(36)
(37)			MCWBR	3.8	4.9	6.6	7.6	7.2	7.5	6.2	6.3	6.4	6.2	4.3	4.3	(37)
(38)		5% WB	MCDWB	4.2	5.8	9.3	12.7	12.7	12.9	12.5	11.5	11.0	8.9	5.1	4.7	(38)
(39)			MCWBR	3.9	4.8	6.2	7.2	6.9	7.2	6.0	5.9	6.2	6.1	4.3	4.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.337	0.369	0.407	0.405	0.401	0.424	0.421	0.381	0.361	0.339	0.309	(40)	
(41)		taud	2.301	2.299	2.265	2.224	2.279	2.317	2.268	2.286	2.376	2.391	2.357	2.307	(41)	
(42)		Ebn at Noon	643	749	803	819	842	849	819	797	786	715	605	568	(42)	
(43)		Edh at Noon	60	82	105	124	124	121	125	116	94	75	57	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.54	1.20	2.42	4.17	5.25	5.55	5.13	4.32	3.14	1.62	0.66	0.38	(44)	
(45)		RadStd	0.06	0.17	0.27	0.55	0.61	0.43	0.65	0.37	0.34	0.23	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-140	+60	N/A

Nomenclature: See separate page