

SZCZECINEK, Poland

WMO: 122150

Lat: 53.715N

Lon: 16.747E

Elev: 142

StdP: 99.63

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-11.0	-17.3	0.8	-14.3	-13.9	1.1	-10.1	8.9	1.0	8.3	0.9	2.0	80	0.543

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	29.0	19.2	27.2	18.4	25.4	17.7	20.5	26.5	19.6	25.0	18.6	23.6	3.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.7	22.7	17.6	12.8	21.6	16.7	12.1	20.9	59.6	26.7	56.4	25.0	53.4	23.6	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.7	6.1	-18.7	31.4	3.7	2.2	-21.3	33.0	-23.5	34.4	-25.6	35.6	-28.3	37.2		
(5)			-18.2	22.2	4.3	1.3	-21.3	23.1	-23.9	23.8	-26.3	24.6	-29.4	25.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-1.9	-0.2	2.9	8.1	12.7	15.6	17.8	17.7	13.7	9.0	4.2	1.1	(6)
(7)		DBStd	7.81	5.17	4.82	4.48	3.77	3.93	3.30	2.88	2.98	2.95	3.56	3.26	4.27	(7)
(8)		HDD10.0	1491	369	287	221	79	17	1	0	0	4	61	176	277	(8)
(9)		HDD18.3	3697	628	519	478	306	181	96	46	49	143	289	426	536	(9)
(10)		CDD10.0	915	0	0	1	23	99	168	242	237	114	30	1	0	(10)
(11)		CDD18.3	79	0	0	0	0	5	13	29	28	3	0	0	0	(11)
(12)		CDH23.3	889	0	0	0	2	69	174	305	301	38	0	0	0	(12)
(13)		CDH26.7	206	0	0	0	0	9	42	68	81	6	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.5	3.4	3.3	3.1	2.8	2.6	2.5	2.6	2.9	3.3	3.5	(14)	
(15)	Precipitation	PrecAvg	702	50	37	49	44	71	79	83	80	62	47	50	50	(15)
(16)		PrecMax	1292	179	74	100	118	223	351	156	201	145	96	96	97	(16)
(17)		PrecMin	447	4	7	11	6	24	22	7	10	19	15	2	10	(17)
(18)		PrecStd	230	41	19	25	30	48	60	39	46	28	26	22	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	10.6	16.5	22.9	27.9	31.1	30.7	32.0	27.1	20.2	13.0	11.0	(19)
(20)			MCWB	7.7	8.5	10.0	13.6	17.6	20.4	19.9	20.4	18.4	14.9	12.1	9.7	(20)
(21)		2%	DB	7.5	8.8	13.5	20.1	25.2	27.2	28.8	28.9	23.8	17.8	11.0	9.1	(21)
(22)			MCWB	6.3	6.8	8.2	12.2	17.1	18.2	19.2	19.2	16.1	14.0	9.6	8.2	(22)
(23)		5%	DB	6.0	7.1	11.0	17.8	23.1	25.1	27.0	26.7	21.3	15.9	9.9	7.7	(23)
(24)			MCWB	5.1	5.5	7.6	10.9	15.4	17.8	18.5	18.3	15.3	13.0	8.8	6.6	(24)
(25)		10%	DB	4.5	5.6	9.0	15.4	20.8	22.9	25.0	24.5	19.2	14.3	8.8	6.4	(25)
(26)			MCWB	3.7	4.3	6.4	9.8	14.2	16.5	17.9	17.5	14.5	12.4	7.8	5.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.2	11.1	15.0	19.5	21.5	21.7	21.7	19.4	15.9	12.4	10.0	(27)
(28)			MCDWB	9.1	10.3	15.1	21.4	25.5	28.0	27.7	28.3	25.6	19.0	12.8	10.6	(28)
(29)		2%	WB	6.5	7.1	9.1	13.2	17.7	19.4	20.5	20.5	17.4	14.6	10.1	8.5	(29)
(30)			MCDWB	7.4	8.5	11.7	18.6	23.5	25.2	26.2	26.5	22.0	16.8	10.9	9.1	(30)
(31)		5%	WB	5.2	5.7	7.8	11.7	16.4	18.2	19.6	19.3	16.2	13.5	9.0	6.9	(31)
(32)			MCDWB	6.0	6.8	10.6	16.1	21.4	23.7	24.7	24.8	19.7	15.6	9.8	7.6	(32)
(33)		10%	WB	3.8	4.3	6.5	10.4	15.1	17.0	18.7	18.2	15.1	12.4	8.0	5.7	(33)
(34)			MCDWB	4.5	5.6	8.8	14.6	19.8	21.8	23.3	23.1	18.3	14.2	8.8	6.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	5.5	7.8	10.3	11.1	10.8	10.4	10.9	9.0	7.3	4.3	3.9	(35)
(36)			MCDBR	4.6	6.5	11.4	14.5	14.5	14.4	14.5	13.0	9.8	5.5	4.8	(36)	
(37)			MCWBR	4.1	5.0	7.2	7.9	7.3	7.2	6.2	6.4	6.5	6.2	4.8	4.3	(37)
(38)		5% WB	MCDBR	4.6	5.7	9.8	12.4	12.5	13.0	11.8	12.6	11.0	9.0	5.4	4.7	(38)
(39)			MCWBR	4.2	4.8	6.6	7.2	6.7	7.0	6.0	6.3	6.2	6.1	4.8	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.332	0.363	0.403	0.401	0.396	0.420	0.417	0.374	0.358	0.337	0.302	(40)	
(41)		taud	2.290	2.292	2.273	2.229	2.286	2.325	2.273	2.287	2.388	2.413	2.354	2.301	(41)	
(42)		Ebn at Noon	653	756	810	822	847	854	823	801	794	722	609	578	(42)	
(43)		Edh at Noon	60	82	104	124	123	120	124	116	93	73	57	49	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.56	1.25	2.46	4.13	5.19	5.45	5.03	4.30	3.12	1.65	0.65	0.39	(44)	
(45)		RadStd	0.09	0.18	0.33	0.54	0.58	0.45	0.63	0.42	0.36	0.25	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-141	+66	N/A

Nomenclature: See separate page