

CHOJNICE, Poland

WMO: 122350

Lat: 53.7153N

Lon: 17.5325E

Elev: 564

StdP: 14.40

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.4	(c) 10.9	(d) 1.0	(e) 5.9	(f) 6.8	(g) 6.8	(h) 8.0	(i) 11.8	(j) 25.3	(k) 39.5	(l) 23.2	(m) 38.2	(n) 5.7	(o) 90	(p) 0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	83.5	66.5	80.1	64.9	77.0	63.5	69.0	79.7	67.2	76.4	65.4	73.7	8.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.6	96.5	72.4	63.9	90.8	70.8	62.2	85.3	69.3	33.5	79.7	32.0	76.3	30.6	73.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.1	(b) 18.5	(c) 16.3	(e) 0.3	(f) 89.3	(g) 8.1	(h) 3.7	(i) -5.5	(j) 92.0	(k) -10.3	(l) 94.1	(m) -14.8	(n) 96.2	(o) -20.7	(p) 98.9		
(4) 21.1	(5) 18.5	(6) 16.3	(7) -0.2	(8) 72.7	(9) 8.0	(10) 2.5	(11) -5.9	(12) 74.5	(13) -10.6	(14) 76.0	(15) -15.1	(16) 77.5	(17) -20.9	(18) 79.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.5	28.5	30.5	36.3	46.2	54.3	60.0	64.3	63.8	56.1	46.9	38.3	31.7
	DBStd	14.47	9.00	8.49	7.48	7.54	6.93	5.87	5.71	5.35	5.51	6.46	6.32	8.32
	HDD50	2899	666	545	425	160	33	1	0	0	10	138	353	568
	HDD65	6900	1131	965	889	565	338	172	84	88	273	560	802	1033
	CDD50	1623	0	0	2	46	167	302	445	427	191	42	1	0
	CDD65	150	0	0	0	1	7	23	63	51	5	0	0	0
	CDH74	1412	0	0	0	15	82	247	601	422	45	0	0	0
	CDH80	320	0	0	0	1	6	54	166	87	6	0	0	0
Wind	WSAvg	8.1	9.1	9.2	8.8	8.3	7.5	7.3	7.0	6.8	7.2	8.1	8.6	9.4
Precipitation	PrecAvg	23.7	1.7	1.2	1.6	1.3	2.2	2.5	3.1	2.8	2.1	1.7	1.7	1.7
	PrecMax	32.2	5.0	2.6	3.8	3.2	4.4	5.0	6.5	6.2	5.4	5.2	4.4	3.6
	PrecMin	17.1	0.2	0.2	0.2	0.1	0.5	1.0	0.4	0.4	0.7	0.4	0.2	0.5
	PrecStd	3.9	1.0	0.6	0.8	0.7	1.0	1.1	1.6	1.4	1.1	1.2	0.8	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.9	49.8	60.6	75.9	80.6	86.6	89.5	87.3	79.7	67.6	54.9	50.5
		MCWB	45.6	46.2	50.8	58.5	64.0	69.7	68.6	68.7	64.5	59.3	53.1	49.0
	2%	DB	44.1	46.6	54.9	69.5	76.3	80.3	84.5	82.0	73.8	62.9	51.1	46.9
		MCWB	42.5	43.7	46.5	55.4	62.0	64.8	66.8	66.1	61.4	56.8	49.1	45.4
	5%	DB	41.6	43.9	50.4	64.3	72.4	76.4	80.5	78.5	69.6	59.4	48.7	44.1
		MCWB	40.1	41.8	45.1	52.0	59.7	63.1	65.6	64.2	59.8	55.0	47.2	42.9
	10%	DB	39.0	41.1	46.6	59.9	68.4	72.1	76.5	75.4	66.0	56.5	46.6	41.8
		MCWB	37.9	39.1	42.8	49.9	57.1	60.9	63.8	63.4	58.2	53.5	45.3	40.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	47.1	51.7	60.0	66.2	71.0	71.3	70.9	66.0	60.9	53.2	49.4
		MCDB	47.1	48.5	58.9	74.6	75.9	81.6	83.6	82.9	75.6	65.5	54.1	50.2
	2%	WB	42.9	44.3	48.1	56.4	63.5	67.4	69.2	68.4	63.3	57.8	49.5	45.7
		MCDB	44.1	46.0	52.4	67.0	74.1	77.3	80.7	77.7	70.7	60.9	50.7	46.6
	5%	WB	40.3	41.8	45.5	53.5	61.1	64.7	67.5	66.6	61.1	55.6	47.4	42.9
		MCDB	41.5	43.7	49.5	62.2	69.9	73.4	77.1	74.6	66.9	58.8	48.5	43.8
	10%	WB	38.0	39.2	43.0	50.9	58.7	62.4	65.6	64.8	59.2	53.5	45.5	40.7
		MCDB	39.0	41.0	46.4	58.1	66.3	69.7	73.8	72.2	64.4	56.3	46.6	41.7
Mean Daily Temperature Range	5% DB	MDBR	7.2	9.2	12.4	17.4	18.4	17.4	17.3	17.4	14.7	11.9	7.4	6.7
		MCDBR	8.0	11.2	18.7	25.1	24.5	24.5	24.2	23.1	21.0	16.0	9.6	8.5
		MCWBR	7.3	8.8	11.9	13.1	12.4	11.6	9.6	9.9	10.2	10.4	8.3	8.0
	5% WB	MCDBR	7.9	10.4	16.6	22.0	22.1	21.4	20.9	19.8	18.1	14.8	9.1	7.9
MCWBR		7.3	8.9	11.7	12.2	12.2	11.9	9.9	10.1	9.9	10.2	8.2	7.7	
Clear-Sky Solar Irradiance	taub	0.302	0.330	0.362	0.403	0.399	0.393	0.421	0.416	0.373	0.356	0.337	0.299	
	taud	2.277	2.283	2.273	2.223	2.287	2.328	2.267	2.287	2.387	2.419	2.350	2.293	
	Ebn at Noon	207	240	258	261	269	272	261	254	252	230	193	184	
	Edh at Noon	19	26	33	39	39	38	40	37	30	23	18	16	
All-Sky Solar Radiation	RadAvg	179	396	779	1311	1647	1729	1595	1367	991	522	205	125	
	RadStd	28	56	105	171	183	142	200	134	115	79	29	13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-270	+131	N/A

Nomenclature: See separate page