

CHOJNICE, Poland

WMO: 122350

Lat: 53.7153N

Lon: 17.5325E

Elev: 172

StdP: 99.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.8	-11.7	-17.2	0.8	-14.0	-14.0	1.1	-11.2	11.3	4.2	10.4	3.4	2.5	90	0.587

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	28.6	19.2	26.7	18.3	25.0	17.5	20.6	26.5	19.6	24.7	18.6	23.1	3.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.8	22.5	17.7	13.0	21.6	16.8	12.2	20.7	60.0	26.5	56.5	24.6	53.3	23.1	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	-17.6	31.8	4.5	2.1	-20.8	33.3	-23.5	34.5	-26.0	35.7	-29.3	37.2		
(5)			-17.9	22.6	4.4	1.4	-21.1	23.6	-23.7	24.5	-26.2	25.3	-29.4	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-1.9	-0.8	2.4	7.9	12.4	15.6	18.0	17.7	13.4	8.3	3.5	-0.2	(6)
(7)		DBStd	8.04	5.00	4.72	4.15	4.19	3.85	3.26	3.17	2.97	3.06	3.59	3.51	4.62	(7)
(8)		HDD10.0	1611	370	303	236	89	18	1	0	0	6	77	196	316	(8)
(9)		HDD18.3	3833	628	536	494	314	188	96	47	49	152	311	446	574	(9)
(10)		CDD10.0	902	0	0	1	26	93	168	247	237	106	23	1	0	(10)
(11)		CDD18.3	83	0	0	0	1	4	13	35	28	3	0	0	0	(11)
(12)		CDH23.3	784	0	0	0	8	46	137	334	234	25	0	0	0	(12)
(13)		CDH26.7	178	0	0	0	1	3	30	92	48	3	0	0	0	(13)
(14)	Wind	WSAvg	3.6	4.1	4.1	4.0	3.7	3.4	3.3	3.1	3.0	3.2	3.6	3.9	4.2	(14)
(15)	Precipitation	PrecAvg	601	43	30	41	32	57	64	80	70	53	42	44	44	(15)
(16)		PrecMax	817	126	65	96	82	111	128	165	157	137	132	111	91	(16)
(17)		PrecMin	435	4	5	6	2	13	25	10	10	18	11	4	13	(17)
(18)		PrecStd	100	26	14	20	18	26	29	41	35	28	30	21	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	9.9	15.9	24.4	27.0	30.3	31.9	30.7	26.5	19.8	12.7	10.3	(19)
(20)			MCWB	7.5	7.9	10.4	14.7	17.8	20.9	20.4	20.4	18.1	15.2	11.7	9.4	(20)
(21)		2%	DB	6.7	8.1	12.7	20.8	24.6	26.8	29.2	27.8	23.2	17.1	10.6	8.3	(21)
(22)			MCWB	5.8	6.5	8.1	13.0	16.7	18.2	19.3	18.9	16.3	13.8	9.5	7.5	(22)
(23)		5%	DB	5.3	6.6	10.2	18.0	22.4	24.6	26.9	25.8	20.9	15.2	9.3	6.7	(23)
(24)			MCWB	4.5	5.5	7.3	11.1	15.4	17.3	18.7	17.9	15.4	12.8	8.4	6.0	(24)
(25)		10%	DB	3.9	5.1	8.1	15.5	20.2	22.3	24.7	24.1	18.9	13.6	8.1	5.4	(25)
(26)			MCWB	3.3	3.9	6.0	10.0	14.0	16.1	17.7	17.5	14.5	11.9	7.4	4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.4	11.0	15.6	19.0	21.7	21.8	21.6	18.9	16.0	11.8	9.7	(27)
(28)			MCD B	8.4	9.2	14.9	23.7	24.4	27.6	28.6	28.3	24.2	18.6	12.3	10.1	(28)
(29)		2%	WB	6.1	6.8	9.0	13.6	17.5	19.7	20.7	20.2	17.4	14.4	9.7	7.6	(29)
(30)			MCD B	6.7	7.8	11.3	19.4	23.4	25.2	27.0	25.4	21.5	16.1	10.4	8.1	(30)
(31)		5%	WB	4.6	5.5	7.5	11.9	16.2	18.1	19.7	19.2	16.1	13.1	8.5	6.1	(31)
(32)			MCD B	5.3	6.5	9.7	16.8	21.0	23.0	25.0	23.6	19.4	14.9	9.1	6.6	(32)
(33)		10%	WB	3.3	4.0	6.1	10.5	14.8	16.9	18.7	18.2	15.1	12.0	7.5	4.8	(33)
(34)			MCD B	3.9	5.0	8.0	14.5	19.1	21.0	23.2	22.4	18.0	13.5	8.1	5.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	5.1	6.9	9.6	10.2	9.7	9.6	9.7	8.2	6.6	4.1	3.7	(35)
(36)			MCDBR	4.4	6.2	10.4	13.9	13.6	13.6	13.4	12.9	11.7	8.9	5.3	4.7	(36)
(37)			MCWBR	4.1	4.9	6.6	7.3	6.9	6.4	5.4	5.5	5.7	5.8	4.6	4.4	(37)
(38)		5% WB	MCDBR	4.4	5.8	9.2	12.2	12.3	11.9	11.6	11.0	10.1	8.2	5.1	4.4	(38)
(39)			MCWBR	4.1	4.9	6.5	6.8	6.8	6.6	5.5	5.6	5.5	5.7	4.5	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.330	0.362	0.403	0.399	0.393	0.421	0.416	0.373	0.356	0.337	0.299	(40)	
(41)		taud	2.277	2.283	2.273	2.223	2.287	2.328	2.267	2.287	2.387	2.419	2.350	2.293	(41)	
(42)		Ebn at Noon	654	756	812	823	849	856	822	802	796	725	608	580	(42)	
(43)		Edh at Noon	60	83	104	124	123	119	125	116	93	73	58	50	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.56	1.25	2.46	4.13	5.19	5.45	5.03	4.31	3.12	1.65	0.65	0.39	(44)	
(45)		RadStd	0.09	0.18	0.33	0.54	0.58	0.45	0.63	0.42	0.36	0.25	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-150	+73	N/A

Nomenclature: See separate page