

MLAWA, Poland

WMO: 122700

Lat: 53.1042N

Lon: 20.3611E

Elev: 487

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.6	7.8	-1.4	5.2	3.5	3.5	6.7	9.0	26.8	39.8	23.6	38.3	5.5	80	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	85.0	68.2	81.7	66.0	78.5	64.7	70.1	81.3	68.3	78.0	66.6	75.2	7.5	140

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	99.5	74.0	64.9	93.7	72.2	63.2	88.2	70.8	34.3	81.7	32.8	78.1	31.4	75.3	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.0	18.2	16.1	-1.4	90.8	6.9	3.1	-6.3	93.0	-10.3	94.8	-14.2	96.5	-19.2	98.8		
			-1.9	73.0	6.6	1.9	-6.7	74.3	-10.6	75.4	-14.3	76.5	-19.1	77.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.6	27.0	29.5	36.1	47.2	55.8	61.3	65.7	64.9	56.2	46.7	37.8	30.4
	DBStd	15.58	9.84	9.12	7.84	7.93	7.37	6.43	6.16	5.79	6.13	6.97	7.20	9.17
	HDD50	3032	714	575	434	144	27	1	0	0	14	150	367	606
	HDD65	6920	1179	995	896	536	298	147	68	74	272	568	816	1071
	CDD50	1804	0	0	2	59	207	341	486	462	199	46	2	0
	CDD65	217	0	0	0	1	13	36	89	71	7	0	0	0
	CDH74	1938	0	0	0	22	133	342	763	607	71	0	0	0
	CDH80	478	0	0	0	2	14	74	220	154	14	0	0	0
	WSAvg	7.7	8.6	8.6	8.8	7.9	7.2	6.9	6.8	6.4	6.7	7.5	8.1	8.6
	PrecAvg	22.4	1.4	1.2	1.3	1.4	2.2	2.6	3.0	2.3	2.1	1.6	1.7	1.6
Precipitation	PrecMax	27.6	4.2	3.0	2.9	4.1	6.0	6.8	7.5	4.8	7.7	4.5	4.5	3.2
	PrecMin	16.2	0.1	0.3	0.4	0.1	1.1	0.6	0.6	0.3	0.2	0.3	0.3	0.4
	PrecStd	2.8	0.8	0.6	0.6	0.8	1.0	1.3	1.5	1.1	1.7	1.1	0.8	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	49.3	60.8	77.1	82.0	87.0	90.3	89.4	81.7	68.7	55.8	50.0
		MCWB	44.5	45.3	49.7	59.8	64.8	69.9	69.7	69.3	64.7	59.3	52.5	48.5
	2%	DB	43.7	46.5	55.6	70.5	77.9	81.6	85.7	84.1	75.1	64.0	52.2	46.6
		MCWB	42.1	43.7	47.4	55.9	63.2	66.3	68.5	67.7	61.9	57.2	49.8	44.9
	5%	DB	41.1	43.7	51.2	65.3	74.0	77.8	81.9	80.4	70.9	60.2	49.5	44.1
		MCWB	39.7	41.4	45.4	53.0	60.8	64.0	66.6	65.3	60.3	55.1	47.6	42.6
	10%	DB	38.4	40.7	47.2	60.9	69.7	74.4	78.1	76.9	67.3	57.0	47.2	41.5
		MCWB	37.2	38.7	42.9	50.7	58.4	62.4	65.1	64.2	58.6	53.4	45.7	40.4
	0.4%	WB	45.1	46.3	52.0	61.3	67.3	71.6	72.5	72.0	66.7	61.1	53.3	48.6
		MCDB	46.2	48.0	58.6	76.1	78.6	83.4	84.3	84.3	77.7	66.6	54.8	49.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.3	43.9	48.5	57.4	64.5	68.3	70.2	69.7	63.8	58.1	50.2	45.2
		MCDB	43.6	46.1	53.6	67.9	75.0	78.3	81.6	80.2	71.9	62.3	51.9	46.3
	5%	WB	39.8	41.5	45.8	54.4	62.2	66.1	68.6	67.6	61.6	55.9	47.8	42.8
		MCDB	41.0	43.6	50.4	63.1	71.7	74.8	78.4	76.6	68.4	59.5	49.2	44.0
	10%	WB	37.3	38.8	43.1	51.6	59.9	63.8	66.8	65.8	59.7	53.7	45.9	40.4
		MCDB	38.3	40.5	46.9	58.8	67.7	71.7	75.2	73.8	65.6	56.8	47.1	41.5
Mean Daily Temperature Range	5% DB	MDBR	7.7	9.2	12.6	17.1	18.6	18.5	18.2	18.6	16.3	12.8	7.7	7.3
		MCDBR	8.0	11.2	18.9	23.9	23.3	23.4	23.2	23.6	21.9	17.4	10.5	8.3
		MCWBR	7.2	9.1	12.3	12.4	11.6	11.0	9.2	9.8	10.7	11.0	8.8	7.6
	5% WB	MCDBR	7.9	11.0	17.5	21.8	21.5	20.9	20.2	20.3	19.2	15.8	10.1	8.1
		MCWBR	7.3	9.2	12.2	11.9	11.5	11.0	9.3	9.7	10.3	10.7	8.8	7.6
Clear-Sky Solar Irradiance	taub		0.306	0.337	0.369	0.417	0.406	0.402	0.435	0.425	0.383	0.360	0.346	0.304
	taud		2.226	2.234	2.238	2.162	2.253	2.295	2.222	2.247	2.340	2.386	2.298	2.263
	Ebn at Noon		207	238	256	257	267	270	257	252	250	230	191	185
	Edh at Noon		21	28	34	42	41	39	42	38	31	24	20	17
All-Sky Solar Radiation	RadAvg		205	429	819	1308	1663	1742	1616	1402	995	535	210	141
	RadStd		39	71	125	173	164	155	183	126	140	89	23	17

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-293	+108	N/A	
(47)	Regional (28 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	-279	+133	N/A	

Nomenclature: See separate page