

MIKOLAJKI, Poland

WMO: 122800

Lat: 53.7892N

Lon: 21.5886E

Elev: 128

StdP: 99.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.1	-14.1	-19.4	0.7	-16.9	-16.4	0.9	-13.4	9.7	-7.8	9.0	-5.7	2.2	340	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	28.2	20.3	26.5	19.1	24.9	18.3	21.3	26.4	20.3	24.8	19.3	23.3	3.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.6	23.7	18.7	13.7	22.5	17.8	12.9	21.5	62.6	26.3	58.9	25.1	55.6	23.3	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	-19.6	31.2	3.4	1.7	-22.0	32.4	-24.0	33.4	-25.9	34.4	-28.3	35.6		
(5)			-19.8	23.1	3.3	1.1	-22.2	23.8	-24.1	24.5	-25.9	25.1	-28.3	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.9	-1.9	1.7	7.9	13.0	16.4	18.8	18.4	13.8	8.2	3.4	-0.7	(6)
(7)		DBStd	8.71	5.64	5.35	4.36	4.20	3.88	3.27	3.03	2.93	3.19	3.72	3.95	5.08	(7)
(8)		HDD10.0	1708	400	332	258	89	14	1	0	0	6	79	198	332	(8)
(9)		HDD18.3	3856	658	565	516	314	169	76	31	36	141	313	447	590	(9)
(10)		CDD10.0	1002	0	0	1	25	108	192	273	259	118	24	1	0	(10)
(11)		CDD18.3	109	0	0	0	1	5	18	46	37	3	0	0	0	(11)
(12)		CDH23.3	722	0	0	0	7	44	131	296	227	17	0	0	0	(12)
(13)		CDH26.7	136	0	0	0	1	2	22	66	44	2	0	0	0	(13)
(14)	Wind	WSAvg	3.1	3.6	3.5	3.4	3.1	2.7	2.6	2.5	2.4	2.6	3.2	3.7	3.7	(14)
(15)	Precipitation	PrecAvg	608	34	30	36	36	58	71	79	78	56	48	45	36	(15)
(16)		PrecMax	746	86	60	88	89	163	119	175	228	129	129	90	65	(16)
(17)		PrecMin	440	9	10	6	3	30	23	15	18	17	1	13	7	(17)
(18)		PrecStd	83	19	12	19	21	25	28	34	44	33	32	18	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	9.0	15.1	24.0	26.7	29.5	30.8	30.3	25.8	19.2	12.7	9.7	(19)
(20)			MCWB	6.8	6.6	9.6	15.2	18.1	20.4	21.1	21.4	18.9	14.7	10.8	8.4	(20)
(21)		2%	DB	6.3	7.5	12.0	20.3	24.6	26.6	28.7	27.7	22.6	16.8	10.9	7.9	(21)
(22)			MCWB	5.3	5.9	7.6	12.9	17.1	18.9	20.7	19.9	16.8	13.6	9.5	6.7	(22)
(23)		5%	DB	5.0	6.0	9.5	17.6	22.6	24.7	26.6	25.7	20.6	15.0	9.4	6.6	(23)
(24)			MCWB	4.1	4.6	6.5	11.3	15.7	17.8	19.8	18.7	15.8	12.6	8.3	5.7	(24)
(25)		10%	DB	3.5	4.6	7.6	15.1	20.4	22.8	24.7	24.0	18.9	13.5	8.3	5.1	(25)
(26)			MCWB	2.8	3.4	5.4	10.0	14.7	16.8	18.8	18.0	15.0	11.7	7.4	4.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	7.6	10.2	15.9	19.4	21.8	23.0	22.5	19.3	15.7	11.4	8.7	(27)
(28)			MCDWB	8.0	8.3	13.8	23.8	24.9	27.8	27.8	27.9	23.8	18.1	12.3	9.4	(28)
(29)		2%	WB	5.6	6.0	8.3	13.5	17.9	20.1	21.6	21.1	17.8	14.2	9.7	7.1	(29)
(30)			MCDWB	6.3	7.1	11.1	18.6	23.2	24.5	26.5	26.2	21.4	16.1	10.6	7.7	(30)
(31)		5%	WB	4.1	4.8	6.8	11.9	16.6	18.8	20.6	19.9	16.6	13.0	8.5	5.7	(31)
(32)			MCDWB	4.9	5.9	8.9	16.5	21.3	22.7	25.3	24.0	19.6	14.6	9.2	6.4	(32)
(33)		10%	WB	2.9	3.4	5.5	10.5	15.3	17.6	19.6	18.8	15.5	11.9	7.5	4.5	(33)
(34)			MCDWB	3.5	4.4	7.4	14.3	19.4	21.7	23.6	22.5	18.2	13.4	8.3	5.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	5.1	6.9	9.1	9.6	8.8	8.6	7.4	5.9	3.8	3.7	(35)	
(36)			MCDBR	4.2	5.5	9.9	13.2	12.3	11.6	11.1	11.1	9.9	7.9	5.0	4.1	(36)
(37)			MCWBR	3.9	4.4	6.5	6.9	6.0	5.5	4.8	4.9	5.0	5.1	4.1	3.8	(37)
(38)		5% WB	MCDBR	4.2	5.4	9.1	11.6	11.2	10.5	10.0	9.9	8.9	7.2	4.6	4.1	(38)
(39)			MCWBR	3.9	4.5	6.4	6.6	6.1	5.7	4.9	4.9	4.9	5.0	4.0	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.331	0.367	0.410	0.399	0.396	0.429	0.421	0.380	0.357	0.343	0.300	(40)	
(41)		taud	2.218	2.217	2.239	2.198	2.290	2.326	2.250	2.270	2.359	2.406	2.300	2.253	(41)	
(42)		Ebn at Noon	645	747	804	815	848	854	814	796	786	721	590	569	(42)	
(43)		Edh at Noon	63	88	107	127	122	119	127	118	95	74	60	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.61	1.32	2.56	4.12	5.29	5.52	5.10	4.38	3.11	1.62	0.61	0.41	(44)	
(45)		RadStd	0.11	0.23	0.41	0.54	0.51	0.49	0.56	0.41	0.41	0.28	0.07	0.05	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+91	N/A
(47)	Regional (18 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	-149	+75	N/A

Nomenclature: See separate page