

GORZOW WIELKOPOLSKI, Poland

WMO: 123000

Lat: 52.7411N

Lon: 15.2772E

Elev: 238

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.6	15.0	4.3	6.9	10.7	9.8	9.2	16.9	18.2	40.8	16.4	39.8	5.5	110	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.7	86.3	67.1	82.8	65.8	79.6	64.7	69.6	81.5	67.9	78.6	66.3	76.2	6.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	95.6	73.4	64.2	90.6	71.8	62.7	85.9	70.2	33.7	81.4	32.3	78.6	31.1	76.4	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.8	13.0	11.6	5.4	92.5	7.7	3.5	-0.2	95.0	-4.7	97.1	-9.1	99.0	-14.7	101.6		
(5)			4.8	73.0	7.5	1.7	-0.6	74.2	-5.1	75.2	-9.3	76.2	-14.8	77.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.0	31.1	33.6	39.4	49.2	57.0	62.8	66.8	66.2	58.1	49.0	40.0	33.8		
	DBStd	14.46	9.02	8.19	7.24	7.70	6.82	6.22	5.98	5.58	5.78	6.63	6.61	8.11		
	HDD50	2406	585	458	333	105	14	0	0	0	4	100	305	502		
	HDD65	6108	1050	878	793	475	263	114	49	53	220	495	751	967		
	CDD50	2046	0	0	5	83	230	385	521	502	246	70	4	0		
	CDD65	270	0	0	0	2	14	49	105	89	11	0	0	0		
	CDH74	2356	0	0	0	29	151	450	932	698	95	1	0	0		
	CDH80	650	0	0	0	3	24	124	296	188	15	0	0	0		
	WSAvg	5.9	6.5	6.5	6.7	6.4	5.8	5.6	5.5	5.1	5.3	5.4	5.8	6.3		
	PrecAvg	21.9	1.6	1.3	1.5	1.2	2.1	2.2	3.0	2.4	1.8	1.5	1.6	1.7		
	PrecMax	28.1	3.2	3.4	3.4	3.3	4.3	5.2	7.2	5.9	4.5	4.0	4.4	3.9		
	PrecMin	15.2	0.0	0.1	0.4	0.0	0.4	0.1	0.7	0.8	0.2	0.3	0.1	0.3		
	PrecStd	3.3	0.9	0.7	0.8	0.7	1.1	1.3	1.7	1.0	0.9	0.8	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.9	54.6	63.8	78.1	83.3	89.0	91.7	90.5	82.1	70.9	57.7	53.3		
		MCWB	47.7	48.4	52.3	60.1	64.4	69.7	69.0	68.8	65.6	61.1	53.5	50.1		
	2%	DB	48.1	50.5	58.2	71.6	78.6	83.5	86.8	84.8	76.5	65.7	54.3	49.4		
		MCWB	45.7	46.3	48.6	56.7	62.5	65.8	67.0	67.4	62.4	58.3	50.9	46.9		
	5%	DB	45.1	47.5	53.5	66.9	73.9	79.3	83.1	81.0	72.6	62.0	51.3	46.8		
		MCWB	42.9	43.9	47.3	54.0	60.1	64.1	66.2	65.5	61.3	56.5	48.7	44.6		
	10%	DB	42.5	44.8	50.2	62.6	70.1	75.0	79.3	77.5	68.4	58.8	49.1	44.2		
		MCWB	40.6	41.8	45.0	52.1	58.2	62.3	65.2	64.4	59.6	54.9	47.1	42.4		
	0.4%	WB	48.7	49.9	53.4	61.3	66.8	71.4	71.7	71.7	67.8	62.2	55.0	50.8		
		MCDB	50.7	52.3	61.5	76.0	78.9	84.4	86.3	83.4	78.6	68.6	56.9	52.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.8	47.0	50.3	58.1	64.0	68.0	69.7	69.2	64.5	59.3	51.3	47.3		
		MCDB	47.8	49.7	55.7	68.6	74.8	79.8	81.6	80.5	72.8	63.6	53.5	48.9		
	5%	WB	43.1	44.3	47.8	55.4	61.9	65.8	68.0	67.4	62.4	57.1	49.1	44.8		
		MCDB	44.8	47.1	52.7	64.7	71.2	75.8	79.0	77.1	69.6	61.1	51.0	46.5		
	10%	WB	40.7	41.8	45.5	53.0	59.6	63.7	66.4	65.8	60.5	55.2	47.2	42.5		
		MCDB	42.4	44.6	49.6	61.0	68.1	72.6	76.3	74.7	67.1	58.5	48.9	44.1		
	5% DB	MDBR	7.7	9.7	12.7	16.9	17.5	16.9	16.7	17.2	15.1	12.5	8.4	7.2		
		MCDBR	9.5	12.9	19.1	23.4	23.9	23.7	23.2	23.0	21.5	16.9	11.2	9.1		
		MCWBR	8.0	9.5	11.7	11.6	11.1	10.5	8.7	9.3	10.0	10.3	8.5	7.6		
		MCWBR	9.5	12.1	17.1	20.8	21.4	21.4	19.5	19.6	18.7	15.5	10.6	9.0		
	5% WB	MCWBR	8.3	9.5	11.3	10.9	10.8	10.8	8.5	9.3	9.8	10.1	8.5	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.341	0.376	0.416	0.412	0.409	0.431	0.427	0.385	0.365	0.343	0.310		
	taud		2.323	2.313	2.250	2.198	2.256	2.291	2.243	2.264	2.358	2.383	2.373	2.339		
	Ebn at Noon		211	241	254	258	266	268	259	252	250	229	198	190		
	Edh at Noon		19	26	34	41	41	39	41	38	31	24	19	16		
(44) All-Sky Solar Radiation	RadAvg		201	418	770	1292	1585	1679	1571	1358	988	536	233	143		
	RadStd		25	69	101	178	186	136	198	125	121	74	35	14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	N/A

Nomenclature: See separate page