

PLOCK, Poland

WMO: 123600

Lat: 52.5883N

Lon: 19.7258E

Elev: 109

StdP: 100.03

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.7	-12.7	-18.1	0.8	-15.4	-15.5	1.0	-12.2	10.4	4.5	9.5	3.1	2.3	70	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	29.6	20.0	27.7	19.1	26.0	18.2	21.2	27.3	20.2	25.6	19.3	24.2	3.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.2	23.5	18.3	13.4	22.5	17.4	12.6	21.8	62.0	27.5	58.5	25.7	55.3	24.2	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.5	7.6	6.8	-17.8	33.0	4.1	1.6	-20.7	34.1	-23.1	35.0	-25.4	35.9	-28.4	37.1		
			-18.1	23.1	4.0	1.0	-21.0	23.8	-23.4	24.4	-25.6	25.0	-28.5	25.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	-2.0	-0.5	3.1	8.9	13.6	16.7	19.0	18.6	14.0	9.0	4.0	-0.1
	DBStd	8.46	5.55	5.12	4.44	4.22	3.86	3.31	3.16	2.99	3.32	3.93	3.99	5.08
	HDD10.0	1529	371	295	217	69	11	0	0	0	5	67	182	312
	HDD18.3	3630	629	528	473	285	154	70	29	33	136	291	430	571
	CDD10.0	1067	0	0	2	35	121	201	280	268	124	35	2	0
	CDD18.3	126	0	0	0	1	7	21	51	42	5	0	0	0
	CDH23.3	1140	0	0	0	16	75	198	452	351	48	0	0	0
	CDH26.7	280	0	0	0	2	9	45	129	87	8	0	0	0
Wind	WSAvg	3.3	3.9	3.8	3.9	3.4	3.0	2.8	2.7	2.6	2.8	3.2	3.6	3.9
Precipitation	PrecAvg	526	31	27	33	34	51	59	78	59	46	34	38	36
	PrecMax	798	90	89	62	87	149	131	193	134	156	95	109	87
	PrecMin	332	3	3	12	2	18	14	14	10	6	4	3	5
	PrecStd	95	18	16	14	21	27	31	42	32	36	23	20	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	10.8	16.4	25.4	28.0	30.5	32.4	31.5	28.0	21.2	14.1	10.9
		MCWB	7.6	8.1	10.4	15.7	18.3	20.9	20.6	21.2	18.3	15.9	11.9	9.6
	2%	DB	7.7	9.2	13.7	21.7	25.6	27.8	29.9	29.0	24.4	18.6	12.1	9.0
		MCWB	6.2	7.3	9.0	13.6	17.5	19.5	20.2	19.8	16.8	14.5	10.4	7.6
	5%	DB	6.2	7.5	11.4	18.7	23.5	25.5	27.8	27.0	22.1	16.5	10.6	7.5
		MCWB	5.0	5.9	7.8	11.9	16.3	18.1	19.4	19.0	15.8	13.4	9.1	6.3
	10%	DB	4.7	5.9	9.3	16.3	21.2	23.6	25.8	25.1	20.1	14.7	9.2	6.0
		MCWB	3.6	4.4	6.7	10.7	14.9	17.2	18.5	17.8	14.9	12.3	7.9	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	8.7	11.5	16.2	19.5	22.2	22.6	22.2	19.1	16.7	12.4	9.9
		MCDB	9.3	9.9	15.5	24.3	26.1	28.3	29.0	29.2	25.5	20.2	13.7	10.7
	2%	WB	6.4	7.4	9.6	14.4	18.2	20.5	21.4	20.9	17.8	15.0	10.8	7.8
		MCDB	7.6	8.9	12.8	20.6	24.3	26.2	27.4	27.1	22.5	17.5	11.9	8.7
	5%	WB	5.1	5.9	8.2	12.7	17.0	19.1	20.4	19.8	16.7	13.7	9.3	6.3
		MCDB	6.1	7.4	10.9	17.5	22.1	24.1	25.5	25.0	20.8	16.0	10.4	7.3
	10%	WB	3.7	4.5	6.8	11.2	15.7	17.9	19.5	18.8	15.5	12.5	8.1	5.0
		MCDB	4.6	5.8	9.1	15.0	20.1	22.2	24.2	23.3	19.0	14.6	9.0	5.9
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.0	6.7	9.3	10.1	10.0	10.1	10.1	8.8	6.9	4.4	4.0
		MCDBR	4.7	6.5	10.3	13.6	13.4	13.3	13.4	13.2	12.4	9.6	6.3	4.8
		MCWBR	4.1	5.1	6.6	7.0	6.7	6.5	5.4	5.7	6.0	5.9	4.9	4.2
	5% WB	MCDBR	4.7	6.3	9.5	12.0	12.0	11.9	11.3	11.6	10.8	8.9	5.9	4.7
		MCWBR	4.2	5.1	6.6	6.5	6.5	6.5	5.2	5.5	5.8	5.9	4.9	4.2
Clear-Sky Solar Irradiance	taub	0.313	0.343	0.375	0.426	0.416	0.410	0.443	0.431	0.391	0.367	0.350	0.311	
	taud	2.245	2.247	2.228	2.141	2.227	2.277	2.201	2.235	2.319	2.365	2.307	2.280	
	Ebn at Noon	657	751	802	803	835	844	804	791	781	720	608	591	
	Edh at Noon	66	89	110	136	131	126	134	123	101	79	63	54	
All-Sky Solar Radiation	RadAvg	0.66	1.34	2.59	4.14	5.21	5.44	5.04	4.44	3.16	1.74	0.73	0.47	
	RadStd	0.12	0.22	0.34	0.54	0.53	0.49	0.59	0.38	0.45	0.27	0.09	0.06	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47)	Regional (27 neighbors)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
		+0.58	N/A	N/A	+0.69	+0.51	N/A	N/A	-179	+83
		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	-168	+80

Nomenclature: See separate page