

SIEDLCE, Poland

WMO: 123850

Lat: 52.1811N

Lon: 22.2447E

Elev: 508

StdP: 14.43

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.6	(c) 7.3	(d) -3.8	(e) 4.6	(f) 1.5	(g) 2.4	(h) 6.3	(i) 8.5	(j) 23.7	(k) 40.6	(l) 20.6	(m) 36.8	(n) 4.5	(o) 70	(p) 0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.7	(c) 85.6	(d) 68.7	(e) 82.2	(f) 66.9	(g) 79.2	(h) 65.4	(i) 70.7	(j) 81.4	(k) 69.0	(l) 78.9	(m) 67.2	(n) 76.1	(o) 7.2	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	101.6	74.9	65.5	95.8	73.0	63.9	90.6	71.5	34.8	81.4	33.4	78.9	31.9	75.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 18.2	(b) 15.9	(c) 14.1	(e) -4.9	(f) 90.8	(g) 7.5	(h) 2.5	(i) -10.3	(j) 92.6	(k) -14.7	(l) 94.1	(m) -19.0	(n) 95.5	(o) -24.4	(p) 97.3		
(a) 18.2	(b) 15.9	(c) 14.1	(e) -5.4	(f) 73.4	(g) 7.4	(h) 1.6	(i) -10.7	(j) 74.6	(k) -15.0	(l) 75.5	(m) -19.2	(n) 76.4	(o) -24.6	(p) 77.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	27.2	29.5	36.4	47.3	55.9	61.7	65.9	64.7	56.0	46.8	38.3	30.4	(6)
(7)		DBStd	15.64	10.35	9.87	8.33	7.67	7.03	6.18	5.66	5.65	6.24	7.47	8.00	9.45	(7)
(8)		HDD50	3000	708	573	423	139	24	0	0	0	17	152	356	608	(8)
(9)		HDD65	6864	1173	993	885	533	293	137	58	75	277	565	802	1073	(9)
(10)		CDD50	1819	0	0	3	57	206	351	494	455	196	52	5	0	(10)
(11)		CDD65	207	0	0	0	1	10	37	87	66	6	0	0	0	(11)
(12)		CDH74	2193	0	0	0	22	147	404	874	672	74	0	0	0	(12)
(13)		CDH80	540	0	0	0	3	16	83	248	180	10	0	0	0	(13)
(14)	Wind	WSAvg	6.7	7.9	7.7	7.8	6.9	6.1	5.9	5.6	5.3	5.5	6.7	7.4	7.8	(14)
(15)	Precipitation	PrecAvg	20.9	1.1	0.9	1.1	1.4	2.2	2.9	2.6	2.4	1.9	1.5	1.5	1.4	(15)
(16)		PrecMax	28.6	2.3	2.1	2.3	3.6	4.5	7.6	6.6	7.7	4.3	7.1	3.3	3.5	(16)
(17)		PrecMin	15.6	0.2	0.0	0.2	0.2	0.6	1.2	0.7	0.1	0.5	0.2	0.3	0.2	(17)
(18)		PrecStd	3.7	0.6	0.5	0.5	0.7	0.9	1.3	1.4	1.4	1.0	1.3	0.7	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	51.1	62.5	77.1	82.0	86.7	90.4	89.8	81.3	70.6	58.6	50.3	(19)
(20)			MCWB	45.1	45.5	50.7	59.3	64.6	69.6	70.1	69.5	64.5	60.7	53.2	47.9	(20)
(21)		2%	DB	44.4	47.7	56.9	70.9	78.4	82.1	86.2	84.8	75.6	65.5	54.7	46.8	(21)
(22)			MCWB	41.8	43.9	47.8	56.2	63.2	67.2	69.0	68.6	62.9	57.7	51.1	44.7	(22)
(23)		5%	DB	41.9	44.6	52.7	65.7	74.4	78.7	82.5	80.9	71.8	61.6	51.5	43.9	(23)
(24)			MCWB	39.8	41.7	45.4	53.1	61.5	65.5	67.4	66.4	61.3	55.8	48.8	42.2	(24)
(25)		10%	DB	39.2	41.5	48.4	61.6	70.4	75.2	78.9	77.4	68.1	58.2	48.9	41.4	(25)
(26)			MCWB	37.4	39.0	43.2	51.0	59.0	63.3	66.0	64.5	59.2	53.9	46.7	39.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	46.7	52.3	60.3	67.3	71.9	72.8	72.7	67.3	61.8	54.3	48.4	(27)
(28)			MCDWB	47.4	49.5	60.8	75.0	78.3	82.5	84.8	84.1	77.1	68.4	57.3	50.2	(28)
(29)		2%	WB	42.3	44.4	49.0	57.5	64.6	69.3	70.9	70.1	64.4	59.0	51.5	45.1	(29)
(30)			MCDWB	44.2	47.3	55.4	67.9	75.2	78.9	81.7	81.2	72.8	63.5	54.1	46.5	(30)
(31)		5%	WB	40.0	41.8	46.1	54.7	62.4	67.0	69.2	68.2	62.3	56.6	49.2	42.3	(31)
(32)			MCDWB	41.7	44.4	51.1	63.6	72.2	75.7	79.0	77.8	69.5	60.7	51.1	43.7	(32)
(33)		10%	WB	37.5	39.1	43.7	52.0	60.3	64.7	67.4	66.2	60.4	54.0	46.8	40.0	(33)
(34)			MCDWB	39.1	41.4	48.0	59.3	68.7	72.8	76.4	74.5	66.7	57.7	48.6	41.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.7	13.3	18.2	20.0	19.3	19.7	20.1	17.4	13.8	8.5	7.7	(35)
(36)			MCDBR	8.3	12.0	20.3	26.3	25.5	24.6	25.8	25.7	23.9	19.2	12.4	8.8	(36)
(37)			MCWBR	7.3	9.1	12.5	13.5	12.6	11.7	10.6	11.2	12.5	12.1	9.3	7.4	(37)
(38)		5% WB	MCDWB	8.1	11.3	18.2	23.7	23.1	21.3	22.0	22.0	21.1	17.5	10.9	8.5	(38)
(39)			MCWBR	7.3	9.1	12.0	13.0	12.1	11.3	10.3	10.4	11.7	11.6	8.6	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.340	0.375	0.427	0.412	0.408	0.438	0.433	0.394	0.363	0.352	0.310	(40)	
(41)		taud	2.221	2.206	2.218	2.131	2.241	2.279	2.212	2.220	2.297	2.359	2.281	2.264	(41)	
(42)		Ebn at Noon	211	239	255	255	266	268	257	251	247	231	193	190	(42)	
(43)		Edh at Noon	22	30	36	44	41	40	42	40	33	25	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	226	457	849	1291	1649	1748	1644	1441	1008	564	233	154	(44)	
(45)		RadStd	42	72	117	167	160	144	181	117	153	97	23	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.77	N/A	N/A	N/A	+1.15	+1.28	N/A	-252	+94	N/A	
(47) Regional (19 neighbors)		+0.90	N/A	N/A	N/A	+0.77	N/A	N/A	-297	+149	+54	

Nomenclature: See separate page