

TERESPOL, Poland

WMO: 123990

Lat: 52.0786N

Lon: 23.6219E

Elev: 451

StdP: 14.46

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	6.4	-4.6	4.4	0.4	1.7	6.1	7.8	18.7	36.1	17.2	32.9	4.3	0	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	86.4	69.2	83.1	67.6	80.0	66.0	71.3	82.1	69.5	79.6	67.8	76.8	7.1	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	103.5	75.8	66.0	97.6	74.0	64.5	92.3	72.3	35.4	82.2	33.8	79.7	32.4	77.0	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.2	14.2	12.6	-5.2	91.4	7.6	2.7	-10.7	93.3	-15.1	94.9	-19.3	96.4	-24.8	98.3		
			-5.7	74.1	7.2	1.6	-10.9	75.2	-15.1	76.2	-19.2	77.1	-24.4	78.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	26.0	28.9	36.5	48.3	56.7	62.7	66.7	65.2	56.1	46.9	39.0	30.8		
	DBStd	16.02	10.52	9.67	8.46	7.50	7.11	6.20	5.81	5.89	6.66	7.52	7.44	9.38		
	HDD50	2993	742	590	421	120	19	0	0	0	19	150	336	596		
	HDD65	6786	1207	1010	882	503	270	117	50	70	275	560	781	1061		
	CDD50	1932	0	0	4	68	227	381	517	472	203	55	5	0		
	CDD65	249	0	0	0	1	13	48	102	76	9	0	0	0		
	CDH74	2577	0	0	0	27	176	498	953	812	110	1	0	0		
	CDH80	697	0	0	0	4	25	113	283	254	18	0	0	0		
	WSAvg	6.1	6.8	6.7	7.3	6.6	5.9	5.5	5.4	5.1	5.2	5.9	6.5	6.6		
	PrecAvg	23.7	1.3	1.3	1.2	1.6	2.2	2.7	3.3	2.7	2.1	1.7	1.8	1.6		
Precipitation	PrecMax	33.4	3.8	3.1	2.7	3.5	4.1	5.7	8.4	6.8	5.2	9.7	3.6	3.2		
	PrecMin	14.8	0.1	0.0	0.1	0.4	0.4	0.5	0.2	0.6	0.3	0.1	0.5	0.2		
	PrecStd	4.5	0.8	0.7	0.6	0.7	0.9	1.3	2.0	1.5	1.2	1.6	0.8	0.7		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.5	50.8	63.0	77.5	83.2	87.2	90.7	91.0	82.4	71.2	59.5	50.4		
		MCWB	43.6	44.9	51.4	60.7	65.3	69.8	70.8	70.0	65.3	61.5	53.6	47.9		
	2%	DB	43.5	46.6	56.8	71.3	78.8	83.3	86.5	86.4	76.9	66.2	55.0	46.6		
		MCWB	40.8	42.8	46.7	56.4	63.3	67.5	69.3	69.4	63.9	57.8	50.9	44.6		
	5%	DB	40.9	43.6	52.6	66.2	75.1	79.7	82.9	82.2	72.8	62.3	51.9	44.0		
		MCWB	38.8	40.7	45.1	53.4	61.8	65.8	68.3	67.6	61.8	56.0	49.1	42.2		
	10%	DB	38.3	40.5	48.6	62.2	71.1	76.2	79.4	78.2	68.8	58.6	49.1	41.7		
		MCWB	36.7	38.1	43.3	51.3	59.4	64.1	66.6	65.2	59.7	54.0	46.9	40.0		
	0.4%	WB	44.1	46.0	52.4	61.3	67.8	71.8	73.9	73.7	67.6	62.2	54.3	48.4		
		MCDB	46.7	49.0	61.5	76.6	79.2	83.7	84.9	85.1	78.3	69.0	57.7	50.2		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.2	43.3	48.8	58.1	65.3	69.7	71.8	70.7	65.1	59.2	51.6	44.9		
		MCDB	43.1	46.1	55.2	68.4	75.8	80.3	82.0	82.1	74.4	64.6	54.2	46.4		
	5%	WB	39.0	40.7	46.1	55.2	63.1	67.6	69.9	68.7	62.9	56.7	49.4	42.4		
		MCDB	40.5	43.2	51.0	63.5	72.6	76.7	79.4	79.2	70.8	61.0	51.6	43.9		
	10%	WB	36.7	38.2	43.6	52.6	60.7	65.5	68.2	66.8	60.7	54.3	47.0	40.1		
		MCDB	38.1	40.4	48.0	59.8	69.4	73.5	76.6	75.5	67.1	58.2	48.9	41.6		
Mean Daily Temperature Range	5% DB	MDBR	8.3	9.7	13.8	18.2	19.8	19.7	19.4	20.8	18.6	14.8	9.0	7.8		
		MCDBR	8.5	12.7	21.4	25.7	25.7	25.0	24.8	26.6	25.4	20.4	13.5	9.3		
		MCWBR	7.4	9.5	13.0	12.9	12.6	11.7	10.3	11.5	13.4	12.7	9.9	7.9		
		MCDBR	8.0	11.8	18.8	22.8	23.0	22.2	21.2	23.7	22.2	18.7	12.0	9.2		
	5% WB	MCWBR	7.3	9.3	12.5	12.6	12.1	11.5	10.3	11.2	12.4	12.5	9.3	8.1		
Clear-Sky Solar Irradiance	taub		0.310	0.339	0.375	0.426	0.412	0.407	0.437	0.433	0.394	0.362	0.350	0.308		
	taud		2.218	2.191	2.212	2.145	2.250	2.291	2.222	2.227	2.300	2.367	2.283	2.258		
	Ebn at Noon		212	240	256	255	266	269	258	251	247	232	195	192		
	Edh at Noon		22	30	36	43	41	40	42	40	33	25	21	18		
All-Sky Solar Radiation	RadAvg		231	465	859	1294	1652	1755	1657	1457	1011	568	234	155		
	RadStd		40	71	119	161	159	139	172	116	153	100	23	27		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (16 neighbors)	+0.90	N/A	N/A	N/A	+0.92	+0.95	N/A	-292	+153	+58	

Nomenclature: See separate page