

SULEJOW, Poland

WMO: 124690

Lat: 51.3533N

Lon: 19.8664E

Elev: 621

StdP: 14.37

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 3.9	(c) 9.9	(d) -0.6	(e) 5.4	(f) 4.5	(g) 5.0	(h) 7.3	(i) 11.3	(j) 27.6	(k) 38.1	(l) 25.1	(m) 38.7	(n) 4.3	(o) 140	(p) 0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.6	(c) 86.4	(d) 68.4	(e) 83.0	(f) 66.7	(g) 79.8	(h) 65.2	(i) 70.2	(j) 82.3	(k) 68.6	(l) 79.5	(m) 67.0	(n) 76.5	(o) 7.9	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.4	99.5	73.8	64.8	94.1	72.2	63.4	89.3	71.1	34.5	82.6	33.1	79.6	31.8	76.7	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.4	19.4	16.9	-2.0	92.1	9.6	3.5	-8.9	94.7	-14.4	96.7	-19.8	98.7	-26.8	101.3		
			-3.0	73.0	8.8	1.6	-9.3	74.2	-14.5	75.1	-19.4	76.0	-25.9	77.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	28.0	30.6	37.3	48.0	56.1	62.3	66.0	65.6	56.8	48.1	39.9	32.2		
	DBStd	15.22	9.70	8.87	8.19	7.26	6.71	6.17	5.82	5.99	6.36	7.38	7.11	8.70		
	HDD50	2765	681	545	397	121	20	0	0	0	13	128	308	552		
	HDD65	6560	1146	964	859	511	284	124	58	65	254	525	753	1017		
	CDD50	1913	0	0	3	61	210	368	497	484	217	68	5	0		
	CDD65	235	0	0	0	1	9	42	90	84	9	0	0	0		
	CDH74	2518	0	0	0	31	156	470	905	842	113	1	0	0		
	CDH80	692	0	0	0	3	20	122	274	252	21	0	0	0		
(14) Wind	WSAvg	7.6	9.0	8.6	9.0	7.5	6.8	6.7	6.7	6.3	6.7	7.2	7.6	8.9		
(15) Precipitation	PrecAvg	23.6	1.3	1.2	1.4	1.6	2.6	2.9	3.6	2.4	2.0	1.6	1.6	1.4		
	PrecMax	31.8	2.8	2.6	2.6	4.4	6.3	7.1	8.8	5.8	4.6	3.7	3.3	3.3		
	PrecMin	17.7	0.2	0.2	0.6	0.1	1.1	0.7	0.4	0.8	0.6	0.2	0.1	0.4		
	PrecStd	3.9	0.6	0.6	0.6	0.9	1.5	1.6	2.2	1.3	0.9	0.9	0.7	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.2	52.7	63.0	77.9	82.8	89.1	91.0	91.5	82.9	71.9	59.5	51.2		
		MCWB	45.4	45.8	51.7	59.9	64.7	69.8	69.7	69.5	64.8	60.4	53.5	48.1		
	2%	DB	45.6	48.2	57.3	71.5	78.5	83.1	86.5	85.8	76.9	67.7	55.5	47.8		
		MCWB	42.7	43.8	47.6	56.4	62.7	67.4	68.3	68.1	62.5	58.6	50.9	45.3		
	5%	DB	42.7	44.8	53.0	66.2	74.6	79.2	82.7	82.2	72.9	63.3	52.4	45.3		
		MCWB	40.2	41.2	46.2	53.6	61.2	65.2	66.7	66.7	61.3	56.4	49.2	43.0		
	10%	DB	39.8	41.5	49.1	62.0	70.5	75.6	78.9	78.5	69.0	59.4	49.7	42.7		
		MCWB	38.0	38.7	44.2	51.1	58.8	63.4	65.3	64.8	59.5	54.4	47.2	40.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.9	47.2	52.6	60.5	66.8	71.9	72.1	72.2	67.1	62.3	54.2	49.0		
		MCDB	47.7	50.8	61.2	75.8	78.3	83.9	84.7	85.9	78.1	69.3	58.6	51.1		
	2%	WB	42.8	44.4	49.2	57.8	64.4	69.2	70.2	69.7	64.5	59.4	51.9	45.6		
		MCDB	45.0	48.1	55.4	69.2	75.0	80.3	82.0	82.9	73.5	66.1	55.0	47.6		
	5%	WB	40.5	41.6	46.8	55.1	62.4	66.9	68.7	68.0	62.6	57.1	49.4	43.3		
		MCDB	42.5	44.5	51.8	64.0	72.3	76.1	79.1	79.5	71.2	62.3	51.9	45.0		
	10%	WB	38.1	38.9	44.4	52.5	60.2	64.7	67.0	66.3	60.5	54.9	47.3	41.0		
		MCDB	39.7	41.3	49.0	60.1	68.9	73.2	75.8	75.6	67.3	59.0	49.6	42.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	10.6	13.7	18.9	19.4	19.3	19.6	20.3	17.7	14.7	9.8	7.9		
		MCDBR	9.6	14.5	21.3	26.8	26.9	26.0	26.1	26.1	24.8	21.2	14.6	9.7		
	5% WB	MCWBR	7.8	10.5	13.5	13.9	13.2	12.3	10.0	10.9	12.2	12.9	10.7	7.8		
		MCWBR	9.2	13.6	19.2	24.4	24.1	22.7	22.0	23.1	22.3	19.6	13.7	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.345	0.383	0.435	0.425	0.422	0.450	0.439	0.403	0.372	0.352	0.316		
	taud		2.259	2.252	2.207	2.121	2.206	2.250	2.183	2.216	2.282	2.336	2.318	2.302		
	Ebn at Noon		214	242	254	254	263	265	254	250	246	230	200	196		
	Edh at Noon		22	29	36	45	43	42	44	40	34	27	21	18		
(44) All-Sky Solar Radiation	RadAvg		238	465	847	1305	1628	1720	1610	1440	1029	588	268	181		
	RadStd		45	82	107	173	176	161	193	116	147	89	33	25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.90	N/A	N/A	+1.40	N/A	N/A	N/A	-293	+126	+54

Nomenclature: See separate page