

RADOM, Poland

WMO: 124850

Lat: 51.414N

Lon: 21.111E

Elev: 600

StdP: 14.38

Time Zone: 1.00 (EUC)

Period: 01-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	7.4	-3.0	4.8	1.6	2.8	6.5	9.1	23.4	38.2	21.9	36.0	4.6	100	0.530

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	85.7	67.8	82.7	66.8	79.9	65.3	70.7	81.3	69.1	79.0	67.4	76.2	7.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	102.5	74.8	65.7	96.8	73.4	64.2	91.8	71.7	35.0	81.5	33.5	79.0	32.2	76.9	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.3	17.6	15.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-5.0	73.6	9.7	2.6	-12.0	75.5	-17.6	77.0	-23.1	78.5	-30.1	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.9	26.3	29.8	37.6	48.1	57.7	63.3	68.3	66.4	57.1	47.6	40.5	31.4
	DBStd	16.15	11.26	10.00	9.13	7.17	6.47	5.59	5.69	5.28	6.35	7.46	7.20	9.06
	HDD50	2832	734	567	392	114	10	0	0	0	12	137	290	576
	HDD65	6523	1199	986	850	508	240	98	32	45	249	541	734	1041
	CDD50	2079	0	0	7	57	249	398	568	509	224	61	6	0
	CDD65	297	0	0	0	1	14	46	135	89	12	0	0	0
	CDH74	2522	0	0	0	23	147	406	1157	682	107	0	0	0
	CDH80	624	0	0	0	4	17	80	345	165	13	0	0	0
Wind	WSAvg	7.2	8.2	8.3	8.3	7.1	6.6	6.3	6.3	6.3	6.1	7.1	8.0	8.4
Precipitation	PrecAvg	25.0	1.3	1.3	1.5	1.7	2.4	2.6	3.9	2.6	2.3	1.7	1.5	1.3
	PrecMax	31.4	3.7	2.5	3.6	4.0	6.5	5.8	12.8	7.4	5.0	4.2	2.8	2.4
	PrecMin	18.7	0.2	0.4	0.5	0.0	1.1	1.3	0.6	0.7	0.2	0.2	0.0	0.3
	PrecStd	3.3	0.7	0.5	0.7	1.0	1.3	1.2	2.8	1.4	1.3	1.1	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.7	54.3	65.3	76.5	82.1	86.5	91.2	89.1	82.1	70.6	60.9	49.8
		MCWB	46.5	47.7	52.6	58.3	63.8	69.2	70.5	69.4	62.5	60.8	55.3	46.3
	2%	DB	46.8	49.5	59.5	70.0	78.1	82.3	87.0	84.1	77.1	65.7	56.0	46.9
		MCWB	43.7	45.7	48.1	55.0	63.8	66.2	67.8	67.9	62.2	56.9	51.5	44.1
	5%	DB	43.7	46.0	55.5	65.5	74.3	78.6	83.9	81.0	72.8	62.5	52.8	44.5
		MCWB	41.1	42.0	46.6	52.9	61.3	64.1	67.7	66.2	60.4	55.8	49.4	42.4
	10%	DB	40.7	42.6	51.4	61.4	70.5	75.4	80.5	77.6	68.7	59.2	50.4	42.2
		MCWB	38.7	39.6	45.0	50.0	58.7	62.2	66.2	64.9	58.6	54.4	48.0	40.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.1	48.6	53.5	59.2	67.0	70.9	73.0	72.5	66.5	61.7	55.6	47.4
		MCDB	50.1	51.8	63.3	74.1	78.3	80.8	84.5	82.0	75.6	68.1	60.0	49.1
	2%	WB	44.0	45.8	50.4	56.6	64.7	68.5	71.2	70.1	63.5	58.4	52.6	44.7
		MCDB	46.6	49.6	57.2	67.2	75.5	78.5	82.1	80.7	71.5	63.7	55.5	46.4
	5%	WB	41.4	42.6	47.7	53.9	62.6	66.4	69.8	68.3	61.9	56.5	50.2	42.6
		MCDB	43.3	46.0	54.4	63.0	72.0	75.0	79.7	77.5	69.7	61.4	52.1	44.5
	10%	WB	38.6	39.7	44.7	51.6	60.4	64.4	68.0	66.6	60.0	54.3	47.9	40.3
		MCDB	40.4	41.9	50.1	59.7	68.0	72.3	77.3	74.1	68.0	58.9	50.3	41.9
Mean Daily Temperature Range	5% DB	MDBR	9.1	11.4	14.5	18.3	17.9	17.6	18.0	17.9	16.7	14.2	10.1	9.1
		MCDBR	10.5	15.1	22.0	25.3	23.3	22.9	23.1	23.4	23.4	18.9	14.3	11.1
		MCWBR	8.7	11.3	12.8	13.2	11.7	10.6	8.7	9.8	10.5	11.4	10.2	8.7
	5% WB	MCDBR	10.2	13.8	20.0	22.5	21.0	20.0	20.4	20.7	19.7	17.5	13.0	10.1
MCWBR		8.7	10.8	12.3	12.3	11.5	10.7	9.1	9.6	9.9	11.3	9.8	8.4	
Clear-Sky Solar Irradiance	taub	0.321	0.348	0.385	0.432	0.418	0.415	0.442	0.435	0.400	0.372	0.355	0.316	
	taud	2.242	2.228	2.196	2.129	2.230	2.269	2.206	2.228	2.291	2.329	2.293	2.284	
	Ebn at Noon	212	240	253	255	265	267	257	252	247	229	197	194	
	Edh at Noon	22	30	37	44	42	41	43	40	33	27	21	18	
All-Sky Solar Radiation	RadAvg	234	467	852	1292	1624	1741	1623	1445	1027	589	259	177	
	RadStd	45	78	111	174	177	152	196	110	154	87	27	28	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	+0.94	N/A	N/A	+1.39	N/A	N/A	N/A	-299	+137	+56	

Nomenclature: See separate page