

KOZIENICE, Poland

WMO: 124880

Lat: 51.5647N

Lon: 21.5436E

Elev: 414

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	8.3	-2.9	4.8	2.3	3.2	6.6	10.1	20.3	36.9	18.6	34.1	3.7	110	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	87.6	69.3	83.8	67.6	80.7	66.2	71.0	82.8	69.4	80.5	67.7	77.7	7.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.2	101.6	75.4	65.6	96.1	73.5	64.2	91.4	72.0	35.1	83.2	33.7	80.7	32.3	77.8	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.1	15.1	13.4	DB	-4.4	92.7	9.4	2.7	-11.2	94.6	-16.6	96.3	-21.9	97.8	-28.7	99.8	(4)
(5)			WB	-4.8	74.2	8.8	1.9	-11.1	75.5	-16.2	76.6	-21.1	77.7	-27.5	79.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	27.4	30.4	37.7	48.0	56.5	63.1	66.9	65.7	56.6	47.7	39.7	32.2	(6)
(7)		DBStd	15.60	10.67	9.65	8.66	7.25	6.56	6.05	5.68	5.56	6.45	7.68	7.34	9.15	(7)
(8)		HDD50	2794	702	548	388	120	16	0	0	0	15	136	316	553	(8)
(9)		HDD65	6546	1167	968	846	510	272	107	46	59	260	536	758	1017	(9)
(10)		CDD50	1977	0	0	7	61	218	393	525	487	214	65	7	0	(10)
(11)		CDD65	255	0	0	0	1	9	49	106	80	10	0	0	0	(11)
(12)		CDH74	2989	0	0	0	37	189	601	1125	896	140	1	0	0	(12)
(13)		CDH80	862	0	0	0	5	28	150	368	285	26	0	0	0	(13)
(14)	Wind	WSAvg	6.2	7.3	7.1	7.4	6.6	5.9	5.5	5.5	4.9	5.1	6.0	6.6	7.0	(14)
(15)	Precipitation	PrecAvg	23.5	1.3	1.3	1.5	1.7	2.5	2.6	3.7	2.4	2.1	1.6	1.5	1.4	(15)
(16)		PrecMax	29.4	3.3	2.7	3.3	4.3	5.6	6.0	11.4	8.0	5.0	4.0	3.2	3.3	(16)
(17)		PrecMin	17.5	0.2	0.3	0.3	0.0	0.8	1.2	0.4	0.4	0.2	0.2	0.1	0.3	(17)
(18)		PrecStd	3.1	0.7	0.6	0.7	1.0	1.3	1.3	2.4	1.5	1.4	1.1	0.6	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	53.7	64.6	78.4	83.4	89.2	92.3	92.3	83.6	72.2	60.3	52.3	(19)
(20)			MCWB	46.0	47.3	51.2	60.1	66.0	70.7	69.6	69.8	65.8	61.1	53.9	48.2	(20)
(21)		2%	DB	46.1	49.1	58.9	72.1	79.1	84.1	87.9	86.8	77.9	67.8	56.1	48.9	(21)
(22)			MCWB	42.9	44.6	48.3	57.0	63.9	68.3	69.2	69.3	63.8	58.9	51.2	45.9	(22)
(23)		5%	DB	43.2	45.9	54.8	66.8	75.2	80.5	83.9	82.8	73.9	63.7	53.2	45.8	(23)
(24)			MCWB	40.5	42.0	46.3	53.8	61.9	66.0	67.6	67.0	62.0	56.7	49.4	43.3	(24)
(25)		10%	DB	40.2	42.7	50.3	62.7	71.4	77.1	80.3	78.9	69.7	60.0	50.6	43.0	(25)
(26)			MCWB	38.0	39.8	44.4	51.8	59.5	63.9	66.4	65.5	59.5	54.9	47.9	41.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.3	47.9	53.0	60.9	68.0	72.6	73.2	72.9	67.5	62.6	54.8	49.6	(27)
(28)			MCD B	49.3	52.0	63.3	77.1	79.8	83.9	86.3	86.3	80.0	69.8	58.8	52.1	(28)
(29)		2%	WB	43.2	45.2	49.9	58.1	65.3	70.1	71.2	70.5	65.0	59.7	52.3	46.0	(29)
(30)			MCD B	45.7	48.8	57.3	69.9	76.5	81.7	82.5	82.7	75.3	66.3	55.4	48.2	(30)
(31)		5%	WB	40.8	42.3	47.3	55.4	63.0	67.9	69.5	68.7	63.0	57.4	50.0	43.4	(31)
(32)			MCD B	43.0	45.3	52.8	64.7	73.2	77.5	80.3	80.1	71.8	62.8	52.6	45.5	(32)
(33)		10%	WB	38.0	39.7	44.9	52.9	60.9	65.6	67.8	66.9	60.9	55.0	47.9	41.1	(33)
(34)			MCD B	39.9	42.5	49.7	60.7	69.1	74.1	77.2	76.1	67.9	59.5	50.4	42.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	10.8	14.9	20.2	21.1	20.7	20.7	21.4	19.3	15.8	10.0	8.5	(35)
(36)			MCDBR	9.5	14.5	22.6	28.7	28.4	27.2	28.0	28.3	26.9	22.2	15.2	10.2	(36)
(37)			MCWBR	7.9	10.5	13.5	14.8	14.7	13.2	11.1	12.4	13.6	13.8	11.0	8.0	(37)
(38)		5% WB	MCD BR	9.4	13.3	20.1	25.6	25.3	24.0	23.6	24.8	23.8	20.1	13.3	9.5	(38)
(39)			MCWBR	8.0	10.1	12.8	14.0	13.8	12.7	10.6	11.3	12.5	12.9	10.0	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.321	0.348	0.384	0.437	0.422	0.419	0.447	0.440	0.403	0.372	0.357	0.317	(40)	
(41)		taud	2.237	2.221	2.200	2.113	2.220	2.260	2.196	2.214	2.280	2.333	2.286	2.278	(41)	
(42)		Ebn at Noon	211	239	253	253	264	266	255	250	245	229	196	193	(42)	
(43)		Edh at Noon	22	30	36	45	42	41	43	40	34	26	22	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	231	463	850	1293	1629	1743	1624	1442	1024	584	253	173	(44)	
(45)		RadStd	44	76	111	175	175	153	195	111	155	88	26	27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.97	N/A	N/A	+1.35	+0.77	N/A	N/A	-302	+148	+56

Nomenclature: See separate page