

DEBLIN, Poland

WMO: 124900

Lat: 51.551N

Lon: 21.894E

Elev: 392

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 1.0	(c) 7.5	(d) -4.3	(e) 4.4	(f) 1.8	(g) 2.1	(h) 6.2	(i) 8.9	(j) 23.5	(k) 26.6	(l) 21.9	(m) 27.9	(n) 3.6	(o) 90	(p) 0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	88.1	68.7	84.5	67.3	81.4	65.9	70.7	83.7	69.2	81.0	67.7	78.0	7.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.7	99.6	74.7	65.3	94.8	73.5	63.9	90.1	72.5	34.8	84.0	33.5	81.5	32.3	78.3	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.7	(b) 17.2	(c) 15.0	(e) -5.7	(f) 93.2	(g) 8.4	(h) 2.7	(i) -11.8	(j) 95.2	(k) -16.7	(l) 96.8	(m) -21.4	(n) 98.3	(o) -27.5	(p) 100.3		
(a) 19.7	(b) 17.2	(c) 15.0	(e) -4.4	(f) 73.7	(g) 8.9	(h) 1.7	(i) -10.8	(j) 74.9	(k) -16.0	(l) 75.9	(m) -21.0	(n) 76.9	(o) -27.5	(p) 78.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	26.6	29.7	37.8	48.1	57.3	63.7	67.8	66.5	56.8	47.1	39.7	31.4	(6)
(7)		DBStd	16.10	10.79	9.63	8.68	7.35	6.88	5.97	6.04	5.95	6.44	7.45	7.12	9.03	(7)
(8)		HDD50	2866	727	569	385	120	15	0	0	0	13	146	314	577	(8)
(9)		HDD65	6590	1192	989	844	509	252	95	42	53	258	556	758	1042	(9)
(10)		CDD50	2061	0	0	6	62	242	411	551	512	216	55	6	0	(10)
(11)		CDD65	308	0	0	0	1	14	55	128	99	11	0	0	0	(11)
(12)		CDH74	3297	0	0	0	35	199	629	1259	1029	146	0	0	0	(12)
(13)		CDH80	1000	0	0	0	7	27	166	419	347	34	0	0	0	(13)
(14)	Wind	WSAvg	6.7	7.2	7.2	7.7	7.3	6.4	6.5	6.2	5.6	6.1	6.2	6.5	7.2	(14)
(15)	Precipitation	PrecAvg	23.0	1.3	1.2	1.4	1.6	2.4	2.6	3.5	2.5	2.1	1.6	1.5	1.4	(15)
(16)		PrecMax	29.1	3.2	2.6	3.0	4.0	5.2	5.8	10.5	8.0	4.4	4.4	3.3	3.1	(16)
(17)		PrecMin	17.2	0.2	0.2	0.4	0.1	1.0	1.1	0.5	0.4	0.3	0.2	0.1	0.3	(17)
(18)		PrecStd	3.0	0.7	0.6	0.6	0.9	1.2	1.3	2.2	1.5	1.3	1.1	0.6	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	53.6	65.1	78.6	83.3	89.6	92.1	93.3	84.3	71.4	61.1	53.5	(19)
(20)			MCWB	46.0	46.9	51.8	59.5	64.6	70.1	69.9	70.2	65.9	60.1	53.9	48.2	(20)
(21)		2%	DB	45.4	48.8	59.4	72.2	79.3	84.6	88.2	87.6	77.7	67.0	56.3	48.4	(21)
(22)			MCWB	42.3	44.2	48.8	55.9	62.9	67.8	68.2	68.6	63.3	58.3	50.7	44.8	(22)
(23)		5%	DB	42.5	45.3	55.5	67.1	75.6	80.7	84.7	83.4	73.8	62.9	53.0	45.6	(23)
(24)			MCWB	39.8	41.1	45.9	53.4	61.1	65.3	67.6	66.9	61.6	56.0	49.1	43.0	(24)
(25)		10%	DB	39.8	42.0	51.1	62.7	71.6	77.2	81.3	79.8	69.4	59.0	50.1	42.7	(25)
(26)			MCWB	37.6	38.7	44.7	51.3	59.2	63.4	66.4	65.4	59.6	54.2	47.3	40.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	48.0	53.0	60.2	67.8	72.1	72.5	72.3	67.9	62.2	54.6	48.7	(27)
(28)			MCD B	49.1	51.5	62.5	76.7	79.5	85.8	84.9	85.6	81.0	69.3	60.1	52.8	(28)
(29)		2%	WB	42.7	44.5	49.8	57.5	64.4	69.4	70.8	70.2	65.1	59.2	51.8	45.4	(29)
(30)			MCD B	45.4	48.7	57.8	69.6	75.6	81.5	83.3	83.6	75.2	65.3	55.1	48.0	(30)
(31)		5%	WB	40.0	41.4	47.5	54.7	62.4	67.3	69.4	68.7	62.7	56.8	49.6	43.0	(31)
(32)			MCD B	42.2	44.9	54.0	64.3	72.7	77.9	80.9	80.5	70.3	62.0	52.5	45.1	(32)
(33)		10%	WB	37.6	39.0	44.7	52.2	60.4	65.1	67.9	67.1	60.6	54.2	47.3	40.6	(33)
(34)			MCD B	39.7	41.7	50.3	60.9	69.7	74.1	77.7	76.8	68.0	58.7	50.0	42.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.3	11.6	15.9	20.3	20.0	20.3	20.3	21.3	19.0	15.7	10.2	9.2	(35)
(36)			MCDBR	10.1	15.7	24.8	28.4	25.8	26.1	26.3	27.4	26.2	22.7	15.5	11.6	(36)
(37)			MCWBR	8.4	11.4	14.9	14.8	12.1	11.6	10.0	11.1	12.9	14.4	11.3	9.2	(37)
(38)		5% WB	MCD BR	9.8	14.1	21.7	25.9	22.8	23.2	22.8	24.2	22.7	20.9	14.1	10.7	(38)
(39)			MCWBR	8.4	10.7	13.8	14.2	11.7	11.0	9.6	10.5	11.7	13.8	10.7	8.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.319	0.346	0.382	0.438	0.423	0.420	0.448	0.442	0.405	0.370	0.356	0.316	(40)	
(41)		taud	2.234	2.217	2.202	2.105	2.213	2.252	2.190	2.205	2.271	2.336	2.285	2.278	(41)	
(42)		Ebn at Noon	212	240	254	252	264	266	255	249	245	230	196	193	(42)	
(43)		Edh at Noon	22	30	36	45	43	41	43	41	34	26	22	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	235	468	858	1297	1635	1750	1637	1455	1023	587	252	171	(44)	
(45)		RadStd	43	73	114	168	171	149	186	112	157	91	26	28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.97	N/A	N/A	+1.31	+0.76	N/A	N/A	-306	+149	+61

Nomenclature: See separate page