

JELENIA GORA, Poland

WMO: 125000

Lat: 50.9003N

Lon: 15.7889E

Elev: 343

StdP: 97.27

Time Zone: 1.00 (EUC)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-13.4	-19.5	0.7	-16.6	-16.0	1.0	-12.3	10.5	4.6	9.4	4.3	0.8	150	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	29.1	19.5	27.1	18.6	25.3	17.9	20.6	27.1	19.6	25.4	18.6	23.8	2.8	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.8	22.9	17.5	13.1	21.6	16.6	12.4	20.7	60.7	27.4	57.3	25.4	54.1	24.1	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.3	6.3	DB	-21.1	32.2	4.7	1.8	-24.5	33.5	-27.2	34.5	-29.9	35.5	-33.3	36.8	(4)
(5)			WB	-21.2	22.2	4.7	0.8	-24.5	22.8	-27.2	23.3	-29.9	23.7	-33.3	24.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	-1.8	-0.4	2.6	7.6	12.1	15.1	17.3	16.9	12.5	8.3	3.6	-0.6	(6)	
	DBStd	7.93	5.73	5.24	4.31	4.21	3.64	3.41	3.03	3.12	3.31	4.01	4.17	5.34	(7)	
	HDD10.0	1621	367	292	230	95	19	2	0	0	12	81	195	328	(8)	
	HDD18.3	3902	626	525	487	323	196	107	57	66	175	312	442	586	(9)	
	CDD10.0	821	0	1	2	22	84	156	226	213	88	27	3	0	(10)	
	CDD18.3	59	0	0	0	0	2	11	24	21	1	0	0	0	(11)	
	CDH23.3	869	0	0	0	7	49	165	334	282	33	1	0	0	(12)	
	CDH26.7	212	0	0	0	0	4	39	91	73	5	0	0	0	(13)	
(14) Wind	WSAvg	2.3	2.7	2.8	2.8	2.4	2.2	2.0	2.0	1.8	1.9	2.3	2.4	2.5	(14)	
(15) Precipitation	PrecAvg	851	65	56	66	45	73	89	115	87	71	56	61	67	(15)	
	PrecMax	1056	142	92	144	80	127	210	368	332	150	153	124	136	(16)	
	PrecMin	600	10	6	24	4	38	38	21	27	22	8	2	23	(17)	
	PrecStd	132	34	26	28	19	27	40	67	65	37	34	28	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	13.0	18.1	24.2	27.1	30.4	32.0	32.2	27.1	22.3	16.0	11.7	(19)	
		MCWB	8.2	8.0	10.4	14.6	17.3	20.3	19.8	20.6	17.8	15.6	11.4	8.6	(20)	
	2%	DB	9.6	10.6	14.7	21.2	24.8	27.6	29.3	28.6	23.7	19.4	13.8	9.9	(21)	
		MCWB	6.7	7.0	8.6	12.9	16.8	19.1	19.4	19.3	16.6	14.0	10.6	7.2	(22)	
	5%	DB	7.7	8.8	12.2	18.5	22.5	25.1	27.0	26.4	21.8	17.2	12.0	8.4	(23)	
		MCWB	5.4	5.8	7.7	11.5	15.3	17.7	18.9	18.6	15.9	12.9	9.2	6.0	(24)	
	10%	DB	5.8	7.1	9.9	16.2	20.2	22.8	24.9	24.4	19.7	15.2	10.4	6.6	(25)	
		MCWB	3.8	4.8	6.5	10.4	14.1	16.6	18.1	17.6	15.0	11.8	8.1	4.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	8.8	10.8	15.3	19.0	21.7	21.6	21.4	19.0	16.6	12.2	9.1	(27)	
		MCDB	11.0	11.7	16.3	22.9	24.7	28.2	27.8	28.6	25.0	21.0	15.0	11.2	(28)	
	2%	WB	7.0	7.6	9.3	13.5	17.3	19.8	20.5	20.4	17.5	14.6	10.8	7.5	(29)	
		MCDB	9.3	10.1	13.6	19.9	23.3	25.6	27.0	27.1	22.2	18.2	13.3	9.7	(30)	
	5%	WB	5.4	6.1	8.0	12.1	16.0	18.4	19.6	19.3	16.5	13.2	9.5	6.1	(31)	
		MCDB	7.5	8.5	11.7	17.8	21.0	23.8	25.5	24.8	20.7	16.6	11.7	8.2	(32)	
	10%	WB	3.9	4.7	6.6	10.7	14.8	17.2	18.6	18.3	15.3	12.2	8.2	4.7	(33)	
		MCDB	5.8	7.0	9.5	15.5	19.5	21.6	23.7	23.0	19.1	14.8	10.2	6.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	8.9	11.0	11.2	10.8	11.0	11.9	10.2	9.2	7.3	6.7	(35)	
		MCDBR	7.7	9.8	14.8	16.2	15.6	15.9	16.1	15.8	14.8	13.3	10.1	7.5	(36)	
	5% WB	MCWBR	5.8	6.8	9.3	8.8	8.3	7.9	7.4	7.4	8.3	8.4	7.3	5.8	(37)	
		MCWBR	7.3	8.6	13.1	14.8	13.8	14.2	13.8	14.1	13.1	12.3	9.5	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.316	0.344	0.392	0.444	0.441	0.436	0.457	0.449	0.405	0.376	0.346	0.310	(40)	
		taud	2.265	2.228	2.148	2.076	2.131	2.185	2.137	2.172	2.258	2.296	2.314	2.313	(41)	
	Ebn at Noon		689	767	792	792	816	823	797	781	774	722	646	639	(42)	
		Edh at Noon	69	94	122	148	146	140	144	133	109	88	67	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.78	1.51	2.53	4.09	4.97	5.28	5.00	4.43	3.16	1.81	0.86	0.58	(44)	
	RadStd		0.13	0.25	0.37	0.55	0.57	0.45	0.59	0.42	0.43	0.26	0.12	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A
(47)	Regional (43 neighbors)	+0.45	N/A	N/A	N/A	N/A	+0.31	N/A	N/A	+59	+21

Nomenclature: See separate page