

SNIEZKA, Poland

WMO: 125100

Lat: 50.7361N

Lon: 15.7394E

Elev: 5293

StdP: 12.09

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.9	5.4	-17.1	2.6	22.2	-9.8	4.0	18.2	82.7	25.9	77.4	26.0	33.6	340	1.285

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	65.9	56.4	62.9	54.9	60.2	53.6	58.1	63.1	56.5	61.0	54.9	59.0	13.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.2	82.1	59.7	54.6	77.3	58.3	53.0	72.7	56.9	27.6	63.5	26.4	60.9	25.3	59.3	64.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
71.6	63.4	56.7	DB	-2.0	70.6	4.4	2.9	-5.1	72.7	-7.7	74.4	-10.1	76.0	-13.3	78.1	
			WB	-2.6	61.3	4.3	1.6	-5.7	62.5	-8.2	63.4	-10.6	64.4	-13.7	65.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.7	20.8	20.7	24.4	32.2	40.4	46.2	49.9	50.0	42.3	36.3	29.4	23.4
	DBStd	13.20	7.80	8.53	8.21	8.59	7.72	7.61	7.01	6.74	6.98	8.41	8.50	8.36
	HDD50	5825	904	820	795	535	312	164	93	85	245	430	619	823
	HDD65	11045	1369	1240	1260	983	763	565	470	466	681	891	1069	1288
	CDD50	256	0	0	0	1	14	48	88	85	14	5	1	0
	CDD65	2	0	0	0	0	0	0	1	1	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	26.5	33.1	32.4	30.4	25.4	22.7	20.9	21.3	19.1	23.0	27.9	30.0	32.6
Precipitation	PrecAvg	38.8	3.4	2.8	3.0	1.9	3.0	3.8	4.6	3.9	3.2	2.7	3.1	3.5
	PrecMax	48.1	7.8	6.5	7.6	3.7	5.4	7.7	12.0	11.0	6.9	7.8	6.9	7.4
	PrecMin	27.5	0.4	0.6	1.0	0.2	1.4	1.6	1.3	1.5	0.9	0.6	0.1	1.6
	PrecStd	5.3	1.8	1.4	1.6	0.8	1.2	1.4	2.2	2.3	1.6	1.5	1.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.2	42.4	45.0	54.6	61.2	67.8	69.6	69.4	61.1	58.8	52.6	46.5
		MCWB	33.2	33.3	35.6	46.0	52.4	57.7	57.8	57.2	52.9	45.9	38.2	35.9
	2%	DB	37.9	38.7	41.2	50.9	57.5	63.7	66.0	65.4	57.3	54.0	47.4	40.8
		MCWB	31.2	32.0	34.3	43.7	50.7	55.6	56.5	56.3	51.3	43.8	38.7	32.1
	5%	DB	34.4	35.1	38.3	47.0	54.4	60.3	62.7	62.0	54.4	50.5	43.8	38.0
		MCWB	30.5	31.2	34.2	41.3	48.8	54.0	55.0	55.0	49.7	43.4	38.1	32.7
	10%	DB	31.8	31.8	35.6	43.7	51.0	57.0	59.8	59.2	51.9	47.5	40.9	34.8
		MCWB	29.6	29.7	33.3	39.7	46.7	51.9	53.8	53.7	48.4	43.0	37.1	31.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.2	37.2	39.6	47.5	54.7	60.1	60.4	59.7	55.4	50.4	44.0	38.6
		MCDB	37.0	38.9	41.5	52.5	59.2	64.6	65.9	65.1	59.0	52.6	46.3	41.7
	2%	WB	33.6	34.3	37.1	44.8	51.8	57.4	58.0	57.7	52.9	47.5	41.8	36.3
		MCDB	36.1	36.5	39.0	49.0	55.8	61.5	63.0	62.6	55.5	50.2	43.8	38.3
	5%	WB	31.8	31.9	35.2	42.5	49.4	54.7	56.3	56.2	51.0	45.6	39.6	34.1
		MCDB	33.7	33.4	37.1	45.8	53.0	59.0	61.0	60.6	53.4	48.1	41.8	36.1
	10%	WB	29.6	29.6	33.2	40.2	47.4	52.4	54.8	54.5	49.2	43.8	37.7	31.8
		MCDB	31.4	31.2	34.9	43.1	50.5	56.1	58.8	58.4	51.3	46.2	40.4	33.6
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.6	7.5	7.5	8.1	8.1	7.7	7.6	6.6	7.4	7.6	7.7
		MCDBR	9.8	10.3	9.1	9.9	10.9	11.4	10.8	10.7	9.0	10.1	10.0	10.2
		MCWBR	7.4	8.1	7.4	7.2	8.1	9.2	7.1	7.6	7.7	8.0	6.7	7.5
	5% WB	MCDBR	8.6	9.6	8.7	9.7	10.0	10.7	9.8	9.7	8.3	8.7	9.4	9.8
		MCWBR	8.1	8.9	8.0	7.7	8.2	9.1	7.6	7.9	7.3	8.0	8.0	8.9
Clear-Sky Solar Irradiance	taub	0.260	0.281	0.316	0.355	0.354	0.351	0.365	0.360	0.329	0.309	0.286	0.256	
	taud	2.380	2.373	2.343	2.300	2.328	2.352	2.308	2.344	2.417	2.458	2.457	2.420	
	Ebn at Noon	251	274	281	281	286	287	280	276	274	259	238	235	
	Edh at Noon	19	25	32	37	38	37	38	35	29	23	18	16	
All-Sky Solar Radiation	RadAvg	252	486	807	1298	1574	1676	1584	1404	1001	574	272	185	
	RadStd	43	77	122	171	181	143	187	135	137	83	36	19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	+0.68	+0.76	N/A	N/A	N/A	N/A
(47) Regional (47 neighbors)	+0.79	N/A	N/A	N/A	N/A	+0.56	N/A	N/A	+104	+38

Nomenclature: See separate page