

BALICE, PolandWMO: **125660**Lat: **50.0777N**Lon: **19.7948E**Elev: **791**StdP: **14.28**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.9	9.5	-0.3	5.5	4.0	5.3	7.4	10.3	27.5	42.3	24.5	40.5	5.0	60	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.3	86.7	69.0	83.4	67.6	80.2	66.2	70.8	82.8	69.2	80.5	67.6	77.3	6.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	100.9	75.4	65.3	96.4	73.7	64.1	92.3	72.2	35.1	83.1	33.7	80.7	32.4	77.5	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.7	18.7	16.4	-0.8	92.4	7.1	2.7	-5.9	94.4	-10.1	96.0	-14.1	97.5	-19.3	99.5		
			-1.3	74.2	6.9	1.4	-6.3	75.2	-10.3	76.0	-14.2	76.8	-19.3	77.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	28.5	31.3	38.3	48.7	57.3	63.5	66.8	65.9	57.2	48.3	39.6	31.0
	DBStd	15.44	9.58	9.06	7.78	7.47	6.60	6.13	5.57	5.75	6.11	7.38	7.49	8.87
	HDD50	2720	666	523	365	110	13	0	0	0	10	124	318	591
	HDD65	6424	1131	943	827	491	250	100	46	59	242	518	761	1056
	CDD50	2036	0	0	3	70	240	404	522	493	226	71	7	0
	CDD65	264	0	0	0	1	12	54	103	86	8	0	0	0
	CDH74	2658	0	0	0	33	178	561	978	795	109	4	0	0
	CDH80	734	0	0	0	3	27	147	305	235	17	0	0	0
Wind	WSAvg	6.5	7.4	7.4	7.8	6.9	6.1	6.2	5.9	5.2	5.7	5.9	6.5	6.8
Precipitation	PrecAvg	27.4	1.4	1.2	1.3	2.0	3.1	3.9	3.7	3.3	2.2	1.9	1.7	1.5
	PrecMax	37.9	3.2	4.3	3.1	4.0	6.2	7.8	11.2	7.3	4.3	6.3	3.6	3.4
	PrecMin	18.5	0.2	0.0	0.1	0.5	1.3	1.6	1.6	0.9	0.2	0.0	0.3	0.2
	PrecStd	4.6	0.7	0.7	0.8	1.0	1.2	1.5	2.2	1.5	1.0	1.3	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.4	56.2	66.0	78.4	83.5	89.3	91.3	91.3	82.2	73.5	64.0	53.9
		MCWB	47.0	47.2	51.4	58.9	64.3	69.4	70.0	70.1	65.5	61.1	54.7	47.2
	2%	DB	47.2	50.6	60.2	72.4	78.7	84.3	87.1	86.0	77.0	68.7	58.6	48.5
		MCWB	43.7	44.6	49.1	56.7	63.1	68.4	68.9	69.1	63.9	59.0	52.0	44.8
	5%	DB	43.8	46.8	55.4	67.6	75.1	80.3	83.1	82.0	73.0	64.5	53.9	45.1
		MCWB	41.0	42.1	46.4	54.3	61.8	66.3	67.7	67.9	62.1	57.0	49.6	42.3
	10%	DB	40.6	43.1	51.0	63.0	71.3	76.7	79.4	78.3	69.1	60.1	50.4	42.4
		MCWB	38.4	39.8	44.7	52.0	59.6	64.4	66.1	65.9	60.5	55.1	47.7	40.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	48.4	52.7	60.5	67.2	72.3	72.9	72.8	67.5	62.6	55.3	48.7
		MCDB	51.8	54.1	62.5	74.5	79.1	84.7	85.9	84.0	77.6	71.3	61.1	52.6
	2%	WB	43.8	45.1	50.0	57.7	64.6	69.9	70.7	70.4	65.2	59.9	52.7	45.0
		MCDB	46.7	49.9	58.5	69.8	75.3	81.2	82.7	82.6	73.8	66.6	57.9	48.0
	5%	WB	41.0	42.5	47.7	55.5	62.6	67.7	69.1	68.8	63.2	57.7	50.2	42.6
		MCDB	43.3	46.2	54.3	65.5	73.1	77.8	80.1	79.9	71.1	63.6	53.4	44.9
	10%	WB	38.4	39.9	45.1	53.1	60.6	65.6	67.5	67.1	61.2	55.4	47.7	40.2
		MCDB	40.2	43.0	50.3	61.3	69.4	74.3	76.9	76.2	67.8	59.9	50.3	42.0
Mean Daily Temperature Range	5% DB	MDBR	10.9	12.6	15.9	19.4	19.4	18.7	19.3	19.6	17.6	16.4	12.4	10.6
		MCDBR	15.1	19.0	25.8	28.6	26.6	25.5	26.3	26.0	25.3	24.2	20.2	14.6
		MCWBR	11.7	13.3	15.7	14.8	13.1	11.9	11.1	11.4	13.4	14.9	14.3	11.3
	5% WB	MCDBR	14.4	17.6	23.3	25.7	24.4	23.5	23.5	23.6	22.4	22.3	18.1	13.8
		MCWBR	11.6	13.0	15.0	13.8	12.7	11.5	10.7	11.0	12.6	14.1	13.3	11.1
Clear-Sky Solar Irradiance	taub	0.320	0.347	0.393	0.449	0.442	0.444	0.461	0.453	0.418	0.380	0.350	0.315	
	taud	2.261	2.228	2.176	2.082	2.153	2.188	2.153	2.177	2.235	2.312	2.333	2.323	
	Ebn at Noon	221	245	253	251	259	259	252	247	243	231	209	207	
	Edh at Noon	23	30	38	47	46	44	45	42	36	28	22	19	
All-Sky Solar Radiation	RadAvg	269	505	860	1283	1558	1657	1592	1440	1022	614	304	209	
	RadStd	46	82	127	156	193	162	194	122	149	88	41	27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (39 neighbors)	+0.99	N/A	N/A	+1.58	+0.81	+0.68	-230	-322	+144	+59

Nomenclature: See separate page