

RZESZOW JASIONKA, Poland

WMO: 125800

Lat: 50.110N

Lon: 22.019E

Elev: 206

StdP: 98.88

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-12.8	-18.8	0.7	-15.9	-15.3	1.0	-12.4	12.5	1.8	11.5	1.6	2.5	90	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	30.4	20.8	28.7	20.0	27.0	19.2	21.9	28.3	20.9	27.0	20.0	25.3	3.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.9	24.9	18.9	14.0	23.6	18.1	13.3	22.3	64.9	28.4	61.3	27.0	58.2	25.3	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.0	8.0	-20.1	32.9	4.0	1.5	-23.0	34.0	-25.4	34.9	-27.6	35.7	-30.6	36.8		
(5)			-20.3	23.8	4.0	0.8	-23.2	24.4	-25.5	24.9	-27.8	25.4	-30.7	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-2.2	-0.7	3.3	9.1	14.0	17.5	19.4	18.8	14.0	9.0	4.3	-0.5
	DBStd	8.74	5.51	5.53	4.74	4.10	3.72	3.33	3.11	3.17	3.56	4.31	4.68	5.09
	HDD10.0	1546	378	300	213	63	8	0	0	0	7	73	177	327
	HDD18.3	3599	636	533	467	277	141	56	25	32	136	290	421	585
	CDD10.0	1136	0	0	3	36	132	224	292	274	127	41	7	0
	CDD18.3	149	0	0	0	1	6	29	59	48	6	0	0	0
	CDH23.3	1563	0	0	0	12	102	303	596	477	72	1	0	0
	CDH26.7	425	0	0	0	1	15	71	184	143	11	0	0	0
(14) Wind	WSAvg	3.6	4.4	4.2	4.2	3.5	3.1	3.0	2.9	2.7	3.0	3.5	4.0	4.4
(15) Precipitation	PrecAvg	689	35	34	40	50	82	87	100	68	70	51	39	33
	PrecMax	1002	83	71	83	100	192	148	240	121	159	102	85	67
	PrecMin	505	11	12	15	6	37	16	17	15	12	6	0	9
	PrecStd	102	16	15	20	22	33	35	57	32	40	30	20	15
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	12.6	18.0	25.1	28.7	30.8	32.8	33.0	28.0	22.6	17.0	11.1
		MCWB	7.2	8.1	10.4	15.4	18.2	21.6	21.5	21.6	18.1	16.0	11.8	8.1
	2%	DB	7.4	10.0	15.0	22.0	26.0	28.9	30.8	30.1	25.4	20.1	14.6	8.9
		MCWB	5.6	7.1	9.0	13.4	17.6	20.5	21.1	20.6	17.8	15.0	10.9	7.1
	5%	DB	6.0	8.1	12.7	19.4	24.0	26.8	28.8	28.1	23.2	18.1	12.9	7.1
		MCWB	4.4	5.7	8.0	12.3	16.8	19.4	20.1	19.9	16.8	14.0	10.1	5.5
	10%	DB	4.6	6.3	10.4	17.1	21.9	24.9	26.8	26.0	21.0	15.9	11.0	5.4
		MCWB	3.2	4.6	7.0	11.1	15.7	18.2	19.4	18.9	15.8	12.7	9.0	4.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	8.8	11.2	15.6	20.0	22.7	23.3	23.0	19.7	16.9	12.6	8.8
		MCDB	9.0	11.1	16.1	23.6	26.5	29.1	29.9	29.8	25.8	21.0	15.5	10.9
	2%	WB	5.8	7.2	9.7	14.2	18.4	21.3	22.0	21.6	18.4	15.5	11.4	7.1
		MCDB	7.1	9.7	13.9	20.3	24.2	27.1	28.5	28.0	23.5	19.3	14.1	8.7
	5%	WB	4.5	5.9	8.4	13.0	17.2	20.0	21.0	20.6	17.4	14.3	10.3	5.6
		MCDB	5.7	7.7	11.9	18.2	22.7	25.2	27.1	26.5	22.0	17.6	12.3	6.8
	10%	WB	3.2	4.7	7.1	11.7	16.1	18.9	20.0	19.6	16.3	13.0	9.1	4.2
		MCDB	4.4	6.2	10.1	16.3	21.1	23.6	25.2	24.6	20.3	15.5	10.9	5.3
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	6.3	8.1	10.9	11.2	11.0	11.3	11.5	10.1	8.5	5.9	4.8
		MCDBR	5.6	8.5	12.4	15.4	14.8	14.3	14.9	14.6	14.0	12.1	8.7	6.3
	5% WB	MCWBR	4.3	5.9	7.4	8.1	7.5	7.0	6.3	6.3	7.2	7.2	5.6	4.9
		MCWBR	5.4	8.0	11.1	13.9	13.7	12.8	13.2	13.2	12.2	11.1	7.5	6.1
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.343	0.386	0.440	0.429	0.430	0.451	0.445	0.410	0.374	0.350	0.314
		taud	2.255	2.221	2.199	2.105	2.197	2.226	2.181	2.196	2.251	2.327	2.321	2.312
	Edn at Noon	Edn at Noon	697	776	807	800	830	831	805	788	774	735	656	650
		Edh at Noon	72	96	118	144	137	135	139	131	111	87	69	60
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.85	1.61	2.76	4.08	5.03	5.38	5.15	4.70	3.28	1.99	0.96	0.65
	RadStd	RadStd	0.14	0.26	0.35	0.46	0.59	0.43	0.56	0.37	0.48	0.29	0.11	0.09

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	+0.64	N/A	N/A	+0.91	N/A	N/A	-158	-222	+111	+53
		+0.55	N/A	N/A	+0.91	+0.50	+0.43	-122	-173	+81	+33

Nomenclature: See separate page