

SANDOMIERZ, PolandWMO: **125850**Lat: **50.6967N**Lon: **21.7158E**Elev: **718**StdP: **14.32**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.5	10.0	0.0	5.6	5.8	5.2	7.4	11.0	22.8	39.4	19.9	35.6	5.6	30	0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	85.4	68.9	82.1	67.5	79.2	65.9	71.0	81.9	69.2	79.1	67.6	76.5	6.5	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	102.9	76.2	65.7	97.3	73.9	64.3	92.8	72.2	35.2	82.4	33.7	79.2	32.4	76.7	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.4	16.0	14.1	DB	-0.3	90.5	7.3	2.5	-5.5	92.3	-9.8	93.8	-13.8	95.2	-19.1	97.0
(5)				WB	-0.8	73.7	7.1	1.4	-6.0	74.7	-10.1	75.5	-14.1	76.3	-19.3	77.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.0	27.8	30.6	37.9	49.1	57.8	63.6	67.3	66.1	57.3	48.0	39.2	30.7	
	DBStd	15.84	9.42	9.27	8.26	7.87	6.92	6.25	5.77	5.52	6.37	7.64	7.95	8.72	
	HDD50	2811	690	542	380	108	13	0	0	0	12	133	333	600	
	HDD65	6479	1155	962	839	480	240	100	43	53	239	528	775	1065	
	CDD50	2091	0	0	5	79	255	408	535	500	232	70	7	0	
	CDD65	285	0	0	0	1	16	58	113	87	10	0	0	0	
	CDH74	2240	0	0	0	23	156	436	902	649	74	0	0	0	
	CDH80	522	0	0	0	2	18	89	248	159	6	0	0	0	
Wind	WSAvg	7.2	8.0	8.1	8.5	7.7	7.0	6.6	6.4	5.8	6.2	6.8	7.3	7.9	
Precipitation	PrecAvg	23.0	1.1	0.9	1.3	1.7	2.7	2.7	3.7	2.4	2.4	1.7	1.3	1.0	
	PrecMax	31.1	2.2	2.2	2.8	3.7	6.8	6.2	13.4	4.7	4.6	4.5	3.1	2.2	
	PrecMin	16.5	0.2	0.4	0.4	0.2	1.3	1.5	0.4	0.2	0.3	0.2	0.0	0.4	
	PrecStd	3.3	0.5	0.4	0.7	0.9	1.3	1.2	2.6	1.1	1.3	1.1	0.6	0.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	53.8	63.9	76.9	82.6	86.9	90.0	88.9	80.5	70.7	60.3	50.3	
		MCWB	44.2	46.8	51.1	59.9	64.1	70.2	69.9	70.3	65.1	61.0	53.6	46.4	
	2%	DB	44.6	48.7	58.3	71.3	78.6	82.7	86.1	84.3	75.9	66.8	55.9	46.6	
		MCWB	41.6	44.0	48.3	56.3	62.8	68.3	68.9	68.9	63.7	58.8	51.0	44.0	
	5%	DB	41.6	45.5	53.9	66.5	74.9	79.0	82.3	80.7	72.3	63.1	52.9	43.5	
		MCWB	39.3	42.0	46.0	53.8	61.7	66.0	67.9	67.3	61.7	56.9	49.3	41.4	
	10%	DB	39.0	42.3	49.9	62.5	71.0	75.9	79.0	77.3	68.7	59.4	50.1	41.1	
		MCWB	37.1	39.6	44.1	51.8	59.7	64.2	66.4	65.3	60.1	54.8	47.5	39.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.0	47.7	52.3	60.6	67.4	72.0	73.0	73.1	67.6	62.4	54.4	47.8
			MCDB	47.6	52.0	61.1	74.9	77.9	83.2	84.6	84.7	76.9	68.6	59.0	50.2
2%		WB	42.0	44.7	49.4	57.7	64.6	69.8	71.1	70.5	64.8	59.8	51.9	44.1	
		MCDB	44.2	48.2	56.9	68.9	74.6	79.9	82.1	81.2	73.8	65.3	55.1	46.3	
5%		WB	39.5	42.2	46.9	55.0	62.7	67.6	69.4	68.5	62.8	57.5	49.7	41.8	
		MCDB	41.4	45.0	52.6	64.1	72.6	76.8	79.3	78.3	70.3	62.2	52.5	43.4	
10%		WB	37.3	39.6	44.5	52.9	60.7	65.5	67.9	66.7	61.0	55.1	47.5	39.3	
		MCDB	38.9	42.0	49.0	60.8	69.8	73.3	76.4	74.6	67.1	58.9	49.9	40.9	
Mean Daily Temperature Range	5% DB	MDBR	8.4	10.4	13.0	16.4	17.3	16.8	17.2	17.7	15.7	13.6	9.4	8.1	
		MCDBR	9.6	14.6	20.7	23.3	22.7	21.8	22.4	22.6	21.5	19.0	13.8	10.1	
		MCWBR	7.8	10.2	12.4	11.3	10.8	10.1	8.8	9.7	10.6	11.5	9.5	8.2	
	5% WB	MCDBR	9.2	13.7	19.0	21.3	20.6	19.7	19.9	20.9	19.4	18.0	12.7	9.7	
		MCWBR	7.7	10.1	12.1	11.1	10.6	10.1	9.0	9.8	10.2	11.4	9.2	8.1	
Clear-Sky Solar Irradiance	taub	0.317	0.342	0.382	0.436	0.424	0.423	0.446	0.440	0.407	0.370	0.350	0.314		
	taud	2.252	2.237	2.211	2.115	2.211	2.245	2.192	2.209	2.261	2.336	2.319	2.309		
	Ebn at Noon	219	245	256	254	264	265	256	251	246	233	205	202		
	Edh at Noon	23	30	36	45	43	42	43	41	35	27	22	19		
All-Sky Solar Radiation	RadAvg	256	495	866	1299	1615	1730	1632	1469	1039	615	285	193		
	RadStd	46	85	112	153	180	140	188	108	152	88	31	29		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		+0.99	N/A	N/A	+1.67	N/A	N/A	N/A	N/A	+184	+95
Regional (26 neighbors)		+0.95	N/A	N/A	+1.53	+0.79	+0.74	N/A	-301	+149	+65