

ZAMOSC, Poland

WMO: 125950

Lat: 50.6979N

Lon: 23.2063E

Elev: 699

StdP: 14.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.5	6.8	-4.6	4.4	-0.1	1.9	6.2	7.5	25.7	37.1	24.5	36.9	4.7	100	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	85.7	68.9	82.4	67.7	79.1	66.3	70.7	81.9	69.1	79.6	67.6	76.9	7.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	101.5	75.8	65.4	96.3	73.8	64.0	91.7	72.1	35.0	82.4	33.6	79.8	32.4	77.0	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.5	19.6	17.2	-4.3	90.6	6.3	2.6	-8.8	92.5	-12.5	94.0	-16.0	95.4	-20.6	97.3		
			-4.6	73.4	5.9	1.5	-8.9	74.5	-12.3	75.4	-15.7	76.3	-19.9	77.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.0	26.3	30.4	36.2	47.7	56.1	62.4	65.7	64.7	56.5	47.7	37.8	31.5
	DBStd	15.78	10.17	10.75	8.72	7.84	7.17	6.19	5.50	5.74	6.59	8.12	8.77	8.72
	HDD50	2981	735	549	430	132	26	0	0	18	142	375	574	
	HDD65	6778	1200	969	891	518	284	125	61	76	264	535	816	1039
	CDD50	1888	0	0	3	64	216	371	487	455	211	72	9	0
	CDD65	214	0	0	0	0	10	46	83	67	8	0	0	0
	CDH74	2254	0	0	0	15	147	474	786	725	105	2	0	0
	CDH80	567	0	0	0	0	14	106	205	233	9	0	0	0
	WSAvg	7.5	9.2	8.6	9.0	7.3	6.2	6.0	6.1	5.8	6.5	7.6	8.2	9.8
	PrecAvg	27.6	1.4	1.2	1.7	2.3	3.2	3.1	4.1	3.1	3.0	2.1	1.8	1.2
Precipitation	PrecMax	50.5	4.9	2.1	3.7	7.1	8.4	6.0	7.8	13.5	7.8	4.9	7.0	2.5
	PrecMin	17.8	0.1	0.2	0.2	0.5	1.3	1.0	0.7	0.2	0.4	0.2	0.0	0.4
	PrecStd	8.9	0.9	0.5	0.9	1.4	1.7	1.2	2.1	2.7	1.8	1.3	1.3	0.4
	PrecStd	8.9	0.9	0.5	0.9	1.4	1.7	1.2	2.1	2.7	1.8	1.3	1.3	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	47.9	54.0	63.3	76.2	82.2	86.9	89.7	90.5	81.3	72.9	62.1	49.9	
	0.4% MCWB	43.0	46.7	51.3	60.8	65.1	70.6	70.0	69.3	64.5	61.0	54.1	46.5	
	2% DB	44.2	49.7	57.1	70.9	78.0	83.2	85.0	86.1	76.9	68.3	57.0	47.0	
	2% MCWB	41.0	43.9	47.8	57.3	64.0	69.0	69.0	68.3	63.6	58.8	51.2	44.1	
	5% DB	41.4	46.5	52.6	66.3	74.7	79.2	81.5	82.1	73.2	64.4	53.4	44.3	
	5% MCWB	38.8	42.4	45.4	55.1	62.4	67.3	68.1	67.4	61.9	57.2	49.1	41.6	
	10% DB	38.6	43.0	48.5	62.0	71.0	75.9	78.2	77.5	69.0	60.1	50.1	41.7	
	10% MCWB	36.6	40.0	43.5	52.4	60.8	65.4	66.7	65.3	59.8	54.7	47.3	39.6	
	0.4% WB	44.0	47.5	52.0	62.2	67.9	72.7	72.7	72.5	67.4	62.5	54.7	47.2	
	0.4% MCDB	47.2	51.9	61.4	73.7	79.0	83.8	84.4	85.6	76.3	69.9	59.9	49.5	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	41.2	45.3	49.0	58.7	65.5	70.2	70.7	70.0	64.8	60.0	52.3	44.3	
	2% MCDB	43.9	49.2	55.8	68.8	75.2	80.8	81.8	82.1	74.2	66.7	56.5	46.6	
	5% WB	39.1	42.5	46.3	55.9	63.5	68.3	69.1	68.2	62.8	57.7	49.8	41.9	
	5% MCDB	41.2	45.8	51.4	64.7	73.0	77.6	79.4	78.6	71.0	63.4	53.0	43.9	
	10% WB	36.8	40.2	44.0	53.3	61.2	66.3	67.5	66.5	60.9	55.2	47.3	39.8	
	10% MCDB	38.5	42.9	48.2	60.6	69.5	74.2	76.4	75.6	67.8	60.1	49.9	41.6	
Mean Daily Temperature Range	MDBR	8.8	10.8	13.5	18.7	19.9	20.0	19.5	20.3	18.1	14.7	9.5	8.0	
	5% DB	9.2	14.4	21.2	26.2	26.2	25.2	25.6	27.4	25.3	21.6	15.9	10.3	
	5% WB	7.5	10.0	13.4	14.6	13.9	12.8	11.6	11.8	13.2	12.9	10.9	8.3	
	MCDBR	9.2	13.4	18.9	24.0	23.9	22.6	22.5	23.6	22.0	20.0	13.8	10.0	
	MCWBR	7.7	10.0	12.7	14.0	13.5	12.2	11.0	11.0	12.2	12.5	9.8	8.4	
	MCWBR	7.7	10.0	12.7	14.0	13.5	12.2	11.0	11.0	12.2	12.5	9.8	8.4	
Clear-Sky Solar Irradiance	taub	0.314	0.340	0.379	0.431	0.420	0.419	0.444	0.439	0.403	0.367	0.349	0.311	
	taud	2.242	2.215	2.211	2.130	2.221	2.253	2.196	2.206	2.267	2.344	2.310	2.295	
	Ebn at Noon	220	245	257	256	266	266	257	251	247	234	205	203	
	Edh at Noon	23	30	36	44	43	42	43	41	35	27	22	19	
All-Sky Solar Radiation	RadAvg	261	502	880	1309	1633	1748	1662	1500	1037	622	283	191	
	RadStd	44	76	113	144	176	131	164	112	153	96	31	29	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (19 neighbors)		+0.99	N/A	N/A	+1.58	+0.86	+0.77	N/A	-313	+158	+68

Nomenclature: See separate page