

ZAMOSC, Poland

WMO: 125950

Lat: 50.6979N

Lon: 23.2063E

Elev: 213

StdP: 98.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-14.0	-20.4	0.6	-17.9	-16.7	0.9	-13.6	11.5	2.8	10.9	2.7	2.1	100	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	29.8	20.5	28.0	19.8	26.2	19.1	21.5	27.7	20.6	26.5	19.8	24.9	3.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.5	24.3	18.6	13.8	23.2	17.8	13.1	22.3	63.6	28.0	60.3	26.6	57.4	25.0	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.1	8.8	7.7	-20.1	32.6	3.5	1.4	-22.7	33.6	-24.7	34.4	-26.7	35.2	-29.2	36.3		
(5)			-20.4	23.0	3.3	0.9	-22.7	23.6	-24.6	24.1	-26.5	24.6	-28.9	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	-3.2	-0.9	2.4	8.7	13.4	16.9	18.7	18.2	13.6	8.7	3.2	-0.3		
	DBStd	8.77	5.65	5.97	4.85	4.36	3.98	3.44	3.06	3.19	3.66	4.51	4.87	4.85		
	HDD10.0	1656	408	305	239	73	14	0	0	0	10	79	208	319		
	HDD18.3	3766	667	538	495	288	158	69	34	42	147	297	453	577		
	CDD10.0	1049	0	0	2	36	120	206	271	253	117	40	5	0		
	CDD18.3	119	0	0	0	0	6	26	46	37	4	0	0	0		
	CDH23.3	1252	0	0	0	8	82	263	437	403	58	1	0	0		
	CDH26.7	315	0	0	0	0	8	59	114	129	5	0	0	0		
(14) Wind	WSAvg	3.4	4.1	3.9	4.0	3.3	2.8	2.7	2.7	2.6	2.9	3.4	3.7	4.4		
(15) Precipitation	PrecAvg	701	35	30	42	59	82	78	103	80	77	53	45	31		
	PrecMax	1282	125	53	93	180	214	153	199	344	198	124	179	64		
	PrecMin	452	2	4	5	13	33	26	19	6	9	5	1	9		
	PrecStd	225	24	12	23	36	44	31	54	69	45	34	34	11		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.8	12.2	17.4	24.6	27.9	30.5	32.0	32.5	27.4	22.7	16.7	9.9		
		MCWB	6.1	8.2	10.7	16.0	18.4	21.5	21.1	20.7	18.1	16.1	12.3	8.1		
	2%	DB	6.8	9.9	14.0	21.6	25.6	28.5	29.4	30.1	25.0	20.2	13.9	8.3		
		MCWB	5.0	6.6	8.8	14.1	17.8	20.5	20.5	20.2	17.6	14.9	10.7	6.7		
	5%	DB	5.2	8.0	11.5	19.1	23.7	26.2	27.5	27.8	22.9	18.0	11.9	6.8		
		MCWB	3.8	5.8	7.5	12.9	16.9	19.6	20.0	19.7	16.6	14.0	9.5	5.3		
	10%	DB	3.6	6.1	9.1	16.7	21.7	24.4	25.7	25.3	20.5	15.6	10.0	5.4		
		MCWB	2.6	4.5	6.4	11.3	16.0	18.6	19.3	18.5	15.5	12.6	8.5	4.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	8.6	11.1	16.8	19.9	22.6	22.6	22.5	19.7	17.0	12.6	8.5		
		MCDB	8.4	11.0	16.3	23.1	26.1	28.8	29.1	29.8	24.6	21.0	15.5	9.7		
	2%	WB	5.1	7.4	9.4	14.8	18.6	21.2	21.5	21.1	18.2	15.6	11.3	6.8		
		MCDB	6.6	9.6	13.2	20.4	24.0	27.1	27.6	27.9	23.5	19.3	13.6	8.1		
	5%	WB	3.9	5.8	8.0	13.3	17.5	20.2	20.6	20.1	17.1	14.3	9.9	5.5		
		MCDB	5.1	7.7	10.8	18.2	22.8	25.3	26.3	25.9	21.6	17.5	11.7	6.6		
	10%	WB	2.7	4.6	6.7	11.8	16.2	19.1	19.7	19.2	16.1	12.9	8.5	4.3		
		MCDB	3.6	6.1	9.0	15.9	20.8	23.4	24.7	24.2	19.9	15.6	9.9	5.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.0	7.5	10.4	11.1	11.1	10.8	11.3	10.0	8.2	5.3	4.4		
		MCDBR	5.1	8.0	11.8	14.5	14.6	14.0	14.2	15.2	14.0	12.0	8.8	5.7		
		MCWBR	4.2	5.6	7.4	8.1	7.7	7.1	6.4	6.6	7.3	7.2	6.1	4.6		
	5% WB	MCDBR	5.1	7.4	10.5	13.3	13.3	12.5	12.5	13.1	12.2	11.1	7.6	5.5		
		MCWBR	4.3	5.6	7.1	7.8	7.5	6.8	6.1	6.1	6.8	6.9	5.5	4.7		
(40) Clear-Sky Solar Irradiance	taub		0.314	0.340	0.379	0.431	0.420	0.419	0.444	0.439	0.403	0.367	0.349	0.311		
	taud		2.242	2.215	2.211	2.130	2.221	2.253	2.196	2.206	2.267	2.344	2.310	2.295		
	Ebn at Noon		692	773	810	807	837	840	809	791	778	739	646	639		
	Edh at Noon		71	95	115	140	134	131	136	129	109	84	68	59		
(44) All-Sky Solar Radiation	RadAvg		0.82	1.58	2.77	4.13	5.15	5.51	5.24	4.73	3.27	1.96	0.89	0.60		
	RadStd		0.14	0.24	0.36	0.45	0.56	0.41	0.52	0.35	0.48	0.30	0.10	0.09		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (19 neighbors)		+0.55	N/A	N/A	+0.88	+0.48	+0.43	N/A	-174	+88	+38	

Nomenclature: See separate page