

NOWY SACZ, Poland

WMO: 126600

Lat: 49.6271N

Lon: 20.6886E

Elev: 971

StdP: 14.19

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.8	10.3	0.3	5.8	5.0	6.0	7.7	11.8	20.1	38.3	17.8	38.3	1.9	110	0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	86.8	69.0	83.4	67.6	80.4	66.0	71.1	82.5	69.3	80.3	67.7	77.5	5.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.3	104.1	76.2	65.6	98.1	74.0	64.1	92.9	72.0	35.4	82.7	34.0	80.7	32.6	77.6	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.8	13.1	11.0	-2.1	92.3	7.9	2.7	-7.8	94.2	-12.4	95.8	-16.8	97.3	-22.5	99.3		
			-2.5	75.2	7.8	3.3	-8.1	77.6	-12.7	79.5	-17.1	81.3	-22.8	83.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.8	29.6	32.0	39.3	49.6	57.4	63.6	66.8	66.1	57.9	49.6	40.9	32.2	(6)
	DBStd	15.19	9.83	9.88	8.31	6.99	6.57	6.21	5.58	5.60	6.06	7.54	8.46	8.65	(7)
	HDD50	2534	634	504	341	89	14	0	0	0	8	104	289	551	(8)
	HDD65	6174	1099	923	798	464	247	100	48	54	223	480	722	1016	(9)
	CDD50	2106	0	1	7	76	242	408	519	499	246	90	17	1	(10)
	CDD65	269	0	0	0	1	10	57	102	88	10	1	0	0	(11)
	CDH74	2730	0	0	0	38	221	582	945	810	125	9	0	0	(12)
	CDH80	748	0	0	0	4	34	160	287	245	18	0	0	0	(13)
(14) Wind	WSAvg	3.9	4.4	4.6	5.1	4.2	3.7	3.5	3.3	2.9	3.0	3.7	4.1	4.3	(14)
(15) Precipitation	PrecAvg	32.3	1.6	1.5	1.9	2.3	3.9	4.4	5.0	3.5	3.0	2.2	1.7	1.4	(15)
	PrecMax	48.1	3.7	3.2	4.4	4.9	11.5	9.0	10.9	6.5	6.5	5.3	3.4	3.1	(16)
	PrecMin	24.7	0.5	0.5	0.4	0.4	1.7	1.1	1.1	0.6	0.6	0.2	0.0	0.3	(17)
	PrecStd	5.0	0.8	0.7	0.9	1.1	2.0	2.0	2.8	1.7	1.6	1.3	0.9	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.7	58.1	65.8	78.9	83.8	89.2	91.1	91.4	82.7	74.7	64.6	55.3	(19)
		MCWB	45.5	47.7	50.7	59.9	63.4	69.9	69.9	70.1	65.7	60.4	55.0	48.0	(20)
	2%	DB	48.0	52.0	60.8	72.5	79.8	84.8	86.8	85.9	77.6	70.6	60.3	50.8	(21)
		MCWB	42.7	44.8	48.9	56.5	62.5	68.3	69.0	69.3	63.9	59.3	52.3	44.9	(22)
	5%	DB	44.6	48.7	56.9	67.8	76.1	80.5	83.0	82.4	73.9	66.4	57.1	47.5	(23)
		MCWB	40.4	42.8	46.9	54.0	61.6	66.4	68.0	67.9	62.0	57.3	50.0	42.6	(24)
	10%	DB	41.8	45.1	52.9	63.6	71.8	76.8	79.5	78.5	70.3	62.1	53.7	43.6	(25)
		MCWB	38.2	40.6	45.0	52.2	59.8	64.2	66.3	66.3	60.5	55.3	48.2	40.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	48.5	52.2	61.2	66.9	72.5	73.6	73.9	67.4	62.9	55.7	48.4	(27)
		MCDB	51.0	55.0	62.1	74.9	78.9	84.1	84.8	86.0	78.2	71.6	63.8	54.2	(28)
	2%	WB	43.3	45.7	50.0	57.9	64.4	70.0	70.9	70.9	65.0	60.1	53.1	45.6	(29)
		MCDB	47.2	51.0	59.5	70.1	74.7	81.5	82.0	82.3	74.9	68.4	59.4	50.3	(30)
	5%	WB	40.8	43.2	47.7	55.3	62.4	67.5	69.2	69.0	63.2	57.9	50.6	42.9	(31)
		MCDB	44.2	48.1	55.5	65.4	73.9	77.7	80.1	79.6	72.0	65.4	56.2	46.9	(32)
	10%	WB	38.4	40.7	45.4	53.1	60.5	65.6	67.7	67.3	61.4	55.8	48.4	40.3	(33)
		MCDB	41.3	44.9	52.2	61.7	70.3	74.3	77.2	76.4	68.6	61.6	53.1	43.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	13.5	15.9	19.8	20.3	19.0	19.4	20.1	18.6	16.8	12.8	11.0	(35)
		MCDBR	12.7	19.3	24.5	28.7	29.3	26.4	26.7	26.8	26.1	24.7	18.1	14.4	(36)
	5% WB	MCWBR	9.1	12.6	14.3	14.4	14.2	12.0	11.3	12.1	13.4	14.2	11.1	9.9	(37)
		MCWBR	12.1	17.5	22.8	25.6	25.6	23.4	22.9	24.4	23.0	22.3	16.8	13.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.308	0.334	0.380	0.437	0.432	0.435	0.450	0.445	0.409	0.371	0.340	0.305	(40)
		taud	2.289	2.238	2.205	2.118	2.189	2.219	2.185	2.204	2.263	2.346	2.366	2.352	(41)
	Ebn at Noon		230	252	259	255	263	263	256	251	247	236	217	215	(42)
		Edh at Noon	23	30	37	45	44	43	44	41	35	27	21	19	(43)
(44) All-Sky Solar Radiation	RadAvg		284	525	885	1274	1548	1643	1590	1470	1035	632	318	216	(44)
	RadStd		41	75	112	147	200	148	187	118	149	92	41	25	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+1.03	N/A	N/A	+1.75	+0.94	+0.81	-230	-333	+153	+67

Nomenclature: See separate page