

KROSNO, Poland

WMO: 126700

Lat: 49.7069N

Lon: 21.7692E

Elev: 331

StdP: 97.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.1	-12.0	-18.0	0.8	-14.0	-15.1	1.0	-11.0	11.3	1.5	9.9	0.7	2.3	100	0.538

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	29.0	20.3	27.3	19.4	25.7	18.6	21.2	27.1	20.2	25.8	19.4	24.4	3.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	14.4	24.0	18.3	13.7	22.8	17.5	13.1	21.8	62.8	27.2	59.5	25.9	56.7	24.5	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.1	7.9	7.0		-18.5	31.3	4.7	1.3	-21.9	32.2	-24.6	33.0	-27.3	33.8	-30.7	34.7	
(5)			DB	-19.1	22.6	4.4	0.8	-22.3	23.2	-24.9	23.6	-27.3	24.0	-30.5	24.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	-2.6	-1.1	3.2	9.4	13.7	17.1	18.9	18.8	13.8	9.4	4.9	-0.5
	DBStd	8.66	5.06	5.13	4.81	4.22	3.83	3.51	3.20	3.18	3.73	4.41	4.62	4.82
	HDD10.0	1544	389	311	213	58	11	1	0	0	8	66	160	327
	HDD18.3	3611	647	544	469	268	149	64	33	33	142	276	402	585
	CDD10.0	1112	0	0	3	42	126	214	277	271	123	49	8	0
	CDD18.3	137	0	0	0	1	6	27	52	46	6	1	0	0
	CDH23.3	1022	0	0	0	7	58	202	379	341	35	1	0	0
	CDH26.7	211	0	0	0	0	3	37	83	84	3	0	0	0
Wind	WSAvg	3.3	3.8	3.7	3.8	3.4	3.1	2.9	2.7	2.6	2.7	3.2	3.7	3.8
Precipitation	PrecAvg	846	50	45	48	59	99	102	129	83	75	58	52	44
	PrecMax	1192	114	99	85	99	268	164	239	158	189	135	118	89
	PrecMin	616	20	15	21	24	48	33	37	22	23	6	2	14
	PrecStd	129	22	19	19	22	49	43	59	39	44	36	28	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	11.0	16.7	24.4	27.0	29.7	31.0	31.4	26.2	21.8	16.2	10.6
		MCWB	6.5	7.2	9.6	14.7	17.2	20.8	20.8	20.5	18.0	14.7	11.7	7.7
	2%	DB	6.7	8.4	14.1	21.3	25.1	27.6	28.9	28.9	24.3	19.7	14.3	9.1
		MCWB	5.1	5.4	8.4	13.0	16.8	19.8	20.5	20.0	17.5	14.6	10.5	6.8
	5%	DB	5.2	6.7	12.0	18.8	23.1	25.7	27.1	26.8	22.2	17.7	12.8	7.1
		MCWB	3.8	4.6	7.5	11.8	16.2	18.8	19.6	19.5	16.4	13.8	9.7	5.2
	10%	DB	3.8	5.2	10.1	16.7	20.9	23.8	25.4	24.9	20.3	15.9	11.3	5.3
		MCWB	2.6	3.6	6.5	10.8	15.0	17.8	18.9	18.6	15.4	12.7	8.9	4.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	7.6	10.6	15.4	19.2	21.9	22.6	22.2	19.1	16.3	12.4	8.2
		MCDB	7.9	10.5	14.6	22.6	25.0	28.1	28.8	28.6	24.6	19.6	14.9	10.1
	2%	WB	5.5	5.9	9.2	13.7	17.6	20.5	21.2	20.9	17.9	15.1	11.1	7.0
		MCDB	6.5	7.7	12.9	19.9	23.3	26.3	27.0	27.0	23.0	18.6	13.6	9.0
	5%	WB	4.0	4.8	8.0	12.5	16.5	19.4	20.4	20.0	16.9	14.0	10.1	5.6
		MCDB	5.0	6.3	11.5	17.7	21.8	24.4	25.7	25.7	21.2	17.4	12.3	6.9
	10%	WB	2.7	3.8	6.8	11.4	15.5	18.3	19.4	19.1	15.9	12.9	9.0	4.2
		MCDB	3.6	5.0	9.7	15.8	20.3	22.7	24.1	24.0	19.6	15.7	11.1	5.2
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.9	7.0	9.1	9.3	9.1	9.4	9.5	8.1	6.8	4.8	3.8
		MCDBR	4.3	6.6	10.3	12.6	12.7	11.9	12.2	12.2	11.3	9.1	6.4	4.9
		MCWBR	3.4	4.6	6.1	6.3	6.2	5.6	5.0	5.1	5.5	5.1	3.9	3.5
	5% WB	MCDBR	4.2	6.0	9.3	11.6	11.6	10.8	10.9	11.1	9.9	8.6	5.8	4.6
		MCWBR	3.5	4.4	5.9	6.1	6.0	5.5	5.0	5.0	5.1	4.9	3.9	3.6
Clear-Sky Solar Irradiance	taub	0.310	0.335	0.378	0.432	0.421	0.424	0.443	0.437	0.402	0.368	0.343	0.307	
	taud	2.266	2.229	2.218	2.130	2.214	2.239	2.199	2.217	2.274	2.348	2.344	2.323	
	Ebn at Noon	718	791	819	810	838	837	813	798	785	748	675	670	
	Edh at Noon	72	96	116	141	135	133	137	128	109	85	68	60	
All-Sky Solar Radiation	RadAvg	0.89	1.64	2.77	4.03	4.92	5.25	5.07	4.67	3.28	2.00	1.00	0.67	
	RadStd	0.13	0.25	0.35	0.46	0.62	0.45	0.57	0.38	0.48	0.29	0.12	0.08	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.56	N/A	N/A	N/A	+0.98	+0.50	+0.44	-126	-175	+82	+34

Nomenclature: See separate page