

LESKO, Poland

WMO: 126900

Lat: 49.4664N

Lon: 22.3417E

Elev: 1386

StdP: 13.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.6	9.8	-1.2	5.4	5.9	4.3	7.2	12.2	23.3	35.4	20.5	33.7	3.5	150	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	83.6	68.2	80.5	66.6	77.7	65.1	69.7	80.0	68.1	77.7	66.5	75.2	5.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	102.1	74.4	64.8	96.5	72.0	63.4	91.8	70.3	34.5	80.0	33.2	77.7	31.9	75.5	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.0	15.2	13.2	-3.2	87.8	7.2	2.4	-8.3	89.5	-12.5	90.9	-16.5	92.2	-21.7	94.0		
			-3.9	72.4	6.9	1.5	-8.8	73.5	-12.9	74.4	-16.7	75.3	-21.7	76.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	27.5	30.2	36.7	47.8	55.3	61.4	64.7	64.3	55.8	48.2	40.7	31.0
	DBStd	15.11	9.31	9.46	8.69	7.28	6.72	6.13	5.68	5.55	6.68	8.00	8.57	9.08
	HDD50	2857	697	553	415	124	26	2	0	0	20	135	297	588
	HDD65	6723	1162	973	876	518	305	140	79	80	285	522	730	1053
	CDD50	1784	0	0	4	57	191	344	455	445	193	78	16	1
	CDD65	175	0	0	0	1	5	32	69	60	8	0	0	0
	CDH74	1573	0	0	0	12	84	302	575	539	60	1	0	0
	CDH80	310	0	0	0	0	5	48	120	130	7	0	0	0
Wind	WSAvg	5.6	6.3	6.5	6.8	6.0	5.1	4.8	4.6	4.4	4.7	5.7	6.3	6.5
Precipitation	PrecAvg	38.8	2.1	2.2	2.2	2.8	4.6	4.2	5.5	3.7	3.9	3.0	2.6	2.1
	PrecMax	50.7	6.1	4.1	5.0	5.8	9.6	9.0	11.2	8.1	8.7	6.3	5.0	3.8
	PrecMin	30.2	0.6	1.2	0.6	1.0	2.4	1.7	0.6	0.6	1.1	0.3	0.0	0.4
	PrecStd	5.0	1.2	0.8	1.1	1.1	1.9	1.6	2.6	1.8	2.0	1.7	1.3	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	53.0	62.0	75.6	80.5	84.6	86.9	88.0	79.2	71.4	63.1	53.9
		MCWB	43.9	44.7	48.6	57.6	62.3	68.7	69.6	68.6	65.2	58.5	53.0	46.3
	2%	DB	45.6	49.0	57.1	70.1	76.5	81.1	83.4	83.6	75.2	67.8	58.9	49.8
		MCWB	41.9	42.2	46.7	54.9	61.8	66.7	68.4	68.2	63.2	57.8	50.5	45.0
	5%	DB	42.6	45.3	53.3	65.6	72.9	77.6	80.2	79.9	71.6	64.2	56.2	46.0
		MCWB	39.4	40.7	44.8	52.5	60.3	64.9	67.1	67.0	61.5	56.4	49.5	41.8
	10%	DB	39.9	42.4	49.7	61.2	69.0	74.0	76.9	76.1	67.8	60.6	53.2	42.6
		MCWB	37.2	38.7	43.2	50.6	58.6	63.2	65.7	65.0	59.2	54.0	47.7	39.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.8	45.7	50.2	58.9	65.5	70.9	72.1	71.6	66.6	60.9	54.1	47.4
		MCDB	48.0	51.8	58.4	71.8	75.9	81.4	82.2	83.1	76.8	67.9	59.9	51.8
	2%	WB	42.5	43.1	47.9	56.0	63.2	68.0	70.0	69.3	64.1	58.7	52.1	45.1
		MCDB	45.2	47.5	55.0	67.5	73.2	77.8	80.0	79.7	73.1	65.5	57.6	49.8
	5%	WB	39.8	41.2	45.8	53.9	61.3	66.2	68.3	67.8	62.2	56.6	50.1	42.3
		MCDB	42.1	44.7	52.2	63.1	70.6	75.1	77.7	77.5	69.7	63.4	55.3	45.4
	10%	WB	37.3	39.1	43.6	51.8	59.3	64.5	66.6	66.2	60.3	54.6	48.1	40.0
		MCDB	39.8	42.0	48.8	59.3	67.7	72.2	74.6	74.7	66.5	60.0	52.7	42.5
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.9	13.5	17.9	18.3	17.6	17.8	18.5	15.8	13.9	10.3	8.2
		MCDBR	9.4	14.6	20.4	25.3	25.1	23.7	23.5	24.3	21.8	19.4	15.1	10.8
		MCWBR	7.0	9.4	11.7	12.5	12.3	11.0	10.4	10.6	11.1	10.7	8.7	7.4
	5% WB	MCDBR	9.1	12.4	18.1	22.3	22.8	20.4	21.0	21.5	19.7	18.0	12.9	10.1
		MCWBR	7.1	8.6	11.2	11.8	11.7	10.3	10.1	10.2	10.5	10.2	8.3	7.3
Clear-Sky Solar Irradiance	taub		0.312	0.339	0.384	0.441	0.428	0.429	0.450	0.445	0.407	0.372	0.347	0.310
	taud		2.236	2.191	2.173	2.091	2.188	2.218	2.170	2.184	2.248	2.318	2.312	2.295
	Ebn at Noon		227	249	257	254	264	264	256	251	248	236	213	211
	Edh at Noon		24	32	39	47	44	43	45	42	36	28	23	20
All-Sky Solar Radiation	RadAvg		283	515	870	1284	1569	1683	1640	1512	1050	649	325	214
	RadStd		43	83	108	141	199	139	168	137	156	96	41	30

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+1.03	N/A	N/A	+1.82	+0.92	+0.83	-229	-328	+157	+65

Nomenclature: See separate page