

LESKO, Poland

WMO: 126900

Lat: 49.4664N

Lon: 22.3417E

Elev: 422

StdP: 96.35

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.8	-12.4	-18.4	0.8	-14.5	-15.4	1.0	-11.0	10.4	1.9	9.2	0.9	1.6	150	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	28.6	20.1	27.0	19.2	25.4	18.4	21.0	26.7	20.1	25.4	19.2	24.0	2.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.1	14.6	23.6	18.2	13.8	22.2	17.4	13.1	21.3	62.4	26.7	59.3	25.4	56.3	24.2	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	6.8	5.9	DB	-19.5	31.0	4.0	1.3	-22.4	31.9	-24.7	32.7	-27.0	33.5	-29.9	34.4	(4)
(5)			WB	-19.9	22.5	3.8	0.9	-22.7	23.1	-24.9	23.6	-27.1	24.0	-29.9	24.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-2.5	-1.0	2.6	8.8	13.0	16.3	18.1	18.0	13.2	9.0	4.8	-0.5	(6)	
	DBStd	8.40	5.17	5.26	4.83	4.04	3.73	3.41	3.16	3.08	3.71	4.44	4.76	5.05	(7)	
	HDD10.0	1587	387	307	231	69	14	1	0	0	11	75	165	327	(8)	
	HDD18.3	3735	646	541	487	288	169	78	44	44	158	290	406	585	(9)	
	CDD10.0	991	0	0	2	32	106	191	253	247	107	43	9	1	(10)	
	CDD18.3	97	0	0	0	1	3	18	38	33	4	0	0	0	(11)	
	CDH23.3	874	0	0	0	7	47	168	319	299	33	1	0	0	(12)	
	CDH26.7	172	0	0	0	0	3	27	67	72	4	0	0	0	(13)	
(14) Wind	WSAvg	2.5	2.8	2.9	3.0	2.7	2.3	2.2	2.0	2.0	2.1	2.5	2.8	2.9	(14)	
(15) Precipitation	PrecAvg	986	54	55	57	72	116	107	140	93	98	76	65	53	(15)	
	PrecMax	1289	154	104	128	147	245	228	285	205	220	161	126	96	(16)	
	PrecMin	766	16	30	15	25	61	44	15	16	29	8	0	10	(17)	
	PrecStd	128	30	21	28	29	48	40	66	45	50	44	32	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	11.7	16.7	24.2	27.0	29.2	30.5	31.1	26.2	21.9	17.3	12.2	(19)	
		MCWB	6.6	7.1	9.2	14.2	16.8	20.4	20.9	20.3	18.4	14.7	11.7	8.0	(20)	
	2%	DB	7.6	9.4	13.9	21.2	24.7	27.3	28.6	28.7	24.0	19.9	15.0	9.9	(21)	
		MCWB	5.5	5.7	8.2	12.7	16.6	19.3	20.2	20.1	17.3	14.3	10.3	7.2	(22)	
	5%	DB	5.9	7.4	11.8	18.6	22.7	25.3	26.8	26.6	22.0	17.9	13.4	7.8	(23)	
		MCWB	4.1	4.8	7.1	11.4	15.7	18.3	19.5	19.4	16.4	13.6	9.7	5.5	(24)	
	10%	DB	4.4	5.8	9.8	16.2	20.6	23.3	24.9	24.5	19.9	15.9	11.8	5.9	(25)	
		MCWB	2.9	3.7	6.2	10.3	14.8	17.4	18.7	18.3	15.1	12.2	8.7	4.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	7.6	10.1	14.9	18.6	21.6	22.3	22.0	19.2	16.1	12.3	8.6	(27)	
		MCDB	8.9	11.0	14.7	22.1	24.4	27.4	27.9	28.4	24.9	20.0	15.5	11.0	(28)	
	2%	WB	5.8	6.2	8.8	13.3	17.3	20.0	21.1	20.7	17.8	14.8	11.1	7.3	(29)	
		MCDB	7.3	8.6	12.8	19.7	22.9	25.4	26.6	26.5	22.8	18.6	14.2	9.9	(30)	
	5%	WB	4.3	5.1	7.7	12.2	16.3	19.0	20.2	19.9	16.8	13.7	10.1	5.7	(31)	
		MCDB	5.6	7.0	11.2	17.3	21.5	23.9	25.4	25.3	20.9	17.4	12.9	7.5	(32)	
	10%	WB	3.0	3.9	6.4	11.0	15.2	18.0	19.2	19.0	15.7	12.6	8.9	4.4	(33)	
		MCDB	4.3	5.6	9.3	15.2	19.8	22.3	23.7	23.7	19.2	15.6	11.5	5.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	7.5	10.0	10.2	9.8	9.9	10.3	8.8	7.7	5.7	4.6	(35)	
		MCDBR	5.2	8.1	11.3	14.0	13.9	13.2	13.1	13.5	12.1	10.8	8.4	6.0	(36)	
	5% WB	MCWBR	3.9	5.2	6.5	6.9	6.9	6.1	5.8	5.9	6.2	5.9	4.8	4.1	(37)	
		MCWBR	5.0	6.9	10.0	12.4	12.7	11.4	11.6	11.9	11.0	10.0	7.2	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.312	0.339	0.384	0.441	0.428	0.429	0.450	0.445	0.407	0.372	0.347	0.310	(40)	
		taud	2.236	2.191	2.173	2.091	2.188	2.218	2.170	2.184	2.248	2.318	2.312	2.295	(41)	
	Edn at Noon	Edn at Noon	715	785	811	802	833	833	807	791	781	743	670	666	(42)	
		Edh at Noon	75	100	122	147	139	136	141	133	112	88	71	63	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.89	1.62	2.74	4.05	4.95	5.31	5.17	4.76	3.31	2.04	1.03	0.68	(44)	
	RadStd	RadStd	0.14	0.26	0.34	0.44	0.63	0.44	0.53	0.43	0.49	0.30	0.13	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.57	N/A	N/A	+1.01	+0.51	+0.46	-127	-182	+87	+36	

Nomenclature: See separate page