

PRZEMYSŁ, Poland

WMO: 126950

Lat: 49.8042N

Lon: 22.7719E

Elev: 920

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.5	11.4	-1.9	5.1	6.1	4.6	7.2	13.9	19.8	33.0	17.9	34.5	5.2	280	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	85.8	69.4	82.6	67.7	79.8	66.3	71.0	82.4	69.4	80.0	67.8	77.3	4.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.3	103.9	76.2	65.7	98.1	74.0	64.2	93.1	72.4	35.3	83.1	34.0	80.2	32.7	77.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.2	14.1	12.3	DB	0.3	89.6	5.9	3.2	-4.0	91.9	-7.4	93.7	-10.7	95.5	-15.0	97.8
			WB	-1.7	74.0	7.4	1.7	-7.0	75.3	-11.4	76.3	-15.5	77.3	-20.9	78.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.2	27.9	31.8	39.0	49.9	57.5	64.6	67.3	67.2	58.9	50.0	40.9	34.2	(6)
	DBStd	15.64	10.11	10.85	9.06	8.02	6.89	5.83	5.44	5.91	6.40	8.37	7.91	6.95	(7)
	HDD50	2552	686	510	351	97	15	0	0	0	6	108	288	491	(8)
	HDD65	6097	1151	929	805	456	247	78	40	44	201	467	724	955	(9)
	CDD50	2255	0	1	11	94	248	437	536	532	274	107	14	1	(10)
	CDD65	324	0	0	0	2	14	66	110	112	19	1	0	0	(11)
	CDH74	2542	0	0	0	27	140	489	779	948	153	6	0	0	(12)
	CDH80	618	0	0	0	1	10	97	196	293	21	0	0	0	(13)
(14) Wind	WSAvg	5.7	6.4	6.3	6.8	6.1	5.2	5.0	5.1	4.4	5.0	5.1	5.7	7.2	(14)
(15) Precipitation	PrecAvg	27.1	1.4	1.5	1.7	2.1	3.0	3.1	3.8	2.9	2.9	2.0	1.8	1.3	(15)
	PrecMax	35.9	3.7	3.2	3.6	4.8	5.5	5.9	8.1	5.9	7.5	5.6	4.4	3.0	(16)
	PrecMin	18.1	0.6	0.5	0.4	0.8	0.9	1.7	0.8	0.1	0.4	0.1	0.0	0.1	(17)
	PrecStd	4.4	0.7	0.6	0.9	1.0	1.2	1.2	2.1	1.4	1.8	1.3	1.0	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	57.1	65.4	77.5	82.3	86.3	90.1	91.0	81.9	74.2	63.5	55.0	(19)
		MCWB	44.6	46.1	50.5	58.5	63.8	70.9	70.1	71.2	64.5	60.9	53.5	47.7	(20)
	2%	DB	47.5	51.9	60.1	72.2	78.4	82.6	85.0	86.7	78.2	70.0	59.2	49.5	(21)
		MCWB	42.8	44.3	47.7	56.7	63.1	68.8	69.5	69.0	64.2	58.7	51.4	44.2	(22)
	5%	DB	44.0	48.1	56.0	67.6	75.0	79.3	81.7	82.9	74.4	66.1	55.4	46.8	(23)
		MCWB	40.2	42.1	46.0	54.3	61.8	66.6	67.8	68.1	62.8	57.3	48.9	42.7	(24)
	10%	DB	41.3	44.6	52.0	63.4	70.9	76.0	78.5	79.2	70.4	62.1	51.5	44.0	(25)
		MCWB	38.0	40.2	44.1	51.9	59.6	64.7	66.5	66.5	60.4	54.9	47.3	40.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	47.4	51.8	60.5	66.5	73.4	72.6	73.3	67.4	62.4	55.1	48.0	(27)
		MCDB	49.5	54.9	62.1	72.8	77.9	83.7	84.4	86.1	78.3	71.0	61.3	54.5	(28)
	2%	WB	43.3	44.8	49.1	57.9	64.7	70.3	70.7	70.7	65.3	59.8	52.3	44.9	(29)
		MCDB	46.8	50.8	57.7	70.0	76.0	80.1	82.1	82.9	76.0	68.2	57.8	48.8	(30)
	5%	WB	40.9	42.8	47.1	55.6	62.9	67.9	69.3	69.1	63.4	57.7	49.7	42.9	(31)
		MCDB	44.1	47.3	54.6	65.3	73.1	76.5	79.5	80.4	72.5	64.7	54.4	46.5	(32)
	10%	WB	38.2	40.5	44.9	53.3	60.7	66.0	67.6	67.5	61.4	55.7	47.5	40.6	(33)
		MCDB	41.2	44.1	51.0	61.8	69.8	74.0	76.1	77.6	68.9	61.5	51.2	43.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	10.7	13.0	17.0	16.9	16.8	17.0	18.0	16.5	14.1	10.0	7.8	(35)
		MCDBR	10.7	15.9	19.8	23.4	22.6	21.4	22.4	24.0	22.3	19.9	16.4	10.6	(36)
	5% WB	MCWBR	8.0	10.0	11.0	11.4	10.7	10.2	9.5	10.1	10.6	10.5	9.8	7.1	(37)
		MCWBR	10.7	14.4	17.5	21.7	21.3	19.3	20.0	21.7	20.2	18.9	14.9	10.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.311	0.337	0.380	0.432	0.420	0.422	0.444	0.439	0.403	0.368	0.343	0.308	(40)
		taud	2.272	2.234	2.215	2.128	2.221	2.245	2.195	2.209	2.272	2.346	2.343	2.329	(41)
	Ebn at Noon		227	250	259	257	266	266	257	252	249	237	213	212	(42)
		Edh at Noon	23	30	37	45	43	42	43	41	35	27	22	19	(43)
(44) All-Sky Solar Radiation	RadAvg		277	510	870	1292	1589	1706	1652	1512	1047	644	314	209	(44)
	RadStd		44	83	108	140	193	134	164	131	155	96	38	30	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (20 neighbors)	+1.06	N/A	N/A	+1.80	+0.86	+0.77	-239	-353	+180	+79

Nomenclature: See separate page