

PRZEMYSŁ, Poland

WMO: 126950

Lat: 49.8042N

Lon: 22.7719E

Elev: 280

StdP: 98.00

Time Zone: 1.00 (EUC)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-11.4	-18.8	0.7	-14.4	-15.2	1.0	-10.0	8.8	0.6	8.0	1.4	2.3	280	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	29.9	20.8	28.1	19.8	26.6	19.1	21.7	28.0	20.8	26.7	19.9	25.2	2.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.6	14.8	24.5	18.7	14.0	23.4	17.9	13.3	22.4	64.3	28.4	61.2	26.8	58.2	25.2	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.3	5.5	-17.6	32.0	3.3	1.8	-20.0	33.3	-21.9	34.3	-23.7	35.3	-26.1	36.6		
(5)			-18.7	23.3	4.1	1.0	-21.7	24.0	-24.1	24.6	-26.4	25.1	-29.4	25.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-2.3	-0.1	3.9	9.9	14.2	18.1	19.6	19.5	15.0	10.0	4.9	1.2	(6)
(7)		DBStd	8.69	5.61	6.03	5.03	4.46	3.83	3.24	3.02	3.29	3.56	4.65	4.39	3.86	(7)
(8)		HDD10.0	1418	381	283	195	54	8	0	0	0	3	60	160	273	(8)
(9)		HDD18.3	3387	639	516	447	253	137	43	22	24	112	259	402	531	(9)
(10)		CDD10.0	1253	0	1	6	52	138	243	298	296	152	59	8	1	(10)
(11)		CDD18.3	180	0	0	0	1	8	37	61	62	11	1	0	0	(11)
(12)		CDH23.3	1412	0	0	0	15	78	272	433	527	85	3	0	0	(12)
(13)		CDH26.7	343	0	0	0	1	6	54	109	163	12	0	0	0	(13)
(14)	Wind	WSAvg	2.5	2.9	2.8	3.0	2.7	2.3	2.3	2.0	2.2	2.3	2.5	3.2	(14)	
(15)	Precipitation	PrecAvg	689	35	38	43	54	77	80	96	73	73	50	45	34	(15)
(16)		PrecMax	912	93	82	91	121	140	149	207	150	191	142	112	76	(16)
(17)		PrecMin	461	14	12	11	20	22	43	20	2	10	3	0	3	(17)
(18)		PrecStd	111	17	16	24	25	31	30	54	36	46	34	25	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	14.0	18.5	25.3	27.9	30.2	32.3	32.8	27.7	23.4	17.5	12.8	(19)
(20)			MCWB	7.0	7.8	10.3	14.7	17.7	21.6	21.2	21.8	18.1	16.1	11.9	8.7	(20)
(21)		2%	DB	8.6	11.1	15.6	22.3	25.8	28.1	29.4	30.4	25.7	21.1	15.1	9.7	(21)
(22)			MCWB	6.0	6.8	8.7	13.7	17.3	20.4	20.9	20.6	17.9	14.9	10.8	6.8	(22)
(23)		5%	DB	6.7	9.0	13.3	19.8	23.9	26.3	27.6	28.3	23.5	18.9	13.0	8.2	(23)
(24)			MCWB	4.6	5.6	7.8	12.4	16.6	19.2	19.9	20.1	17.1	14.0	9.4	5.9	(24)
(25)		10%	DB	5.2	7.0	11.1	17.4	21.6	24.4	25.8	26.2	21.3	16.7	10.8	6.7	(25)
(26)			MCWB	3.3	4.5	6.7	11.1	15.4	18.2	19.1	19.2	15.8	12.7	8.5	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	8.5	11.0	15.8	19.2	23.0	22.6	23.0	19.7	16.9	12.8	8.9	(27)
(28)			MCDWB	9.7	12.7	16.7	22.7	25.5	28.7	29.1	30.1	25.7	21.7	16.3	12.5	(28)
(29)		2%	WB	6.3	7.1	9.5	14.4	18.2	21.3	21.5	21.5	18.5	15.4	11.3	7.2	(29)
(30)			MCDWB	8.2	10.4	14.3	21.1	24.5	26.7	27.9	28.3	24.4	20.1	14.4	9.3	(30)
(31)		5%	WB	5.0	6.0	8.4	13.1	17.1	20.0	20.7	20.6	17.4	14.3	9.8	6.0	(31)
(32)			MCDWB	6.7	8.5	12.5	18.5	22.9	24.7	26.4	26.9	22.5	18.1	12.4	8.0	(32)
(33)		10%	WB	3.4	4.7	7.2	11.8	16.0	18.9	19.8	19.7	16.3	13.2	8.6	4.8	(33)
(34)			MCDWB	5.1	6.7	10.5	16.6	21.0	23.3	24.5	25.3	20.5	16.4	10.7	6.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	5.9	7.2	9.4	9.4	9.3	9.4	10.0	9.2	7.9	5.6	4.3	(35)
(36)			MCDBR	6.0	8.8	11.0	13.0	12.5	11.9	12.4	13.3	12.4	11.1	9.1	5.9	(36)
(37)			MCWBR	4.4	5.6	6.1	6.3	6.0	5.7	5.3	5.6	5.9	5.8	5.4	3.9	(37)
(38)		5% WB	MCDWR	5.9	8.0	9.7	12.1	11.8	10.7	11.1	12.1	11.2	10.5	8.3	5.8	(38)
(39)			MCWBR	4.6	5.2	5.8	6.1	6.0	5.5	5.1	5.4	5.6	5.8	5.3	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.311	0.337	0.380	0.432	0.420	0.422	0.444	0.439	0.403	0.368	0.343	0.308	(40)	
(41)		taud	2.272	2.234	2.215	2.128	2.221	2.245	2.195	2.209	2.272	2.346	2.343	2.329	(41)	
(42)		Ebn at Noon	716	788	816	809	839	839	811	795	784	747	673	667	(42)	
(43)		Edh at Noon	72	95	116	141	134	132	137	129	109	85	68	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.87	1.61	2.74	4.07	5.01	5.38	5.21	4.77	3.30	2.03	0.99	0.66	(44)	
(45)		RadStd	0.14	0.26	0.34	0.44	0.61	0.42	0.52	0.41	0.49	0.30	0.12	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.59	N/A	N/A	+1.00	+0.48	+0.43	-133	-196	+100	+44

Nomenclature: See separate page