

SZECSENY, Hungary

WMO: 127560

Lat: 48.117N

Lon: 19.517E

Elev: 502

StdP: 14.43

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.3	10.7	-1.2	5.3	5.1	5.2	7.3	12.9	21.2	38.7	18.4	39.2	2.2	90	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.2	90.4	70.6	87.2	69.1	84.3	67.9	72.8	85.8	71.1	83.8	69.5	81.3	6.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	107.6	78.9	66.9	100.8	76.6	65.3	95.2	74.6	36.7	85.8	35.2	84.4	33.8	81.4	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.4	13.2	DB	-2.4	94.6	9.0	2.9	-8.9	96.7	-14.1	98.5	-19.1	100.1	-25.7	102.3	(4)
(5)			WB	-2.5	75.9	8.8	1.6	-8.8	77.1	-14.0	78.0	-18.9	78.9	-25.3	80.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	28.4	32.1	41.3	51.6	59.6	66.4	69.1	68.3	59.4	50.1	41.2	31.6	(6)
(7)		DBStd	15.78	9.01	8.40	7.17	6.15	5.96	5.59	5.43	5.29	5.86	6.80	7.15	7.84	(7)
(8)		HDD50	2436	671	500	276	53	4	0	0	0	2	87	273	570	(8)
(9)		HDD65	5873	1136	920	734	404	185	49	22	27	184	462	715	1035	(9)
(10)		CDD50	2442	0	0	7	100	302	491	593	567	284	89	9	0	(10)
(11)		CDD65	404	0	0	0	1	18	90	150	129	16	0	0	0	(11)
(12)		CDH74	5322	0	0	0	54	381	1157	1823	1583	314	10	0	0	(12)
(13)		CDH80	1808	0	0	0	7	79	349	703	598	72	0	0	0	(13)
(14)	Wind	WSAvg	5.0	4.8	4.9	6.2	6.0	5.6	5.1	5.2	4.4	4.7	4.3	4.9	4.4	(14)
(15)	Precipitation	PrecAvg	26.1	1.4	1.4	1.3	1.9	2.9	3.0	3.5	2.6	2.1	2.1	2.0	1.7	(15)
(16)		PrecMax	47.6	3.9	5.2	3.3	4.7	8.6	6.7	6.3	6.4	6.1	4.4	4.3	4.3	(16)
(17)		PrecMin	18.1	0.1	0.0	0.0	0.1	0.8	0.9	0.2	0.2	0.1	0.0	0.0	0.2	(17)
(18)		PrecStd	5.7	0.9	1.1	0.9	1.1	1.7	1.4	1.8	1.7	1.3	1.3	1.1	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	57.5	68.9	79.7	86.6	90.2	95.8	94.4	86.2	75.1	62.8	49.5	(19)
(20)			MCWB	46.1	47.2	53.1	61.8	65.0	71.9	71.2	70.7	66.7	62.0	55.7	46.0	(20)
(21)		2%	DB	46.1	50.8	64.6	74.5	81.9	87.2	90.8	90.1	81.6	70.8	57.9	46.3	(21)
(22)			MCWB	43.3	44.6	50.5	57.7	64.4	69.6	71.0	70.2	65.1	59.8	52.4	43.9	(22)
(23)		5%	DB	42.8	46.7	59.6	70.7	78.5	84.3	87.2	86.4	77.5	67.0	54.6	43.9	(23)
(24)			MCWB	40.8	42.4	48.6	55.5	63.0	68.1	69.5	68.9	63.3	58.2	50.3	41.7	(24)
(25)		10%	DB	39.7	43.6	55.2	66.9	74.5	81.0	83.8	82.9	73.6	62.4	51.5	41.6	(25)
(26)			MCWB	37.8	40.6	45.9	53.4	61.0	66.5	68.3	67.6	61.1	55.6	48.6	39.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	48.4	54.9	62.6	68.2	75.0	74.6	74.3	68.9	63.8	56.8	46.8	(27)
(28)			MCD B	49.3	56.2	64.8	76.7	81.0	86.5	87.5	86.7	82.7	72.2	61.1	49.0	(28)
(29)		2%	WB	43.6	45.4	52.0	59.2	66.1	72.0	72.8	72.3	66.7	61.0	53.6	44.2	(29)
(30)			MCD B	45.5	49.4	62.0	71.6	78.5	83.5	86.3	85.4	78.3	69.3	56.7	45.7	(30)
(31)		5%	WB	41.0	43.2	49.5	56.8	64.3	69.8	71.2	70.6	64.6	58.8	51.0	42.2	(31)
(32)			MCD B	42.5	46.5	57.8	67.6	75.2	81.0	84.2	83.4	74.9	65.4	53.5	43.7	(32)
(33)		10%	WB	37.9	40.8	47.0	54.8	62.3	67.8	69.5	68.9	62.6	56.4	48.7	40.2	(33)
(34)			MCD B	39.5	43.2	53.7	65.0	72.3	78.5	81.0	80.6	70.9	61.3	51.2	41.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.3	15.4	21.0	25.5	24.0	24.2	25.2	25.4	23.9	20.7	14.1	10.1	(35)
(36)			MCDBR	13.2	19.7	31.0	33.0	31.4	29.1	30.2	31.4	31.1	27.5	19.6	12.2	(36)
(37)			MCWBR	10.2	14.3	19.0	17.7	15.5	13.7	12.9	13.8	16.0	17.1	14.0	9.7	(37)
(38)		5% WB	MCD BR	12.1	18.3	27.1	28.9	27.3	26.0	27.3	27.8	26.7	24.5	16.9	10.7	(38)
(39)			MCWBR	9.7	13.7	17.5	16.1	14.3	13.1	12.5	13.4	14.2	15.6	12.7	9.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.347	0.388	0.441	0.432	0.433	0.447	0.445	0.415	0.385	0.359	0.324	(40)	
(41)		taud	2.336	2.292	2.235	2.118	2.196	2.232	2.197	2.211	2.259	2.314	2.339	2.365	(41)	
(42)		Ebn at Noon	233	253	260	256	264	264	258	252	248	235	216	217	(42)	
(43)		Edh at Noon	23	30	37	46	44	43	44	42	36	29	23	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	313	565	952	1398	1680	1826	1768	1589	1128	700	361	242	(44)	
(45)		RadStd	44	89	152	142	189	150	153	156	148	80	43	26	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	+1.03	N/A	N/A	+1.62	+0.97	+0.85	-221	-313	+160	+74

Nomenclature: See separate page