

JOSVAFO, Hungary

WMO: 127660

Lat: 48.485N

Lon: 20.540E

Elev: 305

StdP: 97.71

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-9.9	-17.9	0.8	-8.3	-15.6	1.0	-7.4	5.7	-1.6	4.9	-1.0	0.9	310	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	30.7	20.5	29.0	20.0	27.4	19.1	21.7	28.3	20.7	27.2	19.9	25.9	2.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.7	25.1	18.5	13.9	23.9	17.6	13.1	22.8	64.5	28.1	61.2	27.2	58.1	25.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.2	4.4	3.8	DB	-14.6	32.9	2.7	1.9	-16.5	34.2	-18.1	35.3	-19.7	36.4	-21.6	37.8	(4)
(5)			WB	-15.2	23.3	2.6	1.0	-17.1	24.0	-18.6	24.6	-20.1	25.2	-22.0	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	-2.0	0.2	4.9	10.8	14.8	18.5	20.3	20.1	15.3	10.0	4.8	-0.6	(6)	
	DBStd	8.70	4.27	4.16	4.45	3.71	3.42	3.28	3.10	3.03	3.48	3.94	4.00	4.02	(7)	
	HDD10.0	1389	371	276	164	33	4	0	0	0	2	52	158	330	(8)	
	HDD18.3	3320	629	509	416	225	117	37	16	16	103	259	404	588	(9)	
	CDD10.0	1321	0	0	6	58	153	256	318	314	161	51	4	0	(10)	
	CDD18.3	211	0	0	0	1	8	43	76	72	12	0	0	0	(11)	
	CDH23.3	1844	0	0	0	10	86	363	658	623	103	1	0	0	(12)	
	CDH26.7	498	0	0	0	1	11	78	203	188	18	0	0	0	(13)	
(14) Wind	WSAvg	1.5	1.1	1.3	1.8	1.9	1.9	1.8	1.7	1.7	1.6	1.3	1.2	1.1	(14)	
(15) Precipitation	PrecAvg	617	28	33	32	47	67	78	89	64	52	50	42	35	(15)	
	PrecMax	1156	72	113	111	97	220	189	159	156	143	123	94	86	(16)	
	PrecMin	398	2	2	4	4	16	31	26	14	7	2	1	4	(17)	
	PrecStd	150	20	26	26	26	42	36	41	40	32	34	24	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	12.2	19.0	24.7	28.1	31.0	33.5	32.8	29.1	22.2	16.4	8.9	(19)	
		MCWB	5.9	6.7	10.7	14.8	17.8	21.3	20.6	20.4	18.6	15.4	11.9	6.4	(20)	
	2%	DB	7.0	9.5	16.8	22.0	25.5	28.8	30.7	30.8	26.1	20.0	13.6	7.1	(21)	
		MCWB	5.4	5.7	9.2	12.8	16.9	20.1	20.7	20.3	17.5	14.7	9.8	5.7	(22)	
	5%	DB	5.3	7.7	14.4	20.0	23.8	27.2	29.0	28.7	24.1	18.2	11.7	5.9	(23)	
		MCWB	4.1	5.1	8.0	11.8	16.2	19.2	20.2	19.8	16.6	13.6	9.3	4.7	(24)	
	10%	DB	3.7	5.9	12.1	18.0	21.7	25.5	27.1	26.9	22.1	16.0	10.1	4.7	(25)	
		MCWB	2.5	4.0	6.8	10.8	15.0	18.3	19.3	19.1	15.3	12.5	8.5	3.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.0	11.4	15.7	19.1	22.8	23.0	22.5	19.5	16.7	12.6	7.2	(27)	
		MCDB	8.5	11.0	17.0	22.8	25.3	28.7	29.4	29.5	26.4	20.7	14.9	8.2	(28)	
	2%	WB	5.6	6.6	9.9	14.0	17.8	21.2	21.7	21.3	18.3	15.2	11.0	6.0	(29)	
		MCDB	6.4	8.6	15.4	20.1	23.7	27.4	28.4	28.2	24.8	18.9	12.7	6.9	(30)	
	5%	WB	4.2	5.5	8.6	12.7	16.8	20.0	20.8	20.5	17.2	14.1	9.7	4.9	(31)	
		MCDB	5.2	7.3	13.2	17.9	22.6	25.6	27.3	27.1	22.4	17.2	11.1	5.7	(32)	
	10%	WB	2.6	4.2	7.3	11.6	15.7	19.0	19.9	19.6	16.2	13.0	8.6	3.8	(33)	
		MCDB	3.6	5.7	11.2	16.8	20.7	24.2	25.9	25.7	20.6	15.5	9.9	4.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.8	9.3	10.7	10.5	10.6	11.2	11.3	10.2	8.7	6.4	4.9	(35)	
		MCDBR	6.6	9.2	13.0	13.6	13.2	12.8	13.4	13.6	12.8	11.0	8.9	5.9	(36)	
	5% WB	MCWBR	5.0	6.2	7.1	6.7	6.6	6.1	5.8	5.7	6.0	6.2	5.6	4.7	(37)	
		MCWBR	5.9	8.0	11.9	11.9	11.9	11.8	12.2	12.4	11.3	10.2	7.4	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.312	0.337	0.378	0.434	0.424	0.426	0.442	0.439	0.405	0.374	0.347	0.312	(40)	
		taud	2.335	2.300	2.254	2.130	2.210	2.242	2.203	2.217	2.276	2.335	2.359	2.373	(41)	
	Ebn at Noon		744	807	828	813	839	839	817	801	790	752	691	694	(42)	
		Edh at Noon	71	92	114	142	137	134	137	129	111	89	70	61	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.94	1.69	2.99	4.32	5.22	5.61	5.43	5.01	3.54	2.15	1.12	0.70	(44)	
	RadStd		0.12	0.28	0.42	0.43	0.58	0.40	0.53	0.41	0.45	0.29	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	+0.58	N/A	N/A	+0.95	+0.52	+0.46	-125	-182	+92	+42

Nomenclature: See separate page