

MOSONMAGYAROVAR, Hungary

WMO: 128150

Lat: 47.883N

Lon: 17.283E

Elev: 122

StdP: 99.87

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-7.6	-13.9	1.1	-8.1	-11.3	1.4	-6.0	11.1	3.6	10.1	1.3	2.8	320	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	32.8	21.4	31.1	20.7	29.3	19.9	22.3	30.3	21.5	29.2	20.7	27.9	3.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.6	25.7	18.8	13.8	24.8	18.0	13.1	24.0	66.0	30.3	62.8	29.4	60.0	28.1	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
9.6	8.4	7.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-13.1	35.6	3.0	1.9	-15.3	37.0	-17.0	38.1	-18.7	39.1	-20.9	40.5		
			-13.7	23.9	2.9	0.9	-15.8	24.6	-17.6	25.1	-19.2	25.6	-21.3	26.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-0.2	2.2	6.1	11.5	16.0	19.7	21.6	21.0	16.4	11.3	6.1	1.1	(6)
(7)		DBStd	8.50	4.42	4.04	4.18	3.91	3.60	3.53	3.27	3.25	3.28	3.90	4.10	4.14	(7)
(8)		HDD10.0	1132	315	219	132	28	2	0	0	0	1	32	128	276	(8)
(9)		HDD18.3	2941	573	452	379	205	91	26	9	11	76	220	367	534	(9)
(10)		CDD10.0	1543	0	1	11	74	187	292	359	342	192	72	11	1	(10)
(11)		CDD18.3	309	0	0	0	1	18	68	110	94	17	1	0	0	(11)
(12)		CDH23.3	3167	0	0	0	31	207	686	1118	948	169	9	0	0	(12)
(13)		CDH26.7	1106	0	0	0	3	39	218	441	371	35	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.2	3.6	3.8	3.6	3.3	3.2	2.7	2.9	2.7	3.1	3.1	(14)	
(15)	Precipitation	PrecAvg	570	37	34	32	44	51	57	73	57	38	45	58	43	(15)
(16)		PrecMax	791	82	83	65	98	106	142	144	106	83	137	152	75	(16)
(17)		PrecMin	455	1	2	9	8	2	5	10	18	9	1	25	7	(17)
(18)		PrecStd	84	21	25	19	26	30	36	44	27	20	38	33	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	15.5	20.4	26.4	29.8	33.2	35.1	35.5	29.9	24.5	18.8	13.6	(19)
(20)		MCWB	8.7	9.2	11.6	16.3	19.0	21.6	21.8	21.3	19.6	17.3	13.6	10.1	(20)	
(21)		2%	DB	9.9	12.8	17.6	23.7	27.6	31.2	32.8	32.8	27.3	21.9	16.0	9.7	(21)
(22)		MCWB	6.9	8.2	10.6	14.5	18.2	21.0	21.4	21.3	18.6	16.0	12.3	7.2	(22)	
(23)		5%	DB	7.7	10.6	15.3	21.5	25.7	29.3	31.1	30.6	25.2	19.8	13.7	7.7	(23)
(24)		MCWB	5.4	7.1	9.6	13.5	17.3	20.0	20.8	20.5	17.6	14.7	10.8	5.7	(24)	
(25)		10%	DB	5.8	8.4	13.1	19.3	23.6	27.3	29.2	28.4	23.1	17.6	11.7	6.3	(25)
(26)		MCWB	4.0	5.7	8.5	12.3	16.1	19.1	20.0	19.6	16.6	13.7	9.5	4.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	10.0	12.7	16.7	20.4	23.3	23.4	20.5	17.9	14.0	10.3	(27)	
(28)		MCDWB	12.2	14.5	18.5	25.2	27.5	30.8	32.2	31.1	28.4	23.2	17.9	13.5	(28)	
(29)		2%	WB	7.2	8.6	11.3	15.3	18.9	21.8	22.2	22.1	19.3	16.5	12.4	7.5	(29)
(30)		MCDWB	9.5	12.2	16.5	22.1	26.4	29.2	30.5	30.0	25.7	21.1	15.6	9.3	(30)	
(31)		5%	WB	5.6	7.2	10.1	14.1	17.8	20.8	21.5	21.2	18.3	15.2	11.1	6.1	(31)
(32)		MCDWB	7.4	10.2	14.5	19.9	24.5	27.8	29.4	29.0	23.7	19.0	13.6	7.4	(32)	
(33)		10%	WB	4.1	5.9	8.8	12.9	16.7	19.8	20.6	20.3	17.2	14.0	9.7	4.9	(33)
(34)		MCDWB	5.6	8.3	12.6	18.8	22.5	26.1	27.9	27.1	22.2	17.0	11.5	6.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	5.5	6.9	9.1	11.1	11.1	11.4	11.7	11.8	10.4	9.2	6.3	5.0	(35)	
(36)		5% DB	MCDBR	7.7	10.6	13.3	14.9	14.3	14.1	14.9	15.3	14.1	12.2	9.3	7.2	(36)
(37)		MCWBR	5.6	7.1	7.8	7.4	6.6	5.8	5.5	5.6	6.5	6.9	6.0	5.4	(37)	
(38)		5% WB	MCDBR	7.5	9.8	12.1	13.4	13.2	12.8	13.6	14.1	12.5	11.5	9.1	6.9	(38)
(39)		MCWBR	5.7	6.8	7.4	6.9	6.4	5.7	5.5	5.8	6.0	6.7	6.0	5.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.325	0.349	0.386	0.430	0.426	0.428	0.436	0.437	0.412	0.382	0.356	0.324	(40)	
(41)		taud	2.368	2.337	2.255	2.151	2.214	2.244	2.221	2.235	2.272	2.332	2.356	2.384	(41)	
(42)		Ebn at Noon	738	800	823	819	839	838	824	805	787	749	689	690	(42)	
(43)		Edh at Noon	71	91	115	140	137	134	135	128	112	90	72	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.02	1.83	3.03	4.51	5.34	5.82	5.64	5.02	3.59	2.22	1.16	0.79	(44)	
(45)		RadStd	0.11	0.25	0.38	0.44	0.55	0.42	0.48	0.48	0.43	0.24	0.11	0.09	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)		
(47)	Regional (78 neighbors)	+0.59	N/A	N/A	+0.87	+0.50	+0.44	-122	-170	+98	+51	(47)

Nomenclature: See separate page