

GYOR, Hungary

WMO: 128220

Lat: 47.628N

Lon: 17.805E

Elev: 423

StdP: 14.47

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 12.9	(c) 17.6	(d) 6.4	(e) 7.7	(f) 16.5	(g) 10.5	(h) 9.5	(i) 20.2	(j) 18.8	(k) 40.5	(l) 16.5	(m) 39.5	(n) 3.4	(o) 320	(p) 0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	91.6	70.2	88.3	69.2	85.1	67.9	72.3	86.2	70.8	84.5	69.4	82.2	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	103.7	77.9	66.3	98.4	76.3	64.9	93.7	74.9	36.1	86.2	34.9	84.7	33.7	82.3	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.7	(b) 13.4	(c) 11.6	(e) 7.1	(f) 96.2	(g) 6.2	(h) 3.6	(i) 2.6	(j) 98.8	(k) -1.0	(l) 100.9	(m) -4.5	(n) 103.0	(o) -9.0	(p) 105.6		
(4) 15.7	(5) 13.4	(6) 11.6	(7) 7.1	(8) 96.2	(9) 6.2	(10) 3.6	(11) 2.6	(12) 98.8	(13) -1.0	(14) 100.9	(15) -4.5	(16) 103.0	(17) -9.0	(18) 105.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	32.2	35.4	43.6	53.1	61.1	67.7	70.7	70.0	61.4	52.1	43.1	34.1	
	DBStd	15.39	8.15	8.44	7.74	7.06	6.29	6.40	5.93	5.81	6.25	7.46	7.76	7.74	
	HDD50	2029	551	411	225	48	2	0	0	0	1	65	231	495	
	HDD65	5256	1016	828	664	360	153	43	16	18	142	402	656	958	
	CDD50	2811	1	3	25	141	345	532	643	621	343	131	25	1	
	CDD65	563	0	0	0	3	31	125	195	174	33	2	0	0	
	CDH74	5967	0	0	0	64	412	1316	2026	1794	335	20	0	0	
	CDH80	2151	0	0	0	8	81	447	822	723	69	1	0	0	
Wind	WSAvg	4.8	5.1	5.5	5.9	5.4	4.9	4.6	4.4	3.8	4.0	4.1	4.9	5.0	
Precipitation	PrecAvg	23.1	1.3	1.1	1.4	1.5	2.5	2.5	2.7	2.3	2.3	1.9	1.9	1.5	
	PrecMax	36.1	3.0	4.4	3.6	3.7	7.8	4.9	5.1	5.5	5.4	4.4	4.4	3.7	
	PrecMin	15.3	0.2	0.1	0.1	0.0	0.6	0.3	0.4	0.1	0.4	0.1	0.1	0.2	
	PrecStd	4.4	0.7	0.9	0.9	0.9	1.5	1.2	1.4	1.3	1.5	1.1	0.9	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.7	60.2	69.5	80.0	86.0	92.5	95.8	96.5	86.1	76.5	66.7	58.0	
		MCWB	48.4	48.9	53.4	61.1	66.1	70.4	70.6	70.0	65.8	62.8	56.2	51.2	
	2%	DB	50.8	55.5	64.7	75.2	82.2	88.9	91.6	91.7	81.6	72.1	61.9	51.1	
		MCWB	45.1	46.7	51.5	57.8	64.2	69.8	70.3	70.1	65.7	60.8	54.4	46.3	
	5%	DB	46.9	51.9	60.3	71.2	78.8	85.3	88.1	87.7	77.9	68.2	57.9	47.3	
		MCWB	42.6	45.1	49.6	56.5	62.8	68.4	69.3	69.0	64.3	59.1	52.1	43.6	
	10%	DB	43.6	47.8	56.4	67.4	75.1	81.8	84.7	83.6	74.1	64.4	54.1	44.3	
		MCWB	40.0	42.8	47.7	54.4	61.2	66.7	68.1	67.7	62.5	57.2	49.7	41.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	50.0	55.1	62.2	68.3	73.7	73.8	73.8	69.4	64.2	57.4	51.3
			MCDB	54.6	58.3	66.1	76.7	82.0	87.6	88.3	87.3	81.5	73.7	65.1	57.4
2%		WB	45.5	47.9	52.5	59.5	65.9	71.4	72.2	72.0	67.4	62.0	54.8	46.9	
		MCDB	50.3	54.5	62.1	72.4	78.5	84.8	86.8	85.7	78.0	70.2	61.0	50.7	
5%		WB	42.9	45.5	50.5	57.4	64.0	69.7	70.7	70.5	65.5	59.9	52.5	44.0	
		MCDB	46.5	51.0	58.9	68.6	75.7	82.3	84.7	84.1	75.0	66.9	57.4	46.8	
10%		WB	40.2	43.2	48.2	55.5	62.2	68.0	69.2	68.8	63.6	57.7	50.1	41.7	
		MCDB	43.1	47.7	55.5	66.0	72.7	79.4	82.0	81.3	72.3	63.5	53.7	43.9	
Mean Daily Temperature Range	5% DB	MDBR	10.4	13.3	16.8	20.1	20.0	20.4	21.0	21.6	19.0	17.1	12.0	9.9	
		MCDBR	14.9	19.2	24.0	27.4	26.8	25.8	27.5	28.4	25.5	22.4	17.4	14.3	
		MCWBR	10.6	12.2	13.6	13.2	11.9	10.2	9.8	10.2	11.8	12.5	11.0	10.6	
	5% WB	MCDBR	14.7	17.2	21.4	24.5	23.6	23.2	24.3	25.5	21.9	20.6	16.6	13.5	
		MCWBR	10.8	11.5	12.7	12.2	11.4	9.8	9.6	10.4	10.8	12.0	10.7	10.3	
Clear-Sky Solar Irradiance	taub	0.328	0.352	0.390	0.435	0.429	0.430	0.439	0.440	0.416	0.385	0.358	0.328		
	taud	2.362	2.320	2.240	2.133	2.202	2.236	2.211	2.222	2.257	2.321	2.346	2.376		
	Ebn at Noon	234	253	260	259	266	266	261	254	249	237	219	219		
	Edh at Noon	23	30	37	45	44	43	43	41	36	29	23	20		
All-Sky Solar Radiation	RadAvg	332	590	976	1438	1716	1865	1820	1621	1155	727	382	255		
	RadStd	36	83	128	139	176	134	143	157	136	75	37	31		

Historical Trends

DBAvg	Heating		Cooling			Degree-Days				
	99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+1.04	N/A	N/A	N/A	N/A	-205	-270	N/A	+90	
Regional (75 neighbors)	+1.10	N/A	N/A	+1.60	+0.95	+0.85	-223	-311	+180	+97

Nomenclature: See separate page