

GYOR, Hungary

WMO: 128220

Lat: 47.628N

Lon: 17.805E

Elev: 129

StdP: 99.78

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.6	-8.0	-14.2	1.1	-8.6	-11.9	1.4	-6.5	8.4	4.7	7.4	4.1	1.5	320	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	33.1	21.2	31.3	20.7	29.5	20.0	22.4	30.1	21.6	29.1	20.8	27.9	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.8	25.5	19.1	14.1	24.6	18.3	13.4	23.8	66.2	30.1	63.2	29.3	60.4	27.9	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	6.0	5.2	DB	-13.9	35.7	3.4	2.0	-16.3	37.1	-18.3	38.3	-20.3	39.4	-22.8	40.9	(4)
(5)			WB	-14.3	24.0	3.4	1.0	-16.7	24.8	-18.7	25.4	-20.6	25.9	-23.1	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	0.1	1.9	6.4	11.7	16.1	19.8	21.5	21.1	16.3	11.2	6.2	1.2	(6)	
(7)		DBStd	8.55	4.53	4.69	4.30	3.92	3.49	3.55	3.29	3.23	3.47	4.14	4.31	4.30	(7)	
(8)		HDD10.0	1127	306	228	125	27	1	0	0	0	1	36	128	275	(8)	
(9)		HDD18.3	2920	564	460	369	200	85	24	9	10	79	223	364	532	(9)	
(10)		CDD10.0	1562	1	2	14	78	192	296	357	345	191	73	14	1	(10)	
(11)		CDD18.3	313	0	0	0	2	17	69	108	97	18	1	0	0	(11)	
(12)		CDH23.3	3315	0	0	0	36	229	731	1126	997	186	11	0	0	(12)	
(13)		CDH26.7	1195	0	0	0	4	45	248	457	402	38	1	0	0	(13)	
(14)	Wind	WSAvg	2.1	2.3	2.5	2.6	2.4	2.2	2.1	2.0	1.7	1.8	2.2	2.3	(14)		
(15)	Precipitation	PrecAvg	586	34	29	36	38	63	63	69	59	59	47	49	39	(15)	
(16)		PrecMax	918	77	111	92	93	198	124	130	139	136	111	111	93	(16)	
(17)		PrecMin	388	4	2	2	1	15	7	9	2	10	2	2	6	(17)	
(18)		PrecStd	113	18	23	23	23	39	30	35	34	38	29	23	23	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	15.6	20.8	26.7	30.0	33.6	35.5	35.8	30.1	24.7	19.3	14.5	(19)	
(20)			MCWB	9.1	9.4	11.9	16.2	18.9	21.3	21.5	21.1	18.8	17.1	13.4	10.7	(20)	
(21)		2%	DB	10.4	13.0	18.2	24.0	27.9	31.6	33.1	33.2	27.6	22.3	16.6	10.6	(21)	
(22)			MCWB	7.3	8.2	10.8	14.4	17.9	21.0	21.3	21.2	18.7	16.0	12.5	8.0	(22)	
(23)		5%	DB	8.3	11.1	15.7	21.8	26.0	29.6	31.2	30.9	25.5	20.1	14.4	8.5	(23)	
(24)			MCWB	5.9	7.3	9.8	13.6	17.1	20.2	20.7	20.6	17.9	15.1	11.2	6.5	(24)	
(25)		10%	DB	6.4	8.8	13.6	19.7	24.0	27.6	29.3	28.7	23.4	18.0	12.3	6.8	(25)	
(26)			MCWB	4.5	6.0	8.7	12.4	16.2	19.3	20.1	19.8	17.0	14.0	9.9	5.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	10.0	12.8	16.8	20.2	23.2	23.2	20.8	17.9	14.1	10.7	(27)		
(28)			MCDWB	12.5	14.6	18.9	24.8	27.8	30.9	31.3	30.7	27.5	23.1	18.4	14.1	(28)	
(29)		2%	WB	7.5	8.8	11.4	15.3	18.8	21.9	22.3	22.2	19.6	16.6	12.7	8.3	(29)	
(30)			MCDWB	10.1	12.5	16.7	22.4	25.8	29.3	30.4	29.8	25.5	21.2	16.1	10.4	(30)	
(31)		5%	WB	6.1	7.5	10.3	14.1	17.8	21.0	21.5	21.4	18.6	15.5	11.4	6.7	(31)	
(32)			MCDWB	8.0	10.5	15.0	20.3	24.3	28.0	29.3	28.9	23.9	19.4	14.1	8.2	(32)	
(33)		10%	WB	4.6	6.2	9.0	13.0	16.8	20.0	20.7	20.5	17.5	14.3	10.0	5.4	(33)	
(34)			MCDWB	6.2	8.7	13.1	18.9	22.6	26.3	27.8	27.4	22.4	17.5	12.1	6.6	(34)	
(35)	Mean Daily Temperature Range			MDBR	5.8	7.4	9.3	11.2	11.1	11.3	11.7	12.0	10.6	9.5	6.6	5.5	(35)
(36)		5% DB	MCDBR	8.3	10.6	13.3	15.2	14.9	14.4	15.3	15.8	14.2	12.4	9.6	7.9	(36)	
(37)			MCWBR	5.9	6.8	7.6	7.3	6.6	5.7	5.4	5.7	6.5	6.9	6.1	5.9	(37)	
(38)		5% WB	MCDBR	8.2	9.5	11.9	13.6	13.1	12.9	13.5	14.2	12.2	11.4	9.2	7.5	(38)	
(39)			MCWBR	6.0	6.4	7.1	6.8	6.3	5.5	5.3	5.8	6.0	6.7	6.0	5.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.328	0.352	0.390	0.435	0.429	0.430	0.439	0.440	0.416	0.385	0.358	0.328	(40)	
(41)		taud		2.362	2.320	2.240	2.133	2.202	2.236	2.211	2.222	2.257	2.321	2.346	2.376	(41)	
(42)		Ebn at Noon		737	798	820	816	837	837	822	802	784	747	689	689	(42)	
(43)		Edh at Noon		72	93	117	143	138	135	136	130	114	92	73	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg		1.05	1.86	3.08	4.53	5.41	5.88	5.74	5.11	3.64	2.29	1.20	0.80	(44)	
(45)		RadStd		0.11	0.26	0.40	0.44	0.56	0.42	0.45	0.50	0.43	0.24	0.12	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	-114	-150	N/A	+50	(46)
(47)	Regional (75 neighbors)	+0.61	N/A	N/A	+0.89	+0.53	+0.47	-124	-173	+100	+54	(47)

Nomenclature: See separate page