

VESZPREM SZENTKIRALYSZABADJA, Hungary

WMO: 128300

Lat: 47.067N

Lon: 17.833E

Elev: 922

StdP: 14.21

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.3	16.9	5.8	7.7	16.7	10.5	9.7	20.0	31.7	36.2	27.3	36.3	5.9	330	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	88.8	68.5	85.6	67.6	82.6	66.5	71.0	83.5	69.4	81.8	67.9	79.7	8.4	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	102.4	76.7	65.1	96.2	74.8	63.6	91.1	73.5	35.3	83.6	34.0	81.9	32.7	79.9	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.9	22.2	19.0	DB	8.8	92.8	4.7	3.3	5.4	95.2	2.7	97.2	0.1	99.1	-3.3	101.5
			WB	8.2	73.2	4.6	1.8	4.9	74.4	2.2	75.5	-0.3	76.5	-3.7	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.0	31.3	34.9	42.2	51.7	59.4	66.3	69.9	69.5	60.5	51.4	41.6	32.9	(6)
	DBStd	15.45	8.00	8.81	7.70	7.33	6.45	6.49	5.90	5.99	6.40	7.43	7.61	7.98	(7)
	HDD50	2212	580	426	260	66	5	0	0	0	2	75	267	531	(8)
	HDD65	5583	1045	844	707	400	193	61	23	24	165	423	703	995	(9)
	CDD50	2594	0	2	18	118	298	488	616	605	316	118	14	1	(10)
	CDD65	488	0	0	0	1	21	99	174	164	28	1	0	0	(11)
	CDH74	4177	0	0	0	19	199	846	1501	1402	206	4	0	0	(12)
	CDH80	1253	0	0	0	1	21	227	488	486	30	0	0	0	(13)
	WSAvg	7.7	7.5	8.6	9.0	8.5	7.9	7.7	8.2	6.6	7.0	6.7	6.9	7.2	(14)
	PrecAvg	25.5	1.6	1.4	1.5	1.8	2.5	2.8	2.5	3.0	2.5	2.1	2.3	1.9	(15)
(16) Precipitation	PrecMax	38.7	3.7	3.6	3.9	3.7	7.2	5.5	5.7	8.6	6.4	5.9	4.7	4.4	(16)
	PrecMin	18.0	0.2	0.2	0.3	0.2	0.9	0.6	0.6	0.1	0.8	0.1	0.4	0.3	(17)
	PrecStd	5.2	0.9	1.0	0.9	1.0	1.3	1.3	1.3	1.9	1.6	1.5	1.1	1.1	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	59.0	66.5	76.6	82.8	89.9	93.1	93.5	83.6	73.7	63.6	54.7	(19)
		MCWB	46.7	47.5	51.3	59.2	63.8	69.3	68.7	68.5	66.0	61.3	54.5	48.4	(20)
	2%	DB	49.0	54.8	62.7	71.8	79.0	85.9	88.6	89.2	79.6	70.0	59.1	49.7	(21)
		MCWB	43.8	46.0	49.9	56.1	62.7	68.4	68.7	68.2	64.2	59.6	52.6	45.1	(22)
	5%	DB	45.8	50.7	58.3	68.1	75.9	82.4	85.2	85.4	75.8	66.6	55.4	45.8	(23)
		MCWB	41.5	44.1	47.6	54.7	61.5	66.8	67.6	67.2	62.6	58.0	50.4	42.3	(24)
	10%	DB	42.5	46.9	54.4	64.6	72.3	79.0	82.2	81.7	72.0	63.1	52.1	43.1	(25)
		MCWB	39.3	41.6	45.8	52.8	59.8	65.5	66.7	66.2	60.8	56.0	48.4	40.5	(26)
	0.4%	WB	47.4	49.2	53.3	60.8	66.9	73.1	72.4	72.7	67.3	62.9	55.8	49.5	(27)
		MCDB	52.3	56.7	63.7	73.8	78.2	84.8	85.5	84.6	80.3	71.2	61.3	54.0	(28)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	44.4	46.7	50.9	57.9	64.5	70.3	70.8	70.6	65.4	60.6	53.4	45.6	(29)
		MCDB	48.5	53.2	60.0	69.0	75.8	81.8	83.8	83.4	76.8	68.5	58.6	48.9	(30)
	5%	WB	42.1	44.5	48.7	55.7	62.6	68.4	69.3	69.0	63.7	58.7	51.1	42.9	(31)
		MCDB	45.1	49.8	56.8	65.7	73.1	79.5	81.6	81.8	73.4	65.2	55.0	45.3	(32)
	10%	WB	39.5	42.3	46.5	53.7	60.7	66.5	67.7	67.3	61.9	56.6	48.9	40.7	(33)
		MCDB	42.4	46.4	53.6	63.2	70.4	76.8	79.3	79.1	70.1	62.3	51.8	42.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	12.0	15.0	17.1	17.4	17.5	17.8	18.0	16.0	15.4	10.7	9.2	(35)
		MCDBR	13.9	17.1	21.0	23.0	22.9	21.7	22.6	23.4	21.5	19.8	16.2	13.7	(36)
		MCWBR	9.9	10.9	12.0	11.7	10.8	9.3	8.5	8.7	9.5	11.1	10.8	10.3	(37)
	5% WB	MCDBR	13.5	15.6	19.0	20.8	20.7	20.1	20.7	21.2	19.5	18.9	15.4	12.9	(38)
		MCWBR	10.2	10.6	11.4	10.9	10.6	9.7	9.1	9.2	9.4	11.2	10.7	10.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.323	0.348	0.384	0.430	0.422	0.423	0.431	0.434	0.412	0.380	0.352	0.323	(40)
	taud		2.372	2.325	2.255	2.142	2.222	2.254	2.231	2.235	2.264	2.333	2.362	2.383	(41)
	Ebn at Noon		239	256	263	261	268	268	264	257	251	241	224	224	(42)
	Edh at Noon		23	30	37	45	43	42	43	41	36	29	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		353	609	994	1444	1739	1892	1863	1659	1173	758	405	269	(44)
	RadStd		41	88	128	139	167	136	137	164	139	79	42	37	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+1.51	N/A	N/A	N/A	N/A	N/A
Regional (70 neighbors)	+1.06	N/A	N/A	N/A	+0.90	+0.85	-212	-306	+176	+99

Nomenclature: See separate page