

VESZPREM SZENTKIRALYSZABADJA, Hungary

WMO: 128300

Lat: 47.067N

Lon: 17.833E

Elev: 281

StdP: 97.99

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.4	-8.4	-14.5	1.1	-8.5	-11.9	1.4	-6.7	14.1	2.3	12.2	2.4	2.6	330	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	31.6	20.3	29.8	19.8	28.1	19.2	21.6	28.6	20.8	27.7	20.0	26.5	3.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.6	24.8	18.4	13.7	23.8	17.6	13.0	23.1	64.2	28.7	61.3	27.7	58.2	26.6	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	9.9	8.5	-12.9	33.8	2.6	1.9	-14.8	35.1	-16.3	36.2	-17.7	37.3	-19.6	38.6		
(5)			-13.2	22.9	2.6	1.0	-15.0	23.6	-16.5	24.2	-18.0	24.7	-19.8	25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-0.4	1.6	5.7	11.0	15.2	19.0	21.0	20.8	15.8	10.8	5.3	0.5	(6)
(7)		DBStd	8.59	4.45	4.89	4.28	4.07	3.58	3.61	3.28	3.33	3.55	4.13	4.23	4.43	(7)
(8)		HDD10.0	1229	322	237	144	37	3	0	0	0	1	42	148	295	(8)
(9)		HDD18.3	3102	581	469	393	222	107	34	13	13	92	235	391	553	(9)
(10)		CDD10.0	1441	0	1	10	66	166	271	342	336	176	66	8	1	(10)
(11)		CDD18.3	271	0	0	0	1	12	55	97	91	16	1	0	0	(11)
(12)		CDH23.3	2321	0	0	0	11	111	470	834	779	114	2	0	0	(12)
(13)		CDH26.7	696	0	0	0	1	12	126	271	270	17	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.4	3.9	4.0	3.8	3.5	3.5	3.7	3.0	3.1	3.0	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	647	40	36	37	45	64	70	64	75	63	54	58	49	(15)
(16)		PrecMax	983	95	91	99	95	182	139	146	219	162	151	119	113	(16)
(17)		PrecMin	456	5	4	7	5	24	15	15	3	20	2	9	7	(17)
(18)		PrecStd	133	23	26	22	25	34	33	33	49	40	37	28	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	15.0	19.2	24.8	28.2	32.2	33.9	34.2	28.7	23.2	17.6	12.6	(19)
(20)			MCWB	8.1	8.6	10.7	15.1	17.7	20.7	20.4	20.3	18.9	16.3	12.5	9.1	(20)
(21)		2%	DB	9.5	12.7	17.0	22.1	26.1	29.9	31.4	31.8	26.4	21.1	15.1	9.9	(21)
(22)			MCWB	6.5	7.8	10.0	13.4	17.0	20.2	20.4	20.1	17.9	15.3	11.4	7.3	(22)
(23)		5%	DB	7.7	10.4	14.6	20.1	24.4	28.0	29.6	29.7	24.3	19.2	13.0	7.6	(23)
(24)			MCWB	5.3	6.7	8.7	12.6	16.4	19.3	19.8	19.6	17.0	14.4	10.2	5.7	(24)
(25)		10%	DB	5.8	8.3	12.4	18.1	22.4	26.1	27.9	27.6	22.2	17.3	11.2	6.2	(25)
(26)			MCWB	4.0	5.3	7.7	11.5	15.4	18.6	19.3	19.0	16.0	13.4	9.1	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.6	11.9	16.0	19.4	22.8	22.4	22.6	19.6	17.2	13.2	9.7	(27)
(28)			MCDWB	11.3	13.7	17.6	23.2	25.7	29.3	29.7	29.2	26.8	21.8	16.3	12.2	(28)
(29)		2%	WB	6.9	8.2	10.5	14.4	18.1	21.3	21.6	21.5	18.6	15.9	11.9	7.6	(29)
(30)			MCDWB	9.2	11.8	15.5	20.5	24.3	27.7	28.8	28.5	24.9	20.3	14.8	9.4	(30)
(31)		5%	WB	5.6	6.9	9.3	13.2	17.0	20.2	20.7	20.6	17.6	14.8	10.6	6.1	(31)
(32)			MCDWB	7.3	9.9	13.8	18.7	22.8	26.4	27.6	27.7	23.0	18.4	12.8	7.4	(32)
(33)		10%	WB	4.2	5.7	8.1	12.1	16.0	19.2	19.9	19.6	16.6	13.7	9.4	4.9	(33)
(34)			MCDWB	5.8	8.0	12.0	17.3	21.3	24.9	26.3	26.2	21.1	16.8	11.0	6.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	6.7	8.3	9.5	9.7	9.7	9.9	10.0	8.9	8.5	6.0	5.1	(35)
(36)			MCDBR	7.7	9.5	11.6	12.8	12.7	12.1	12.6	13.0	12.0	11.0	9.0	7.6	(36)
(37)			MCWBR	5.5	6.1	6.7	6.5	6.0	5.2	4.7	4.8	5.3	6.2	6.0	5.7	(37)
(38)		5% WB	MCDWR	7.5	8.7	10.5	11.5	11.5	11.2	11.5	11.8	10.9	10.5	8.6	7.2	(38)
(39)			MCWBR	5.6	5.9	6.3	6.1	5.9	5.4	5.0	5.1	5.2	6.2	5.9	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.348	0.384	0.430	0.422	0.423	0.431	0.434	0.412	0.380	0.352	0.323	(40)	
(41)		taud	2.372	2.325	2.255	2.142	2.222	2.254	2.231	2.235	2.264	2.333	2.362	2.383	(41)	
(42)		Ebn at Noon	753	808	830	822	845	844	831	811	791	759	706	705	(42)	
(43)		Edh at Noon	72	93	116	142	136	133	134	128	114	92	73	65	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.11	1.92	3.13	4.55	5.48	5.97	5.87	5.23	3.70	2.39	1.28	0.85	(44)	
(45)		RadStd	0.13	0.28	0.40	0.44	0.53	0.43	0.43	0.52	0.44	0.25	0.13	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	+0.84	N/A	N/A	N/A	N/A	N/A
(47)	Regional (70 neighbors)	+0.59	N/A	N/A	N/A	+0.50	+0.47	-118	-170	+98	+55

Nomenclature: See separate page