

BUDAORS, Hungary

WMO: 128380

Lat: 47.450N

Lon: 18.967E

Elev: 132

StdP: 99.75

Time Zone: 1.00 (EUC)

Period: 82-92

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-9.0	-14.4	1.1	-9.9	-12.3	1.3	-7.5	18.0	-0.9	16.6	0.7	1.9	270	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	31.0	20.1	29.3	19.7	27.8	19.2	21.3	28.9	20.5	27.5	19.8	26.1	2.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.6	13.7	24.3	17.9	13.1	23.6	17.3	12.5	23.0	62.1	28.9	59.4	27.9	56.9	26.1	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.6	9.3	DB	-16.3	33.5	5.1	1.4	-19.9	34.5	-22.9	35.3	-25.8	36.1	-29.4	37.1	(4)
(5)			WB	-16.1	23.1	4.2	0.7	-19.1	23.6	-21.6	24.0	-24.0	24.4	-27.1	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	-0.3	1.0	5.6	11.2	16.2	18.2	21.1	20.5	16.9	10.7	4.0	1.5	(6)	
	DBStd	8.53	4.86	4.66	4.47	3.47	3.27	3.04	2.99	3.20	3.06	3.98	3.79	4.18	(7)	
	HDD10.0	1236	319	253	147	27	2	0	0	0	1	38	182	266	(8)	
	HDD18.3	3072	577	486	396	216	81	38	9	16	64	236	431	523	(9)	
	CDD10.0	1452	0	1	9	62	193	247	344	326	206	62	2	1	(10)	
	CDD18.3	246	0	0	0	1	13	34	95	83	19	0	0	0	(11)	
	CDH23.3	2089	0	0	0	4	101	276	860	698	149	2	0	0	(12)	
	CDH26.7	573	0	0	0	0	14	55	272	211	22	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.2	3.2	3.3	3.6	2.8	3.2	3.1	2.6	2.7	2.5	2.8	3.3	(14)	
(15) Precipitation	PrecAvg	560	38	34	32	43	59	67	49	51	41	38	61	46	(15)	
	PrecMax	842	87	136	59	96	148	238	128	137	117	154	173	120	(16)	
	PrecMin	327	0	0	2	9	1	8	3	0	1	0	11	1	(17)	
	PrecStd	121	22	27	17	22	36	45	31	32	31	36	40	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	16.3	21.3	24.3	28.8	30.3	33.2	32.4	29.3	23.1	15.5	14.4	(19)	
		MCWB	7.0	10.2	13.0	15.3	17.7	20.2	20.3	20.5	19.2	16.1	11.6	10.8	(20)	
	2%	DB	8.6	12.0	17.0	21.7	25.9	28.2	31.4	30.8	26.9	20.9	12.0	11.2	(21)	
		MCWB	6.3	7.9	10.6	13.7	17.1	20.1	20.5	19.7	18.1	15.2	9.2	8.8	(22)	
	5%	DB	7.4	8.8	14.6	19.6	24.1	26.4	29.7	29.1	25.1	18.8	10.3	9.1	(23)	
		MCWB	5.4	5.7	9.5	13.0	16.7	18.9	20.0	19.5	17.8	13.6	8.1	6.9	(24)	
	10%	DB	5.7	6.6	12.4	17.5	22.4	24.7	28.0	27.4	23.1	16.9	9.2	7.2	(25)	
		MCWB	4.0	4.4	8.2	11.9	15.9	17.9	19.2	18.9	16.7	12.6	7.5	5.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	10.6	13.9	16.0	19.0	21.6	22.7	22.0	19.8	17.0	12.1	11.2	(27)	
		MCDB	9.8	15.8	20.3	22.6	25.4	28.3	29.9	29.3	26.3	21.2	14.2	14.8	(28)	
	2%	WB	6.6	8.1	11.2	14.3	18.0	20.7	21.4	21.1	19.1	15.5	9.6	8.8	(29)	
		MCDB	8.4	11.5	15.9	20.2	24.3	27.0	29.4	28.9	25.8	19.9	11.1	10.9	(30)	
	5%	WB	5.6	6.1	9.9	13.3	17.2	19.6	20.6	20.2	18.1	14.4	8.6	7.2	(31)	
		MCDB	7.2	8.2	13.9	18.7	22.6	25.1	27.9	27.3	23.8	17.9	9.8	9.1	(32)	
	10%	WB	4.2	4.7	8.6	12.3	16.4	18.6	19.9	19.5	17.2	13.2	7.6	5.5	(33)	
		MCDB	5.6	6.5	12.0	16.8	21.4	23.5	26.3	25.8	22.1	16.1	9.0	7.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	6.3	8.1	8.8	9.1	9.0	10.3	10.1	10.2	9.2	6.4	4.8	(35)	
		MCDBR	6.7	10.8	12.4	12.4	12.3	12.4	13.4	13.4	13.0	12.3	8.2	6.8	(36)	
	5% WB	MCWBR	4.8	7.1	7.4	6.2	5.2	5.3	4.7	5.0	5.5	6.9	5.8	4.8	(37)	
		MCWBR	6.0	9.3	11.3	11.0	10.5	11.3	11.9	11.7	12.2	10.8	6.9	7.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.331	0.354	0.391	0.439	0.429	0.429	0.442	0.442	0.417	0.385	0.360	0.330	(40)	
		taud	2.363	2.315	2.241	2.123	2.210	2.243	2.209	2.221	2.256	2.324	2.349	2.373	(41)	
	Edn at Noon	Edn at Noon	737	797	820	812	837	838	820	802	784	749	690	689	(42)	
		Edh at Noon	73	93	117	145	137	134	137	130	114	92	74	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.04	1.85	3.10	4.57	5.52	5.99	5.87	5.26	3.70	2.37	1.25	0.79	(44)	
	RadStd	RadStd	0.12	0.27	0.46	0.44	0.58	0.45	0.42	0.51	0.43	0.26	0.12	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (51 neighbors)		+0.60	N/A	N/A	N/A	+0.52	+0.50	-123	-179	+101	+54

Nomenclature: See separate page