

AGARD, Hungary

WMO: 128460

Lat: 47.183N

Lon: 18.617E

Elev: 348

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	17.0	5.3	7.3	13.9	10.0	9.3	19.7	27.7	37.7	24.5	37.7	3.7	320	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	91.3	71.2	88.2	70.0	85.3	68.9	73.0	86.2	71.5	84.6	70.1	82.8	5.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	106.9	78.9	67.2	101.2	77.5	65.7	96.1	76.2	36.8	86.4	35.4	84.5	34.3	83.0	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.7	20.1	16.7	DB	5.2	95.5	7.3	2.8	0.0	97.5	-4.3	99.1	-8.5	100.7	-13.8	102.7
			WB	4.6	75.8	7.2	1.7	-0.5	77.1	-4.8	78.1	-8.8	79.1	-14.0	80.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	31.6	34.7	43.6	54.2	61.8	68.8	71.8	71.0	62.2	52.9	43.4	33.7
	DBStd	15.79	7.72	8.30	7.75	6.57	6.18	6.12	5.51	5.65	6.17	6.99	6.90	7.71
	HDD50	2028	569	428	222	33	2	0	0	0	0	52	216	506
	HDD65	5181	1034	847	664	328	137	31	8	12	126	376	648	970
	CDD50	2966	0	0	23	158	366	565	676	652	365	142	18	1
	CDD65	646	0	0	0	3	36	146	219	199	41	2	0	0
	CDH74	6310	0	0	0	65	387	1401	2107	1939	389	22	0	0
	CDH80	2224	0	0	0	9	72	461	815	771	96	0	0	0
	WSAvg	6.2	6.1	6.7	7.4	6.9	7.0	6.2	6.3	5.5	5.7	5.1	5.5	5.7
	PrecAvg	21.7	1.3	1.1	1.2	1.5	2.0	2.6	2.3	2.3	2.0	1.7	1.9	1.7
(15) Precipitation	PrecMax	36.1	2.8	2.7	3.6	3.7	6.5	6.9	5.0	7.9	5.6	3.8	4.1	3.9
	PrecMin	10.9	0.1	0.0	0.0	0.1	0.4	0.2	0.3	0.2	0.2	0.0	0.0	0.0
	PrecStd	5.7	0.8	0.9	0.8	0.9	1.3	1.7	1.3	1.8	1.5	1.1	0.9	0.9
	PrecStd	5.7	0.8	0.9	0.8	0.9	1.3	1.7	1.3	1.8	1.5	1.1	0.9	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.4	58.2	69.3	81.1	85.7	91.8	95.2	95.8	87.3	77.0	65.6	55.2	
	0.4% MCWB	47.7	48.3	54.0	62.4	65.6	72.3	71.1	70.9	67.3	63.4	56.9	50.7	
	2% DB	48.6	53.4	65.4	75.2	81.9	88.5	91.0	91.7	82.8	72.8	60.6	49.6	
	2% MCWB	43.9	46.3	51.9	58.0	65.0	70.5	71.4	70.7	65.7	61.2	54.2	45.8	
	5% DB	45.1	49.4	60.8	71.2	78.6	85.6	87.8	87.9	78.6	69.0	56.7	45.9	
	5% MCWB	41.3	44.2	49.4	56.4	63.7	69.3	70.6	69.4	64.3	58.9	51.7	42.9	
	10% DB	42.2	45.9	56.5	67.6	74.7	82.1	84.7	84.1	74.6	64.7	53.2	43.5	
	10% MCWB	39.3	42.4	47.8	54.4	61.7	67.9	69.3	68.6	62.2	57.0	49.4	41.0	
	0.4% WB	48.4	49.4	55.3	63.1	68.9	74.3	75.2	74.3	69.1	64.6	57.5	51.2	
	0.4% MCDB	53.2	56.7	66.5	77.8	81.1	88.0	88.0	87.6	83.7	75.1	63.8	54.8	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	44.6	46.8	52.8	59.6	66.5	72.0	73.3	72.4	67.1	62.1	54.9	46.3	
	2% MCDB	47.6	52.1	62.5	71.9	78.4	85.1	86.4	85.7	79.4	71.1	59.8	48.8	
	5% WB	41.9	44.9	50.6	57.5	64.6	70.4	71.7	70.9	65.3	60.0	52.3	43.4	
	5% MCDB	44.5	48.8	59.2	68.5	75.8	82.9	84.8	84.3	75.9	67.0	56.0	45.6	
	10% WB	39.4	42.7	48.4	55.6	62.8	68.8	70.2	69.6	63.5	57.9	49.9	41.3	
	10% MCDB	41.9	45.7	55.5	66.3	72.8	80.2	82.3	82.5	72.4	63.9	52.7	43.0	
(35) Mean Daily Temperature Range	MDBR	11.1	12.7	16.8	19.8	18.7	19.1	19.7	20.7	18.8	17.9	12.7	9.8	
	5% DB MCDBR	15.7	19.2	25.7	26.9	25.5	24.2	25.2	27.4	25.9	24.1	18.3	13.4	
	5% DB MCWBR	11.7	13.1	14.7	12.9	11.4	10.0	9.8	10.2	11.4	13.3	12.2	10.4	
	5% WB MCDBR	15.3	16.7	23.1	24.4	22.8	22.2	22.6	24.1	22.9	22.1	17.3	12.8	
	5% WB MCWBR	11.9	12.0	13.7	12.1	10.7	9.8	9.6	9.9	10.4	12.7	11.9	10.2	
	5% WB MCWBR	11.9	12.0	13.7	12.1	10.7	9.8	9.6	9.9	10.4	12.7	11.9	10.2	
(40) Clear-Sky Solar Irradiance	taub	0.333	0.357	0.394	0.443	0.432	0.432	0.444	0.445	0.421	0.388	0.361	0.332	
	taud	2.360	2.306	2.230	2.110	2.200	2.234	2.202	2.212	2.242	2.315	2.344	2.370	
	Ebn at Noon	234	252	259	257	265	265	259	254	247	237	220	219	
	Edh at Noon	23	30	38	47	44	43	44	42	37	30	24	21	
(44) All-Sky Solar Radiation	RadAvg	338	596	988	1453	1753	1904	1872	1680	1180	764	410	257	
	RadStd	41	88	143	138	178	143	136	163	138	81	39	35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		+1.12	N/A	N/A	N/A	+0.99	+0.94	-221	-324	+189	+103

Nomenclature: See separate page