

TAT, Hungary

WMO: 128470

Lat: 47.750N

Lon: 18.600E

Elev: 109

StdP: 100.02

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-8.6	-16.7	0.9	-9.7	-13.0	1.2	-7.1	9.2	1.8	8.4	1.7	1.4	140	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	32.9	21.5	31.2	20.9	29.3	20.2	22.7	29.8	21.8	28.9	21.0	27.8	3.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.3	25.8	19.5	14.4	24.8	18.7	13.7	24.0	67.3	29.9	64.1	29.0	61.3	27.9	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.1	DB	-14.3	35.5	3.9	1.8	-17.1	36.8	-19.4	37.9	-21.5	38.9	-24.3	40.2	(4)
(5)			WB	-14.7	24.5	3.6	1.0	-17.3	25.2	-19.4	25.7	-21.4	26.3	-24.1	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	-0.2	1.5	6.2	11.8	16.2	19.9	21.6	21.2	16.4	11.5	6.3	1.1	(6)	
	DBStd	8.61	4.57	4.55	4.27	3.69	3.49	3.31	3.22	3.22	3.40	3.76	4.04	4.35	(7)	
	HDD10.0	1137	316	238	129	22	2	0	0	0	1	28	124	277	(8)	
	HDD18.3	2928	574	472	376	197	83	21	7	9	78	213	362	535	(9)	
	CDD10.0	1564	0	0	11	77	194	297	361	346	191	75	12	1	(10)	
	CDD18.3	314	0	0	0	2	17	68	110	97	18	1	0	0	(11)	
	CDH23.3	3214	0	0	0	33	210	669	1120	989	184	9	0	0	(12)	
	CDH26.7	1135	0	0	0	6	40	206	445	395	44	0	0	0	(13)	
(14) Wind	WSAvg	2.5	2.8	2.9	3.0	2.8	2.5	2.2	2.2	2.0	2.1	2.3	3.0	2.9	(14)	
(15) Precipitation	PrecAvg	582	37	32	32	38	61	64	65	62	54	46	49	41	(15)	
	PrecMax	963	73	107	101	74	183	158	147	168	129	108	91	98	(16)	
	PrecMin	353	2	1	2	3	17	7	11	3	11	1	3	4	(17)	
	PrecStd	132	19	24	22	21	34	35	36	40	36	28	22	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	14.7	20.4	27.3	29.8	32.8	35.3	35.2	30.7	24.5	18.1	11.7	(19)	
		MCWB	8.7	8.7	12.0	16.6	19.2	22.1	21.5	21.4	19.6	16.9	13.7	9.3	(20)	
	2%	DB	9.2	11.3	18.1	23.7	27.6	31.0	33.1	33.0	27.7	22.1	15.5	9.7	(21)	
		MCWB	6.8	7.6	11.1	14.5	18.6	21.1	21.6	21.4	18.8	15.6	12.4	7.7	(22)	
	5%	DB	7.4	9.4	15.7	21.7	25.7	29.1	31.1	31.0	25.4	20.0	13.6	8.2	(23)	
		MCWB	5.4	6.6	9.8	13.4	17.5	20.4	21.0	20.6	17.7	14.9	10.8	6.5	(24)	
	10%	DB	5.9	7.6	13.2	19.5	23.6	27.4	29.2	28.7	23.3	17.9	11.8	6.7	(25)	
		MCWB	4.0	5.7	8.5	12.3	16.5	19.7	20.3	19.9	16.7	13.7	9.6	5.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	9.4	12.9	17.1	20.6	23.5	23.9	23.8	20.7	17.7	14.1	9.7	(27)	
		MCDB	11.5	13.6	18.9	25.1	27.7	30.5	31.5	30.9	28.7	23.3	17.5	11.3	(28)	
	2%	WB	7.2	7.9	11.4	15.2	19.3	22.2	22.7	22.5	19.5	16.5	12.6	8.1	(29)	
		MCDB	9.0	10.5	16.3	21.9	25.9	28.8	30.0	29.8	26.1	21.0	15.2	9.4	(30)	
	5%	WB	5.7	6.9	10.1	14.1	18.2	21.3	21.8	21.6	18.4	15.3	11.2	6.6	(31)	
		MCDB	7.2	9.0	14.9	19.9	24.2	27.5	28.9	28.9	23.8	18.9	13.2	7.9	(32)	
	10%	WB	4.3	5.8	8.9	13.0	17.1	20.3	21.0	20.7	17.3	14.2	9.8	5.4	(33)	
		MCDB	5.6	7.6	12.4	18.7	22.4	26.1	27.7	27.4	22.0	17.1	11.6	6.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.8	9.6	11.6	11.3	11.4	12.1	12.3	11.1	9.6	6.5	5.0	(35)	
		MCDBR	7.4	9.6	14.4	15.2	14.7	14.0	15.2	15.6	14.4	12.5	9.0	6.5	(36)	
	5% WB	MCWBR	5.4	6.6	8.4	7.8	7.1	6.2	6.0	6.2	6.9	7.0	6.0	5.1	(37)	
		MCWBR	7.2	8.6	12.6	13.6	13.4	12.7	13.5	14.2	12.6	11.4	8.3	6.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.330	0.353	0.391	0.438	0.430	0.431	0.443	0.442	0.416	0.385	0.361	0.329	(40)	
		taud	2.353	2.313	2.239	2.128	2.202	2.237	2.204	2.220	2.258	2.320	2.345	2.370	(41)	
	Edn at Noon		732	795	818	812	835	836	818	800	783	745	684	684	(42)	
			73	93	117	143	138	135	137	130	114	92	73	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.01	1.82	3.06	4.50	5.42	5.89	5.74	5.15	3.64	2.30	1.20	0.77	(44)	
	RadStd		0.13	0.27	0.47	0.44	0.59	0.46	0.44	0.50	0.45	0.25	0.13	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (63 neighbors)		+0.58	N/A	N/A	+0.87	+0.55	+0.51	-122	-174	+92	+44

Nomenclature: See separate page