

KEKESTETO, Hungary

WMO: 128510

Lat: 47.867N

Lon: 20.017E

Elev: 1015

StdP: 89.71

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.3	-11.3	-20.7	0.7	-8.1	-17.4	0.9	-8.3	11.7	-1.7	10.7	-2.2	4.4	40	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	25.1	17.5	23.5	16.9	22.0	16.3	18.6	23.1	17.7	22.1	16.9	21.2	2.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	13.7	21.2	16.0	12.9	20.1	15.1	12.2	19.3	57.3	23.3	54.2	22.3	51.5	21.2	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.8	7.9	-14.7	27.3	2.6	1.7	-16.6	28.6	-18.1	29.6	-19.5	30.6	-21.4	31.8		
(5)			-15.7	20.1	2.6	0.9	-17.5	20.7	-19.0	21.2	-20.5	21.7	-22.3	22.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	-3.6	-2.6	0.7	6.7	11.3	14.7	16.5	16.5	11.5	7.0	2.1	-2.3		
	DBStd	8.39	4.24	4.47	4.53	4.55	4.07	3.79	3.52	3.63	3.93	4.58	4.51	4.25		
	HDD10.0	1986	423	353	289	117	34	6	1	1	28	115	237	382		
	HDD18.3	4341	681	586	547	349	219	119	77	79	206	350	486	641		
	CDD10.0	745	0	0	1	17	74	147	204	203	75	23	1	0		
	CDD18.3	58	0	0	0	0	1	11	22	23	2	0	0	0		
	CDH23.3	153	0	0	0	0	1	24	64	63	1	0	0	0		
	CDH26.7	11	0	0	0	0	0	1	6	4	0	0	0	0		
(14) Wind	WSAvg	3.9	4.7	4.4	4.3	3.9	3.5	3.2	3.3	3.0	3.4	4.0	4.8	4.8		
(15) Precipitation	PrecAvg	608	31	36	34	42	66	65	80	64	54	50	46	39		
	PrecMax	1160	75	111	120	112	230	165	196	219	185	128	108	97		
	PrecMin	335	2	0	0	0	15	17	0	0	0	0	0	0		
	PrecStd	166	20	28	27	29	44	35	51	48	40	36	28	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	8.3	12.8	19.1	22.5	25.7	27.2	27.2	22.5	17.4	12.3	7.4		
		MCWB	4.4	4.2	7.3	11.8	14.8	18.1	18.0	17.7	15.5	12.7	9.2	4.5		
	2%	DB	4.9	6.0	10.4	16.5	20.4	23.6	25.1	25.1	20.2	15.5	10.6	5.8		
		MCWB	3.6	3.2	6.1	10.3	14.3	17.3	17.3	17.4	14.5	11.8	8.1	3.9		
	5%	DB	3.5	4.5	8.4	14.6	18.8	21.8	23.3	23.4	18.4	14.2	9.3	4.5		
		MCWB	2.6	2.7	4.9	9.2	13.5	16.4	17.1	16.7	14.0	11.2	7.2	3.1		
	10%	DB	2.1	3.2	6.6	12.9	17.2	20.3	21.7	21.9	16.9	12.9	8.0	3.3		
		MCWB	1.4	2.0	3.8	8.1	12.6	15.6	16.4	16.2	13.2	10.5	6.5	2.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	5.1	8.2	12.6	16.3	19.5	19.6	19.7	16.2	13.8	10.4	5.9		
		MCDB	5.9	6.9	11.3	17.7	20.6	24.0	24.3	23.9	20.6	15.8	11.6	6.4		
	2%	WB	3.9	4.0	6.6	10.9	14.9	18.1	18.6	18.5	15.3	12.7	8.8	4.6		
		MCDB	4.6	5.3	9.2	15.4	19.1	22.4	23.2	22.9	18.9	14.6	10.0	5.2		
	5%	WB	2.8	3.0	5.5	9.6	14.0	17.0	17.7	17.5	14.4	11.7	7.8	3.5		
		MCDB	3.3	4.1	7.8	13.6	17.9	20.9	22.1	22.1	17.8	13.6	8.9	4.2		
	10%	WB	1.4	2.1	4.3	8.6	13.0	16.0	16.9	16.6	13.6	10.7	6.7	2.4		
		MCDB	2.0	3.0	6.4	12.2	16.7	19.7	21.0	21.2	16.5	12.5	7.8	3.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	4.1	5.2	6.4	6.5	6.3	6.3	5.9	5.0	4.6	3.7	3.6		
		MCDBR	3.9	5.0	7.0	7.5	7.6	7.3	7.5	6.8	6.1	5.2	4.4	4.4		
	5% WB	MCWBR	3.6	3.7	4.7	4.5	5.0	4.9	4.4	4.3	4.1	3.6	3.5	3.7		
		MCWBR	4.0	4.4	6.2	7.0	7.0	6.8	6.9	6.5	5.6	5.0	4.2	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.299	0.330	0.370	0.362	0.364	0.375	0.374	0.351	0.328	0.309	0.282		
		taud	2.435	2.419	2.396	2.301	2.352	2.362	2.328	2.343	2.391	2.450	2.470	2.461		
	Ebn at Noon		807	868	890	881	900	897	880	867	855	820	763	760		
		Edh at Noon	65	82	99	120	119	119	121	114	99	79	63	57		
(44) All-Sky Solar Radiation	RadAvg		0.99	1.80	3.07	4.48	5.42	5.86	5.71	5.17	3.64	2.29	1.20	0.76		
	RadStd		0.13	0.28	0.44	0.44	0.57	0.42	0.48	0.47	0.44	0.26	0.13	0.10		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	+0.72	+0.75	N/A	N/A	N/A	N/A
(47)	Regional (51 neighbors)	+0.61	N/A	N/A	+0.94	+0.57	+0.54	-125	-186	+97	+45

Nomenclature: See separate page