

POROSZLO, Hungary

WMO: 128660

Lat: 47.650N

Lon: 20.633E

Elev: 302

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.3	14.4	3.3	6.6	11.9	7.9	8.3	17.3	18.9	37.0	16.8	34.7	2.7	40	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	92.2	72.1	89.3	70.7	86.6	69.3	74.3	87.8	72.5	85.6	70.9	83.4	5.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.9	111.1	82.0	68.1	104.3	79.0	66.5	98.7	76.7	37.9	87.8	36.3	85.6	34.8	83.8	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	13.5	11.5	4.5	96.5	7.0	2.6	-0.5	98.4	-4.6	99.9	-8.5	101.3	-13.6	103.2
			3.9	76.6	6.6	1.8	-0.8	77.9	-4.7	79.0	-8.4	80.0	-13.2	81.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	30.0	33.4	42.9	54.2	62.6	69.2	72.2	71.7	63.0	52.2	42.2	32.5	(6)
	DBStd	16.63	8.27	8.62	7.99	6.51	6.56	6.06	5.75	5.62	6.47	7.08	7.40	7.76	(7)
	HDD50	2212	619	466	241	32	2	0	0	0	61	249	542		(8)
	HDD65	5354	1084	885	686	328	123	28	8	10	113	397	685	1007	(9)
	CDD50	3043	0	1	20	157	394	575	689	672	390	130	15	0	(10)
	CDD65	709	0	0	0	3	50	152	232	218	53	1	0	0	(11)
	CDH74	7460	0	0	0	72	592	1575	2419	2239	545	18	0	0	(12)
	CDH80	2810	0	0	0	13	160	548	1017	924	147	1	0	0	(13)
(14) Wind	WSAvg	4.8	4.9	5.2	6.0	5.4	5.1	4.9	4.8	4.4	4.5	4.2	4.4	4.3	(14)
(15) Precipitation	PrecAvg	21.9	1.1	1.4	1.2	1.6	2.2	2.6	3.0	2.1	2.0	1.7	1.6	1.8	(15)
	PrecMax	36.4	3.0	3.1	3.9	3.6	6.1	6.6	5.4	8.4	5.6	5.2	3.5	3.3	(16)
	PrecMin	13.9	0.2	0.1	0.0	0.1	0.4	0.8	0.8	0.2	0.1	0.0	0.0	0.2	(17)
	PrecStd	6.0	0.7	0.9	0.9	1.0	1.4	1.4	1.4	1.7	1.4	1.2	0.9	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	58.1	69.3	81.6	89.3	92.4	97.2	95.8	88.6	76.4	63.7	52.5	(19)
		MCWB	45.6	48.1	54.6	62.7	67.1	73.7	72.4	71.2	68.3	63.5	56.5	48.6	(20)
	2%	DB	46.7	51.9	64.4	75.3	84.3	88.9	92.7	91.9	84.2	72.0	59.0	48.2	(21)
		MCWB	42.8	45.9	51.9	58.3	65.9	70.8	72.8	71.0	66.2	60.2	53.4	45.4	(22)
	5%	DB	43.3	48.2	60.6	71.8	80.5	86.3	89.5	88.7	80.3	68.4	55.7	45.1	(23)
		MCWB	40.5	43.7	49.4	56.5	64.2	69.3	71.4	70.4	64.8	58.8	51.5	42.8	(24)
	10%	DB	40.5	45.0	56.2	68.2	76.6	83.1	86.1	85.5	76.4	64.4	52.6	42.4	(25)
		MCWB	38.6	41.7	47.2	54.2	62.2	67.7	69.8	69.0	63.1	56.9	49.5	40.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	49.4	55.8	63.1	69.3	76.1	76.4	75.7	69.9	64.7	57.3	49.4	(27)
		MCDB	51.1	55.7	66.2	79.1	84.3	88.8	89.8	89.0	85.3	73.8	62.4	51.7	(28)
	2%	WB	43.4	46.6	52.8	60.0	67.2	73.5	74.4	73.5	67.6	61.8	54.6	46.0	(29)
		MCDB	46.2	50.6	62.1	72.7	80.7	85.0	88.7	87.3	80.7	69.8	58.2	48.0	(30)
	5%	WB	40.9	44.1	50.4	57.7	65.5	71.3	72.6	71.7	65.8	59.7	52.0	43.2	(31)
		MCDB	42.9	47.5	58.7	69.0	77.9	82.6	86.4	85.1	77.8	66.4	54.5	44.6	(32)
	10%	WB	38.6	42.0	48.0	55.7	63.6	69.3	70.9	70.1	64.1	57.7	49.8	40.9	(33)
		MCDB	40.5	45.1	54.9	65.9	74.8	79.9	83.6	82.8	73.9	63.3	52.4	42.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	12.9	17.9	21.3	21.6	21.8	22.6	23.0	21.0	18.9	13.1	9.0	(35)
		MCDBR	13.1	18.0	25.6	27.1	27.6	25.5	27.2	27.3	26.8	24.3	17.8	12.2	(36)
	5% WB	MCWBR	10.2	13.1	14.8	13.3	12.5	10.7	11.0	11.2	12.1	13.9	12.3	10.0	(37)
		MCWBR	12.2	15.9	22.8	24.7	25.1	23.2	25.3	25.2	24.2	21.7	15.5	11.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.331	0.354	0.393	0.447	0.432	0.434	0.450	0.448	0.418	0.386	0.360	0.330	(40)
		taud	2.336	2.298	2.236	2.103	2.208	2.235	2.196	2.207	2.256	2.322	2.341	2.352	(41)
	Ebn at Noon		232	252	259	255	265	264	258	252	248	237	218	216	(42)
		Edh at Noon	23	30	37	47	44	43	44	42	36	29	23	21	(43)
(44) All-Sky Solar Radiation	RadAvg		312	579	996	1444	1759	1893	1849	1687	1179	753	401	239	(44)
	RadStd		38	95	133	137	169	120	161	147	134	84	39	36	(45)

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)	+1.13	N/A	N/A	+1.75	+0.99	-225	-340	+180	+83

Nomenclature: See separate page