

EGER, Hungary

WMO: 128700

Lat: 47.900N

Lon: 20.383E

Elev: 715

StdP: 14.32

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	16.7	1.6	6.1	18.7	6.3	7.8	21.5	18.6	41.0	16.1	39.7	3.7	340	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	90.6	68.9	87.2	67.9	84.2	66.7	71.5	84.7	69.8	83.5	68.3	81.1	6.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	102.2	77.8	65.4	96.3	75.7	63.8	90.9	74.0	35.7	84.6	34.2	83.6	33.0	81.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.6	13.3	11.6	DB	7.8	94.6	4.9	3.3	4.3	97.0	1.5	99.0	-1.3	100.8	-4.8	103.2
			WB	6.7	73.9	4.5	2.0	3.5	75.4	0.9	76.6	-1.7	77.8	-4.9	79.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	30.7	34.4	43.2	53.9	61.5	67.7	71.0	70.9	62.2	52.5	43.0	32.7	(6)
(7)		DBStd	15.93	7.91	7.66	7.91	6.86	6.41	6.22	5.79	5.89	6.46	7.23	7.44	7.60	(7)
(8)		HDD50	2131	598	438	233	38	2	0	0	0	1	59	227	535	(8)
(9)		HDD65	5322	1063	858	676	335	145	42	13	13	128	389	660	1000	(9)
(10)		CDD50	2887	0	0	22	156	360	531	650	648	367	136	17	0	(10)
(11)		CDD65	605	0	0	0	3	37	124	198	196	45	2	0	0	(11)
(12)		CDH74	5595	0	0	0	42	351	1099	1861	1874	358	10	0	0	(12)
(13)		CDH80	1827	0	0	0	3	61	315	670	696	82	0	0	0	(13)
(14)	Wind	WSAvg	5.4	5.0	5.3	6.2	6.1	5.8	5.5	5.7	5.1	5.2	4.9	5.1	4.7	(14)
(15)	Precipitation	PrecAvg	22.8	1.1	1.2	1.2	1.7	2.5	2.7	3.1	2.4	2.0	1.7	1.7	1.6	(15)
(16)		PrecMax	41.4	2.8	3.1	4.2	4.4	8.0	6.5	6.8	7.8	5.7	4.4	3.8	3.3	(16)
(17)		PrecMin	13.1	0.1	0.0	0.0	0.0	0.6	0.7	0.1	0.2	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.2	0.7	0.9	1.0	1.1	1.6	1.4	1.8	1.7	1.5	1.2	1.0	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.4	57.3	67.9	78.6	85.6	91.2	95.3	95.1	86.9	75.5	63.4	51.8	(19)
(20)			MCWB	45.1	47.1	52.7	59.8	63.7	69.4	69.5	68.7	65.9	61.1	55.0	46.7	(20)
(21)		2%	DB	47.4	51.3	63.5	74.0	81.2	86.9	90.4	91.0	81.9	71.3	59.3	48.4	(21)
(22)			MCWB	43.6	44.3	50.2	57.1	63.2	68.4	69.1	68.8	64.0	59.4	52.3	45.0	(22)
(23)		5%	DB	44.3	47.9	59.4	70.3	77.9	83.7	86.9	87.1	78.0	67.8	56.1	45.6	(23)
(24)			MCWB	41.1	42.5	47.8	55.1	62.0	66.7	68.4	67.6	62.4	57.7	50.6	42.6	(24)
(25)		10%	DB	41.5	45.1	55.7	66.9	74.6	80.6	83.4	83.6	74.4	64.1	53.5	42.9	(25)
(26)			MCWB	38.8	41.1	46.0	53.2	60.2	65.7	67.1	66.7	60.8	55.8	49.1	40.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.7	47.7	54.0	61.4	66.8	73.6	73.4	73.1	67.4	62.8	56.5	47.9	(27)
(28)			MCD B	49.5	54.5	64.5	75.2	79.6	85.9	85.4	86.5	83.6	72.5	61.2	49.9	(28)
(29)		2%	WB	44.1	45.3	51.2	58.4	64.9	70.7	71.4	71.1	65.4	60.4	53.8	45.4	(29)
(30)			MCD B	46.6	49.8	60.3	70.9	77.9	82.8	85.2	84.5	78.7	69.2	57.7	48.0	(30)
(31)		5%	WB	41.5	43.5	49.3	56.3	63.2	68.6	69.8	69.3	63.7	58.7	51.6	43.0	(31)
(32)			MCD B	43.9	46.9	57.3	67.8	75.1	80.2	83.8	83.2	74.9	66.2	55.1	45.3	(32)
(33)		10%	WB	39.0	41.5	47.2	54.4	61.5	66.7	68.3	67.8	62.0	56.7	49.4	40.7	(33)
(34)			MCD B	41.3	44.7	54.6	64.9	72.3	77.6	80.8	81.3	72.0	62.7	52.9	42.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	12.1	15.7	18.2	18.9	19.2	20.0	20.3	18.1	15.9	11.3	8.9	(35)
(36)			MCDBR	12.1	16.0	22.0	23.0	23.4	23.0	24.3	24.6	22.7	20.3	15.3	10.8	(36)
(37)			MCWBR	9.2	11.0	12.5	11.3	10.8	10.0	9.2	9.3	9.7	10.6	9.8	8.5	(37)
(38)		5% WB	MCD BR	11.1	13.8	19.6	21.1	21.1	20.6	21.5	21.8	20.1	18.5	13.3	9.9	(38)
(39)			MCWBR	8.9	10.2	12.0	10.8	10.7	10.0	9.1	9.4	9.4	10.2	9.3	8.2	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.321	0.343	0.381	0.433	0.421	0.423	0.438	0.436	0.406	0.377	0.352	0.320	(40)
(41)		taud		2.352	2.319	2.267	2.142	2.230	2.256	2.219	2.232	2.282	2.343	2.364	2.374	(41)
(42)		Ebn at Noon		235	256	263	259	267	267	261	256	252	239	220	220	(42)
(43)		Edh at Noon		23	29	36	45	43	42	43	41	35	28	23	20	(43)
(44)	All-Sky Solar Radiation	RadAvg		309	567	979	1421	1726	1858	1809	1652	1160	730	385	236	(44)
(45)		RadStd		39	93	134	137	175	125	161	143	138	86	41	32	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (50 neighbors)	N/A	N/A	N/A	+1.73	+1.01	+0.90	-227	-338	+176	+81

Nomenclature: See separate page