

NYIREGYHAZA, Hungary

WMO: 128920

Lat: 47.984N

Lon: 21.692E

Elev: 338

StdP: 14.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	15.0	2.8	6.4	14.7	7.3	8.1	17.8	24.2	31.6	21.5	30.5	7.1	40	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	90.7	70.7	87.5	69.4	84.5	68.0	72.8	85.9	71.1	83.9	69.5	81.7	6.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.6	106.4	78.9	66.7	99.4	76.9	65.1	94.1	75.2	36.6	86.3	35.1	84.0	33.7	81.7	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	17.8	15.6	5.8	95.2	5.9	3.0	1.5	97.3	-1.9	99.1	-5.2	100.7	-9.5	102.9		
			4.9	75.0	5.5	2.1	0.9	76.5	-2.3	77.7	-5.4	78.9	-9.4	80.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	29.8	33.6	42.3	53.5	61.5	67.7	70.7	61.0	51.5	41.5	32.2		
		DBStd	16.24	8.23	8.47	8.01	7.44	6.67	6.23	5.71	5.59	6.65	7.51	8.03		
		HDD50	2297	627	461	256	49	3	0	0	1	74	273	553		
		HDD65	5545	1092	880	702	350	148	43	15	16	156	421	704		
		CDD50	2803	0	1	18	154	359	530	641	627	333	120	19		
		CDD65	574	0	0	0	4	39	124	191	177	37	2	0		
		CDH74	5564	0	0	0	61	430	1132	1842	1736	347	16	0		
		CDH80	1910	0	0	0	10	87	359	705	663	86	0	0		
(14)	Wind	WSAvg	7.6	7.5	8.2	9.4	8.7	8.0	7.4	7.0	6.8	7.1	6.9	7.3	7.0	
(15)	Precipitation	PrecAvg	21.8	1.1	1.3	1.2	1.8	2.3	2.5	2.7	1.9	2.0	1.8	1.6	1.6	
(16)		PrecMax	36.2	2.4	3.5	4.4	4.1	6.0	4.3	6.0	4.6	6.0	3.9	2.8	3.8	
(17)		PrecMin	16.3	0.3	0.1	0.2	0.1	0.7	0.8	0.5	0.3	0.6	0.1	0.0	0.1	
(18)		PrecStd	4.5	0.5	0.8	1.0	1.0	1.1	1.1	1.5	1.1	1.2	1.1	0.7	0.9	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	50.7	57.5	68.0	80.4	86.1	91.4	95.3	95.0	87.8	76.2	65.4	53.9		
(20)		0.4% MCWB	45.7	48.5	52.7	60.9	65.0	71.7	71.3	70.6	67.8	61.8	55.2	49.3		
(21)		2% DB	46.8	51.9	62.7	74.6	82.4	87.6	90.6	90.8	81.9	72.2	60.7	49.1		
(22)		2% MCWB	43.8	45.4	50.4	57.0	63.7	69.5	70.8	70.7	65.3	60.0	53.1	45.6		
(23)		5% DB	43.4	48.3	58.7	70.8	79.0	84.2	87.1	87.1	77.9	68.1	56.6	45.6		
(24)		5% MCWB	41.1	43.3	48.1	55.3	62.5	68.0	69.7	69.5	63.7	58.5	51.1	43.0		
(25)		10% DB	40.4	45.2	54.9	67.2	75.2	80.9	83.8	83.4	73.7	63.9	53.2	42.6		
(26)		10% MCWB	38.4	41.3	46.4	53.6	60.9	66.4	68.5	68.1	61.6	56.3	49.0	40.3		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	46.9	48.9	54.5	61.8	67.5	73.9	74.6	75.3	68.8	63.6	56.8	49.1		
(28)		0.4% MCDB	49.4	55.5	63.8	77.7	80.6	86.7	87.4	87.9	83.6	72.5	62.8	52.8		
(29)		2% WB	44.0	46.0	51.7	59.0	65.3	71.7	72.6	72.8	66.7	61.1	54.0	45.9		
(30)		2% MCDB	46.6	50.8	60.0	71.5	78.1	83.6	86.4	85.4	79.3	70.2	59.4	48.6		
(31)		5% WB	41.3	44.0	49.5	56.7	63.7	69.7	71.1	70.7	64.7	59.1	51.7	43.2		
(32)		5% MCDB	43.2	47.8	57.1	68.0	75.7	80.8	84.5	83.5	75.8	66.9	55.9	45.3		
(33)		10% WB	38.7	41.6	47.1	54.8	62.0	67.7	69.5	68.9	62.7	57.0	49.3	40.6		
(34)		10% MCDB	40.4	44.7	53.9	65.0	73.0	78.4	81.4	81.5	71.8	62.9	53.0	42.3		
(35)	Mean Daily Temperature Range	MDBR	8.9	11.5	15.4	18.8	19.5	19.6	20.7	21.5	18.9	17.2	12.2	8.2		
(36)		5% DB MCDBR	11.0	16.0	21.1	24.5	25.5	24.5	26.3	26.9	24.8	23.2	17.7	11.4		
(37)		5% DB MCWBR	8.6	11.1	12.0	11.4	10.4	10.0	10.1	10.4	10.7	12.5	11.4	9.0		
(38)		5% WB MCDBR	10.4	14.9	19.3	22.2	22.9	22.3	23.9	24.6	22.5	21.0	15.6	11.0		
(39)		5% WB MCWBR	8.4	10.8	11.8	11.0	10.2	9.8	9.9	10.5	10.4	11.8	10.4	9.0		
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.356	0.394	0.448	0.433	0.435	0.454	0.451	0.415	0.385	0.361	0.331		
(41)		taud	2.306	2.269	2.211	2.090	2.198	2.225	2.179	2.187	2.251	2.306	2.319	2.328		
(42)		Ebn at Noon	229	249	258	254	264	264	256	251	248	235	215	213		
(43)		Edh at Noon	24	31	38	47	44	43	45	43	36	29	23	21		
(44)	All-Sky Solar Radiation	RadAvg	307	563	970	1409	1713	1846	1798	1649	1156	724	384	232		
(45)		RadStd	41	91	134	139	176	122	163	142	141	90	45	33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+1.60	+1.85	N/A	N/A	N/A	N/A
(47)	Regional (49 neighbors)	+1.08	N/A	N/A	+1.66	+0.92	+0.86	-216	-324	+167	+74

Nomenclature: See separate page