

SZENTGOTTHARD FARKASFA, Hungary

WMO: 129100

Lat: 46.917N

Lon: 16.317E

Elev: 1027

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	17.0	6.1	7.8	17.3	10.2	9.6	21.0	14.9	40.7	13.1	38.7	3.1	40	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	88.2	69.5	85.0	68.8	81.9	67.4	71.8	83.3	70.1	81.8	68.5	79.5	5.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	107.0	76.9	66.2	100.4	75.2	64.7	95.0	73.2	36.1	83.4	34.6	81.8	33.3	79.6	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.2	11.2	9.6	7.6	92.2	5.3	4.4	3.8	95.3	0.7	97.8	-2.3	100.3	-6.1	103.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	31.7	35.3	42.5	51.2	58.8	65.4	68.6	68.0	59.5	51.0	42.0	33.1	
	DBStd	14.78	7.86	8.40	7.85	7.04	6.22	6.33	5.63	5.69	5.97	7.28	7.75	7.27	
	HDD50	2176	569	414	252	70	6	0	0	0	3	79	258	525	
	HDD65	5616	1034	831	697	414	207	72	30	33	183	436	690	989	
	CDD50	2421	0	3	20	106	280	461	577	557	289	109	18	1	
	CDD65	386	0	0	0	1	16	83	142	125	19	0	0	0	
	CDH74	3645	0	0	0	22	202	791	1331	1150	144	5	0	0	
	CDH80	1078	0	0	0	1	25	218	425	393	16	0	0	0	
Wind	WSAvg	4.2	3.7	4.2	4.8	5.0	4.7	4.3	4.2	3.8	3.9	3.9	3.8	3.6	
Precipitation	PrecAvg	29.8	1.2	1.5	1.6	1.9	2.9	3.6	3.6	3.5	3.4	2.6	2.4	1.7	
	PrecMax	40.3	3.4	4.6	3.7	4.4	5.2	6.5	6.1	7.4	7.2	6.9	6.2	3.5	
	PrecMin	21.7	0.2	0.3	0.2	0.1	1.0	1.1	0.5	0.2	0.9	0.0	0.2	0.0	
	PrecStd	4.7	0.8	1.3	1.0	1.0	1.2	1.3	1.5	1.8	1.9	1.6	1.4	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	62.0	68.5	77.1	83.0	89.6	92.2	93.7	82.2	74.3	65.3	56.0	
		MCWB	46.6	48.3	52.1	59.9	64.9	70.2	70.8	69.6	67.3	62.4	56.3	50.7	
	2%	DB	50.4	55.7	64.0	72.3	79.2	85.8	88.0	88.2	78.0	69.6	60.3	50.5	
		MCWB	44.0	46.1	50.8	56.5	63.8	69.4	69.8	68.9	65.7	60.6	53.8	46.1	
	5%	DB	46.4	51.7	59.8	68.5	75.7	82.2	84.8	84.3	74.6	66.0	56.3	46.4	
		MCWB	41.7	43.9	48.9	54.8	62.0	68.0	68.8	68.6	63.9	58.7	51.4	42.4	
	10%	DB	42.6	47.8	55.6	64.9	72.2	78.7	81.6	80.7	70.9	62.2	53.0	42.7	
		MCWB	38.7	41.4	46.5	52.8	59.9	65.9	67.3	67.2	61.6	56.6	49.5	40.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.0	49.4	53.9	61.2	67.5	73.2	74.4	73.8	69.4	63.8	57.2	50.9
			MCDB	53.1	59.8	64.8	73.9	79.0	84.0	86.2	85.1	80.0	72.3	63.3	55.2
2%		WB	44.8	46.7	51.5	58.2	65.1	70.6	71.9	71.4	66.8	61.2	54.4	46.8	
		MCDB	49.4	54.7	61.9	69.7	76.3	82.1	83.6	82.9	75.9	67.9	59.1	50.2	
5%		WB	42.0	44.4	49.4	55.8	63.0	68.7	70.1	69.5	64.7	59.3	52.1	43.0	
		MCDB	45.8	50.5	58.6	65.9	73.2	80.2	81.8	81.3	72.5	64.7	56.0	45.5	
10%		WB	39.5	42.0	47.2	53.8	61.0	67.0	68.4	67.9	62.8	57.4	49.7	40.4	
		MCDB	42.3	47.0	54.5	62.8	70.4	77.2	79.1	78.6	69.5	61.7	52.4	42.2	
Mean Daily Temperature Range	5% DB	MDBR	11.5	15.0	17.6	19.5	19.8	20.0	20.5	20.2	17.7	16.4	11.8	10.5	
		MCDBR	17.6	21.2	24.3	25.7	25.3	24.8	25.3	25.7	22.3	20.5	17.5	16.3	
		MCWBR	11.7	12.9	13.4	12.9	12.2	10.9	10.0	9.7	10.9	11.8	11.3	11.8	
	5% WB	MCDBR	16.5	19.9	22.6	23.2	23.1	23.4	23.4	23.5	21.1	19.2	16.1	15.2	
		MCWBR	11.5	12.5	12.9	12.0	11.8	10.8	10.2	10.4	10.8	11.4	10.8	11.7	
Clear-Sky Solar Irradiance	taub		0.317	0.341	0.378	0.424	0.419	0.424	0.427	0.431	0.405	0.378	0.347	0.317	
	taud		2.397	2.348	2.274	2.164	2.226	2.252	2.243	2.245	2.289	2.339	2.381	2.427	
	Ebn at Noon		243	260	266	263	269	267	265	258	254	242	227	229	
	Edh at Noon		23	29	36	44	43	42	42	40	35	29	23	20	
All-Sky Solar Radiation	RadAvg		370	626	1003	1417	1709	1869	1847	1637	1161	759	407	286	
	RadStd		44	89	121	141	160	133	135	168	141	80	48	41	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+1.58	+1.66	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	+0.97	N/A	N/A	+1.62	+0.92	+0.79	-198	-272	+169	+108

Nomenclature: See separate page